



Los Angeles Regional Water Quality Control Board

August 14, 2024

Tim Beaman, P.E.
Assistant Public Works Director
City of Oxnard
300 West Third Street
Oxnard, CA 93030

**ADMINISTRATIVE REVISIONS TO WASTE DISCHARGE REQUIREMENTS (WDRs)
AND NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
PERMIT – CITY OF OXNARD, OXNARD WATER RESOURCE RECOVERY
FACILITY, OXNARD, CA (NPDES PERMIT NO. CA00054097, CI-2022)**

Dear Tim Beaman:

On May 23, 2024, the Los Angeles Regional Water Quality Control Board (Los Angeles Water Board) adopted NPDES permit Order No. R4-2024-0252 for the Oxnard Water Resource Recovery Facility. The Los Angeles Water Board has determined a minor modification is needed in the Monitoring and Reporting Program (MRP) to require monthly grab sample monitoring for ammonia in addition to a 24-hour composite. This additional monitoring is needed to assess compliance with the instantaneous maximum effluent limitation for ammonia. In accordance with section 122.63 of title 40 of the Code of Federal Regulations, the following administrative revision shall be effective immediately:

Table E-8 in section 4.1 of the MRP shall specify a monthly grab sample in addition to a 24-hour composite sample under the “Sample Type” column, as follows:

Table E-8. Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Notes
Ammonia (as N)	mg/L	24-hr composite <u>and</u> <u>grab</u>	Monthly	b

NORMA CAMACHO, CHAIR | SUSANA ARREDONDO, EXECUTIVE OFFICER

If you have any questions, please contact Steven Webb at Steven.Webb@waterboards.ca.gov or at (213) 576-6793, or Danielle Robinson at Danielle.Robinson@waterboards.ca.gov or at (213) 576-6656.

Sincerely,

Jenny Newman  Digitally signed by Jenny Newman
Date: 2024.08.14 16:13:02 -07'00'
Water Boards

for Susana Arredondo
Executive Officer
Los Angeles Regional Water Quality Control Board

cc: Jan Hauser, City of Oxnard
Roberto Fuentes, City of Oxnard
Eric Ngo, City of Oxnard