
Central Coast Regional Water Quality Control Board

September 16, 2022

Sent Via Electronic Mail

John Diodati
San Luis Obispo County Public Works Department
Oak Shores Development CSA-7a
976 Osos St. Room 206
San Luis Obispo, CA, 93408
Email: jdiodati@co.slo.ca.us

Dear John Diodati,

OAK SHORES DEVELOPMENT CSA-7A, 2537 RIDGE RIDER ROAD, BRADLEY, CA, 93426, SAN LUIS OBISPO COUNTY:

- **NOTICE OF APPLICABILITY FOR ENROLLMENT IN ORDER WQ 2014-0153-DWQ, *GENERAL WASTE DISCHARGE REQUIREMENTS FOR SMALL DOMESTIC WASTEWATER TREATMENT SYSTEMS***
- **TRANSMITTAL OF MONITORING AND REPORTING PROGRAM NO. R3-2022-0055**
- **TERMINATION OF INDIVIDUAL PERMIT ORDER NO. 01-130**

The Central Coast Regional Water Quality Control Board (Central Coast Water Board) reviewed the Form 200, November 2016 Revised Report of Waste Discharge (received on August 27, 2021), and available documents associated with the domestic wastewater treatment system at Oak Shores Development CSA-7a which is owned by San Luis Obispo County Public Works Department. The wastewater system is currently regulated pursuant to Order No. 01-130. On September 23, 2014, the State Water Resources Control Board (State Water Board) adopted *WQ 2014-0153-DWQ, General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems* (General Permit). The Central Coast Water Board reviewed your facility information and determined the updated permit requirements and monitoring and reporting program contained in the General Permit are more appropriate for your facility than Order No. 01-130.

This letter serves as a notice of applicability for enrollment in the General Permit for the discharge of wastewater from the Oak Shores Development CSA-7a wastewater system.

This letter also includes a wastewater facility operation summary and site-specific requirements and limitations (Attachment 1), figures (Attachment 2), and a monitoring and reporting program (Attachment 3).

JANE GRAY, CHAIR | MATTHEW T. KEELING, EXECUTIVE OFFICER

San Luis Obispo County Public Works Department must comply with the following:

1. **General Permit** – San Luis Obispo County Public Works Department must comply with all conditions and requirements of the General Permit and this notice of applicability, including attachments. As described in the General Permit, ongoing operation, maintenance, monitoring, and reporting are required. A copy of the General Permit can be found electronically at the following link:

https://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf

Monitoring and Reporting Program – San Luis Obispo County Public Works Department must comply with the requirements of Monitoring and Reporting Program No. R3- 2022-0055, enclosed with this letter (Attachment 3). Your first semiannual report is due on **August 1, 2023**

Monitoring reports and annual reports must be provided electronically in searchable PDF with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permitting/docs/transmittal_sheet.pdf

San Luis Obispo County Public Works Department must submit all reports/documents and laboratory data (using the transmittal sheet as the cover page) to the publicly accessible State Water Board's GeoTracker^{1,2} database with applicable Electronic Submittal of Information (ESI) requirements under the wastewater system-specific global identification number WDR100035384 at:

https://www.waterboards.ca.gov/ust/electronic_submittal/index.html

The attached monitoring and reporting program outlines the GeoTracker electronic reporting requirements.

2. **Fees** – San Luis Obispo County Public Works Department paid an annual fee on January 4, 2022 for coverage in the existing individual permit, Order No. 01-130. This payment covers permit fees for the 2021-2022 fiscal year.

San Luis Obispo County Public Works Department must pay an annual fee to maintain coverage in the General Permit. Annual fees are determined by the State Water Board fee program and cover the state fiscal year of July 1 through

¹ Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguid2.pdf

² Additional information available at: <http://geotracker.waterboards.ca.gov/>

June 30. Fees are charged (and updated) annually and are based on the facility's threat and complexity ratings. Your facility is currently rated with a threat and complexity of 2B.

A copy of the current state fee schedule is available at the following link:

https://www.waterboards.ca.gov/resources/fees/water_quality/#wdr

3. **Notification** – The Central Coast Water Board will be notified of your enrollment at a regularly scheduled public meeting on December 8-9, 2022. Details about that meeting are available on our website at:
http://www.waterboards.ca.gov/centralcoast/board_info/agendas/
4. **Future Discharge Modifications** – Pursuant to Water Code section 13260, you must inform the Central Coast Water Board at least 120 days prior to modifying your discharge. If there are any significant changes in either treatment or disposal methodologies, or the volume or character of the treated wastewater, you must notify the Central Coast Water Board immediately of such changes.
5. **Responsible Party** – San Luis Obispo County Public Works Department is responsible for the management and disposal of the wastewater in compliance with the conditions of the General Permit. Any noncompliance with this General Permit constitutes a violation of the California Water Code and subjects San Luis Obispo County Public Works Department to enforcement action and termination of enrollment under this General Permit.
6. **Change in Ownership** – In the event of any change in control or ownership of the property, San Luis Obispo County Public Works Department must notify the succeeding owner or operator of the existence of this General Permit by letter, a copy of which shall be immediately forwarded to the Central Coast Water Board. In addition, the succeeding owner must submit a Form 200 for enrollment in the General Permit. Once both of these things have occurred, the new owner or operator can be enrolled in the General Permit and your enrollment in the General Permit can be terminated. Contact the Central Coast Water Board for a change of ownership form.
7. **Certified Operator** – San Luis Obispo County Public Works Department is required to comply with the operator certification requirements³ administered by the State Water Board's Office of Operator Certification, which currently requires a Class I certified operator onsite to maintain and operate the treatment system.

³ Title 23 Division 3. Chapter 26 Wastewater Treatment Plant Classification, Operator Certification and Contract Operator Registration.

https://www.waterboards.ca.gov/water_issues/programs/operator_certification/docs/ocr_clean.pdf

If you have any questions, please contact **Rachel Hohn** at (805) 542-4789 **or by email at Rachel.Hohn@waterboards.ca.gov**, or Jennifer Epp at Jennifer.Epp@waterboards.ca.gov.

Sincerely,

Jennifer Epp  Digitally signed by Jennifer Epp
Date: 2022.09.16 08:15:23 -07'00'

for Matthew T. Keeling
Executive Officer

Attachments:

Attachment 1: Wastewater System Operation Summary and Site-Specific
Requirements and Limitations

Attachment 2: Figures

Attachment 3: Monitoring and Reporting Program Order No. R3-2022-0055

cc:

Faith Zenker, Department of Public Works, fzenker@co.slo.ca.us
Cori Burnett, Department of Public Works, cburnett@co.slo.ca.us
Luis Gonzales, Facility Operator, lagonzales@co.slo.ca.us
Stephanie Dayton, owner of WWTP land, sdayton@oakshores.us
Timothy Bean, owner of spray field ponds and emergency ponds land,
tim@nacimientowater.com
James Bishop, James.Bishop@Waterboards.ca.gov
Rachel Hohn, Rachel.Hohn@Waterboards.ca.gov
Jesse Woodard, Jesse.Woodard@waterboards.ca.gov
Jennifer Epp, Jennifer.Epp@Waterboards.ca.gov
WDR Program, RB3-WDR@Waterboards.ca.gov GeoTracker

ECM/CIWQS = CW-245581

GeoTracker No. = GT- WDR100035384

Rev 3/2/22

ECM Subject Name = San Luis Obispo County Service Area #7, Oak Shores
Development Wastewater Permit 0153 Enrollment

R:\RB3\Shared\WDR\WDR Facilities\San Luis Obispo Co\Oak Shores San Luis
CSA\2021_ROW_D\0153 Enrollment\0153-NOA_Oak Shores Development_draft3.docx

ATTACHMENT 1

**WASTEWATER SYSTEM OPERATION SUMMARY AND SITE-SPECIFIC
REQUIREMENTS AND LIMITATIONS**

OWNERSHIP AND WASTEWATER SYSTEM DESCRIPTION

Ownership and facility information submitted by San Luis Obispo County Public Works Department to the Central Coast Water Board is shown in Table 1.

Table 1. Owner and Wastewater Facility Information

Facility Name	Oak Shores Development CSA-7a
Facility Address	2537 Ridge Rider Road Bradley, CA, 93426
Parcel Numbers	012-201-043
Latitude/Longitude	35.753042, -120.98495
Facility Contact	Faith Zenker
Owner of Facility	San Luis Obispo County Public Works Dept
Legally Responsible Official of Owner	John Diodati
Owner Mailing Address	976 Osos St. Room 206 San Luis Obispo, CA, 93408
Billing Address	976 Osos St, Room 206 San Luis Obispo, CA, 93408
Permitted Design Flow (gallons per day, gpd)	Permitted flow is 100,000. The 2005 Capacity and Demand Report calculated the existing facility's peak treatment capacity to be 126,300 gpd, however the permitted flow is capped at 100,000.
Baseline Flow (average annual flow) in gpd	68,900
Operators	Luis Gonzales, Grade 3
Waste type and Service Area	Domestic and municipal waste from
Threat to Water Quality	2
Complexity	B
For Internal Use	
Fee Code	58
Primary Place Type	Wastewater Treatment Facility
Facility Type	Municipal/Domestic
Facility Waste Type	Domestic and Municipal Wastewater
Regulatory measure Type	Enrollee - WDR
Reclamation Included	No
EPA Approved Pretreatment Program	No

Oak Shores Development CSA-7a is located at Lake Nacimiento. The average depth to groundwater is 45 feet.

WASTEWATER SYSTEM OPERATION SUMMARY

The Oak Shores Development CSA-7a wastewater is generated from the recreational community of Oak Shores. Occupancy, and corresponding wastewater flow, varies throughout the year with highest occupancy, and flows, occurring during the summer months. The maximum monthly average daily flow for 2017 to 2021 ranged from 41,400 to 68,900 gpd. There are currently 657 sewer connections to the wastewater collection system and historically 26 percent have full-time occupancy.

The Oak Shores Development CSA-7a collection system includes manholes and cleanouts which are typically underwater. The County conducts annual dye-testing for leak testing. They also utilize flow data to confirm there is no significant stormwater inflow during wet weather or high lake level conditions.

A summary of the system is included in Table 2 below. A facility site map and dispersal system layout are shown in Attachment 2.

Table 2. Permitted Secondary Treatment & Disposal Technologies and Capacity

Design Flows	The average monthly design flow is 100,000 gallons per day
Headworks/Preliminary Treatment	The headworks consists of a flow meter and an influent manual bar screen
Treatment	Secondary Treatment: Wastewater is treated two 400,000 gallon circular aerated treatment ponds which are operated in series followed by a 1.62-million-gallon maturation/polishing pond
Disinfection¹	NA
Effluent Storage	NA
Disposal	Effluent wastewater is pumped to two spray field ponds prior to application to the spray fields. The ponds are 1.8 miles from the treatment plant, the Upper Pond has a storage volume of 1,319,689 gallons and a surface area of 53,766 sf. The Lower Pond has a storage volume of 2,645,656 gallons with a surface area of 55,355 sf
Biosolids/Sludge Production and Handling	NA

WASTEWATER SYSTEM-SPECIFIC REQUIREMENTS AND LIMITATIONS

San Luis Obispo County Public Works Department must operate the facility in accordance with the General Order and this notice of applicability.⁴ The facility's secondary treatment includes two in-line aeration ponds followed by a polishing pond. San Luis Obispo County Public Works Department must operate the wastewater treatment system to comply with the effluent limits below.

A. Effluent limits

San Luis Obispo County Public Works Department must comply with the site-specific limits listed in Table 3.

Table 3. Wastewater Limits for Wastewater Ponds

Constituent	Unit	Limit	Point of Compliance	Sample Location ¹
Flow (monthly average)	gpd	100,000	Effluent	IS-1
Total Suspended Solids (TSS)	mg/L	--	Effluent after aerations ponds	ES-1
Five-Day Biochemical Oxygen Demand (BOD ₅)	mg/L	90	Effluent after aerations ponds	ES-1
Total N	% Influent versus Effluent	50%	Effluent below root zone	ES-1

¹ Refer to monitoring and reporting program for sampling locations

GROUNDWATER LIMITS

As stated in the General Permit, Section C, the discharge must not pollute groundwater or surface waters, adversely affect beneficial uses of groundwater, or cause an exceedance of Basin Plan water quality objectives. Specifically, San Luis Obispo County Public Works Department must manage the facility to comply with water quality

⁴ General Order section B.1.b. states that treatment and disposal of wastewater must demonstrate best practicable treatment or control for wastewater, which shall be demonstrated by compliance with the General Order, effluent limits in the General Order, and compliance with site-specific limits set forth in this notice of applicability.

objectives for groundwater found in Section 3.3.4 of the *Water Quality Control Plan for the Central Coastal Basin* (Basin Plan).⁵ These objectives include:

- 1) General objectives for taste and odors and radioactivity for all groundwaters.
- 2) Because the receiving groundwater has a designated use of municipal and domestic supply, objectives for bacteria and organic chemicals, inorganic chemicals, and radionuclides, which are established at the drinking water maximum contaminant levels (MCLs) as defined in California Code of Regulations, title 22, division 4, chapter 15 2.
- 3) The facility does not discharge into a designated groundwater basin, so there are no groundwater basin-specific objectives.

Central Coast Water Board does not require first-encountered groundwater monitoring wells at this time. If effluent water quality indicates exceedances of the Basin Plan groundwater objectives, the Central Coast Water Board may require groundwater monitoring in the future

⁵ Current edition, June 2019 is available at: [Water Quality Control Plan for the Central Coastal Basin \(ca.gov\)](https://www.waterboards.ca.gov/water_quality_control_plan_for_the_central_coastal_basin)

ATTACHMENT 2
FIGURES



Figure 1. Site Location Map




Figure 2. Site Map adapted from San Luis Obispo County, Aerial Maps of Wastewater System





Figure 3. Spray Field and Ponds (left) and Kavanaugh Emergency Percolation Ponds (right) adapted from San Luis Obispo County, Aerial Maps of Wastewater System

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION**

MONITORING AND REPORTING PROGRAM NO R3-2022-0055

for

**OAK SHORES DEVELOPMENT CSA-7A
SAN LUIS OBISPO COUNTY**

This monitoring and reporting program (MRP) describes requirements for monitoring a wastewater treatment system for San Luis Obispo County Public Works Department for the Oak Shores Development CSA-7a system located at 2537 Ridge Rider Road in Bradley, California 93426.

San Luis Obispo County Public Works Department owns and operates the wastewater system that is subject to the notice of applicability dated September 16, 2022, for coverage in Order WQ 2014-0153-DWQ, *General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems* (General Permit).

1. SAMPLING AND ANALYSIS

All samples must be representative of the volume and nature of the discharge or matrix of materials sampled. The name of the sampler, sample type (grab or composite), time, date, location, bottle type, and any preservative used for each sample shall be recorded on the sample chain of custody form. The chain of custody form must also contain all custody information including date, time, and to whom the samples were relinquished. If composite samples are collected, the basis for sampling (time or flow weighted) shall be approved by the Central Coast Regional Water Quality Control Board (Central Coast Water Board). Unless otherwise specified below, sampling shall be performed as shown in Table 1.

Table 1. Sampling and Monitoring Schedule

Monitoring Period	Sample Collection Months
Annually	October
Semiannually	April and October
Quarterly	January, April, July, and October
Monthly	Each month of the year

Field test instruments (such as those to test pH, dissolved oxygen, and electrical conductivity) may be used provided that they are used by a State Water Resources Control Board (State Water Board) California Environmental Laboratory Accreditation Program certified laboratory, or:

1. The user is trained in proper use and maintenance of the instruments;

2. The instruments are field calibrated prior to monitoring events at the frequency recommended by the manufacturer;
3. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency; and
4. Field calibration reports are maintained and available for at least three years.

2. WATER SUPPLY MONITORING

Representative samples of the water supply must be collected and analyzed as shown in Table 2 from the production wells prior to any disinfection.

In lieu of the required water supply sampling, San Luis Obispo County Public Works Department may request approval to submit a Well Identification Number and the reporting year's consumer confidence report (annual water quality report or drinking water quality report), as required by the State Water Board Division of Drinking Water and/or county. San Luis Obispo County Public Works Department must report the results of any constituent monitored more frequently than is required by the monitoring program shown in this monitoring and reporting program. San Luis Obispo County Public Works Department must also report detectable concentrations (above the reporting limit) for any other constituent that has a published maximum contaminant level (MCL).

Table 2. Water Supply Monitoring

Parameter	Units	Type of Sample	Sampling Frequency	Reporting Frequency
TDS	mg/L	Grab	Annually	Annually
Nitrate and Nitrite (as N)	mg/L	Grab	Annually	Annually

mg/L denotes milligrams per liter

3. MONITORING LOCATIONS

Monitoring location information, including nomenclature that shall be used when reporting data to the GeoTracker database (described below), is shown in Table 3.

Table 3. Monitoring Locations

Sample Title	GeoTracker Field Point Code	Sample Description
Influent Sample – 1	IS-1	Representative grab sample after screening and before the aeration ponds
Effluent Sample – 1	ES-1	Representative grab sample from effluent pipeline prior to spray field




Figure 1. Process Flow Diagram with Sampling Locations. IS-1 and ES-1 represent compliance sampling locations. Sample locations at the aeration ponds are for process monitoring.

4. POND SYSTEM MONITORING

4.1 Influent Monitoring

Influent samples shall be taken from a location that provides representative samples of the wastewater and flow rate. At a minimum, influent monitoring shall consist of the following:

Table 4. Influent Monitoring

Constituent	Units	Sample Type	Sample Frequency	Reporting Frequency
Flow Rate ^a	gpd	Meter	Continuous	Semi Annually
Biochemical Oxygen Demand	mg/L	Grab	Monthly	Semi Annually
Total Suspended Solids (TSS)	mg/L	Grab	Monthly	Semi Annually
Total Nitrogen (as N)	mg/L	Grab	Monthly	Semi Annually
Nitrate	mg/L	Grab	Monthly	Semi Annually

gpd denotes gallons per day.

mg/L denotes milligrams per liter.

4.2 Wastewater Pond Monitoring

All wastewater and treated wastewater storage ponds (lined and unlined) shall be monitored as specified below:

Table 5. Pond Monitoring

Constituent	Units	Sample Type	Sample Frequency	Reporting Frequency
Dissolved Oxygen	mg/L	Grab	Monthly	Semi Annually
Freeboard	0.1 feet	Measurement	Monthly	Semi Annually
Odors	--	Observation	Monthly	Semi Annually
Berm condition	--	Observation	Monthly	Semi Annually

mg/L denotes milligrams per liter.

4.3 Effluent Monitoring

Effluent samples shall be taken from a location that provides representative samples of the wastewater. At a minimum, effluent monitoring shall consist of the following:

Table 6. Effluent Monitoring

Constituent	Units	Sample Type	Sample Frequency	Reporting Frequency
Flow Rate ^a	gpd	Meter	Continuous	Semi Annually
Biochemical Oxygen Demand, 5-day (BOD ₅)	mg/L	Grab	Monthly	Semi Annually
Total Suspended Solids (TSS)	mg/L	Grab	Monthly	Semi Annually
Total Nitrogen (as N)	mg/L	Grab	Monthly	Semi Annually
Nitrate (as N)	mg/L	Grab	Monthly	Semi Annually
Dissolved Oxygen	mg/L	Grab	Monthly	Semi Annually
Total Dissolved Solids (TDS)	mg/L	Grab	Monthly	Semi Annually

mg/L denotes milligrams per liter.

5. LAND APPLICATION AREA MONITORING

The Discharger shall monitor land application areas when wastewater and/or supplemental irrigation water is applied. If wastewater/supplemental irrigation water is not applied during a reporting period, the monitoring report shall so state. Land application areas monitoring shall include the following:

Table 7. Land Application Area Monitoring

Constituent	Units	Sample Type	Sampling Frequency	Reporting Frequency
-------------	-------	-------------	--------------------	---------------------

Supplemental Irrigation	gpd	Meter ^a	Monthly	Semi Annually
Wastewater Flow ^a	gpd	Meter ^a	Monthly	Semi Annually
Local Rainfall	Inches	Weather Station ^b	Monthly	Semi Annually
Acreage Applied ^c	Acres	Calculated	Monthly	Semi Annually
Application Rate	gal/acre/mo	Calculated	Monthly	Semi Annually
Soil Erosion Evidence	--	observation	Monthly	Semi Annually
Containment Berm Condition	--	observation	Monthly	Semi Annually
Soil Saturation/Ponding	--	observation	Monthly	Semi Annually
Nuisance Odors/Vectors	--	observation	Monthly	Semi Annually
Discharge Off-Site	--	observation	Monthly	Semi Annually

gpd denotes gallons per day.

- a. Meter requires meter reading, a pump run time meter, or other approved method.
- b. Weather station may be site-specific station or nearby governmental weather reporting station.
- c. Acreage applied denotes the acreage to which wastewater is applied.

6. COLLECTION SYSTEM MAINTENANCE

San Luis Obispo County Public Works Department must submit records of annual leak testing results and any maintenance performed on the sewer collection system within the past year.

Table 8. Collection System Maintenance Monitoring

Constituent	Sample Type	Sampling Frequency	Reporting Frequency
Leak testing (dye-testing)	observation	Annually	Annually

7. REPORTING

The semiannual monitoring reports must be submitted in accordance with Table 9.

Table 9. Semiannual Monitoring Reports

Report	Monitoring Period	Report Due Date
First Semiannual Report	January 1 to June 30	August 1
Second Semiannual Report	July 1 to December 31	February 1

At a minimum, the semiannual reports must include:

- **Facility Information and Description** - Briefly describe your facility, treatment process, and disposal process with references to figures.

- **Data Tables** - Tabular summaries of all monitoring data (water supply, influent, effluent, and groundwater) compared to effluent limits, as appropriate. Submit the results of any pollutant or parameter monitored more frequently than is required by this monitoring program.
- **Compliance and Performance Discussion** -
 - Disclosure of any noncompliance (violations) with of the notice of applicability and/or General Permit requirements, including a description, it's cause, the exact date(s) and time(s), and the steps taken or planned to reduce, eliminate and prevent recurrence of the noncompliance.
 - An evaluation (graphs recommended) of the treatment facilities' performance, including percent removal of the main pollutants (BOD₅, TSS, Total Nitrogen) over time, nuisance conditions, system problems, etc.
 - A discussion of any data gaps and potential deficiencies in the monitoring system or reporting program.
- **Disposal Area Inspection** - Report the results of the disposal area inspections, as described in Section 5.
- **Operator Information** - List the name and contact information for the wastewater operators responsible for operation, maintenance, and/or system monitoring.
- **Flow Evaluation** - A summary in tabular format of the maximum and average flows for each month and comparison to permitted flows.
- **Figures** - A wastewater treatment process flow diagram with a label for the monitoring locations and a scaled facility map showing the treatment system, discharge points, and wells (supply and groundwater, if present).
- **Laboratory Sheets** - Copies of laboratory analytical report(s) and chain of custody form(s).

8. ELECTRONIC SUBMITTAL

All monitoring reports must be provided electronically in a searchable PDF format, with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permiiting/docs/transmittal_sheet.pdf

San Luis Obispo County Public Works Department must submit all reports/documents and laboratory analytical data (influent, effluent, groundwater data) to the State Water Board's GeoTracker^{6,7} database consistent with applicable Electronic Submittal of

⁶ Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguid2.pdf

⁷ Additional information available at:

<https://geotracker.waterboards.ca.gov/>

Information (ESI) requirements under a wastewater system-specific global identification number **WDR100035384** at:

<https://geotracker.waterboards.ca.gov/esi/login>

Table 10 summarizes the GeoTracker electronic reporting requirements. For general questions, please contact the GeoTracker Help Desk: Geotracker@waterboards.ca.gov.

Table 10. GeoTracker Electronic Submittal Information (ESI) Data Requirements

Electronic Submittal	Description of Action	Action	Frequency
Reports and Documents	Complete copy of all documents including monitoring reports (in searchable PDF format) and any other associated documents related to the Wastewater System.	Upload directly to GeoTracker all monitoring reports (in searchable PDF format) and any other associated documents.	On or before the due dates required by this General Permit and for other documents when required by the Central Coast Water Board.
Laboratory Data	All analytical data (including geochemical data) in electronic deliverable format (EDF). This includes all water, soil, and vapor samples collected when monitoring a discharge.	Upload, or direct your State Certified Laboratory staff to upload, all laboratory data directly to GeoTracker.	On or before the due date of the required monitoring report
Location data (Geo XY)	Name, classify, and identify the location (latitude and longitude) of all sampling points. Monitoring wells must be surveyed, influent and effluent sample locations must be identified on the GeoTracker mapping tool under "non-surveyed data."	Upload the location data (surveyed and non-surveyed) to the GeoTracker Geo_XY file.	These data points are required prior to laboratory data uploads. Must be added every time a permanent monitoring point is established.
Geo Map	Site layout, map of facilities, wastewater treatment system, and disposal area(s).	Upload the Site layout PDF to the GeoTracker site plan file.	One time, or when the facility is modified.

9. TECHNICAL REPORTS

San Luis Obispo County Public Works Department must submit to GeoTracker the three reports described in General Permit *Section E. 1. Technical Report Preparation Requirements* by the dates included in Table 11. If this information is already contained in an operation and maintenance manual or similar document, that may be submitted in compliance with this requirement.

Table 11. Technical Report Submittal Due Dates

Report	Report Due Date
Spill Prevention & Emergency Response Plan	90 days from date of General Permit enrollment ¹
Sampling and Analysis Plan	90 days from date of General Permit enrollment ¹
Sludge Management Plan	90 days from date of General Permit enrollment ¹

¹ The date of General Permit enrollment is September 16, 2022

10. LEGAL REQUIREMENTS

The Central Coast Water Board's requirements that San Luis Obispo County Public Works Department submit the technical and monitoring reports described in this monitoring and reporting program are made pursuant to [section 13267 of the California Water Code](#). Failure to submit reports in accordance with schedules established by this General Permit and notice of applicability with attachments or failure to submit a report of sufficient technical quality to be acceptable to the Central Coast Water Board may subject San Luis Obispo County Public Works Department to enforcement action pursuant to [section 13268 of the California Water Code](#).

The Central Coast Water Board needs the required information to ensure compliance with the notice of applicability and the General Permit. San Luis Obispo County Public Works Department is required to submit this information because it is subject to the General Permit and is responsible for the discharge.

The burden, including costs, of the reports bears a reasonable relationship to their need and the benefits to be obtained. The requirement for the reports is necessary to ensure compliance with the General Permit, notice of applicability, and monitoring and reporting program to protect water quality.

San Luis Obispo County Public Works Department must implement the above monitoring program as of the date of this MRP. The Central Coast Water Board may rescind or modify the MRP at any time. San Luis Obispo County Public Works Department must not implement any changes to this MRP unless and until a revised MRP is issued by the Central Coast Water Board.

Ordered by:

Jennifer Epp Digitally signed by Jennifer Epp
Date: 2022.09.16 08:16:34
-07'00'
Water Boards

for Matthew T. Keeling
Executive Officer