

Central Coast Regional Water Quality Control Board

September 30, 2022

Sent Via Electronic Mail

Santa Cruz County CSA #7
Matt Machado, Director of Public Works
Boulder Creek Golf and Country Club
701 Ocean St Room 410
Santa Cruz, California 95060
Email: Matt.Machado@santacruzcounty.us

Dear Matt Machado,

BOULDER CREEK GOLF AND COUNTRY CLUB CSA #7, 16901 BIG BASIN HIGHWAY, BOULDER CREEK, SANTA CRUZ COUNTY:

- **NOTICE OF APPLICABILITY FOR BOULDER CREEK COUNTRY GOLF AND COUNTRY CLUB'S ENROLLMENT IN ORDER WQ 2014-0153-DWQ, GENERAL WASTE DISCHARGE REQUIREMENTS FOR SMALL DOMESTIC WASTEWATER TREATMENT SYSTEMS**
- **TRANSMITTAL OF MONITORING AND REPORTING PROGRAM NO. R3-2022-0045**
- **TERMINATION OF INDIVIDUAL PERMIT ORDER NO. R3-2001-0034**

The Central Coast Regional Water Quality Control Board (Central Coast Water Board) reviewed the report of waste discharge and associated material (received on May 2, 2022) submitted by County of Santa Cruz, Public Works Department, Sanitation Division (hereafter County of Santa Cruz) on behalf of Boulder Creek Golf and Country Club. On September 23, 2014, the State Water Resources Control Board (State Water Board) adopted *Order WQ 2014-0153-DWQ, General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems* (General Permit). The Central Coast Water Board reviewed your facility information and determined the updated permit requirements and monitoring and reporting program contained in the General Permit are more appropriate for your facility than Order No. R3-2001-0034.

This letter also includes a wastewater facility operation summary and site-specific requirements and limitations (Attachment 1), figures (Attachment 2), and a monitoring and reporting program (Attachment 3).

County of Santa Cruz must comply with the following:

1. **General Permit** – County of Santa Cruz must comply with all conditions and requirements of the General Permit and this notice of applicability, including

JANE GRAY, CHAIR | MATTHEW T. KEELING, EXECUTIVE OFFICER

attachments. As described in the General Permit, ongoing operation, maintenance, monitoring, and reporting are required. A copy of the General Permit can be found electronically at the following link:

https://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf

2. Monitoring and Reporting Program – County of Santa Cruz must comply with the requirements of Monitoring and Reporting Program No. R3-2022-0045, enclosed with this letter (Attachment 3). Your first semiannual report is due on **February 1, 2023**

Monitoring reports must be provided electronically in searchable PDF with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permitting/docs/transmittal_sheet.pdf

County of Santa Cruz must submit all reports/documents and laboratory data (using the transmittal sheet as the cover page) to the publicly accessible State Water Board's GeoTracker^{1,2} database with applicable Electronic Submittal of Information (ESI) requirements under the wastewater system-specific global identification number WDR100035838 at:

https://www.waterboards.ca.gov/ust/electronic_submittal/index.html

The attached monitoring and reporting program outlines the GeoTracker electronic reporting requirements.

3. Installation and Operations Report – System installations must be inspected during construction and certified by a qualified professional (e.g., licensed engineer, environmental health specialist). The qualified professional must certify to the Central Coast Water Board that the wastewater treatment and disposal systems are installed per design. The qualified professional must inspect and conduct final testing of the systems in operation. County of Santa Cruz must provide certification of correct installation and operation to the Central Coast Water Board within **45-days of start-up and with the first annual report**.

As-built drawings must be submitted to the Central Coast Water Board **within**

¹ Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguide2.pdf

² Additional information available at: <http://geotracker.waterboards.ca.gov/>

45-days of start-up and with the first annual report if the system installation varies from the design plans in any way.

4. **Fees** – County of Santa Cruz paid an annual fee on March 10, 2022 for coverage in the existing individual permit, Order No. R3-2001-0034. This payment covers permit fees for the 2021-2022 fiscal year.

County of Santa Cruz must pay an annual fee to maintain coverage in the General Permit. Annual fees are determined by the State Water Board fee program and cover the state fiscal year of July 1 through June 30. Fees are charged (and updated) annually and are based on the facility's threat and complexity ratings. Your facility is currently rated with a threat and complexity of 2B.

A copy of the current state fee schedule is available at the following link:

https://www.waterboards.ca.gov/resources/fees/water_quality/#wdr

5. **Notification** – The Central Coast Water Board will be notified of your enrollment at a regularly scheduled public meeting December 8-9, 2022. Details about that meeting are available on our website at:

http://www.waterboards.ca.gov/centralcoast/board_info/agendas/

6. **Future Discharge Modifications** – Pursuant to Water Code section 13260, you must inform the Central Coast Water Board at least 120 days prior to modifying your discharge. If there are any significant changes in either treatment or disposal methodologies, or the volume or character of the treated wastewater, you must notify the Central Coast Water Board immediately of such changes.
7. **Responsible Party** – County of Santa Cruz is responsible for the management and disposal of the wastewater in compliance with the conditions of the General Permit. Any noncompliance with this General Permit constitutes a violation of the California Water Code and subjects County of Santa Cruz to enforcement action and termination of enrollment under this General Permit.
8. **Change in Ownership** – In the event of any change in control or ownership of the property, County of Santa Cruz must notify the succeeding owner or operator of the existence of this General Permit by letter, a copy of which shall be immediately forwarded to the Central Coast Water Board. In addition, the succeeding owner must submit a Form 200 for enrollment in the General Permit. Once both of these things have occurred, the new owner or operator can be enrolled in the General Permit and your enrollment in the General Permit can be terminated. Contact the Central Coast Water Board for a change of ownership form.

- 9. Certified Operator** – County of Santa Cruz is required to comply with the operator certification requirements³ administered by the State Water Board's Office of Operator Certification, which currently requires a certified operator onsite to maintain and operate the treatment system.
- 10. Service Agreement** – Boulder Creek Golf and Country Club has an agreement in place with County of Santa Cruz, Public Works Department, Sanitation Division such that a qualified service provider/vendor will perform required maintenance, sampling, and reporting to the Central Coast Water Board. A service agreement with a qualified service provider must remain in place until the Central Coast Water Board agrees in writing that such an agreement is no longer necessary.

If you have any questions, please contact **Danial Woldearegay at (805) 549-3892 or by email at danial.woldearegay@Waterboards.ca.gov**, or Jennifer Epp at Jennifer.Epp@waterboards.ca.gov.

Sincerely,

for Matthew T. Keeling
Executive Officer

Attachments:

- Attachment 1: Wastewater System Operation Summary and Site-Specific Requirements and Limitations
- Attachment 2: Figures
- Attachment 3: Monitoring and Reporting Program No. R3-2022-0045

cc:

Isaac Bojorquez, Isaac.bojorquez@santacruzcounty.us
Helen Clary, Boulder Creek Golf and Country Club, hele@bouldercreekgolf.com
Marilyn Underwood, Santa Cruz County, Marilyn.Underwood@santacruzcounty.us
Danial Woldearegay, Danial.Woldearegay@waterboards.ca.gov
Jesse Woodard, Jesse.Woodard@Waterboards.ca.gov
Jennifer Epp, Jennifer.Epp@Waterboards.ca.gov
WDR Program, RB3-WDR@Waterboards.ca.gov GeoTracker

³ Title 23 Division 3. Chapter 26 Wastewater Treatment Plant Classification, Operator Certification and Contract Operator Registration.
https://www.waterboards.ca.gov/water_issues/programs/operator_certification/docs/ocr_clean.pdf

Boulder Creek Golf
and Country Club NOA

September 30, 2022

ECM/CIWQS = CW-210116

GeoTracker No. = GT- WDR100035838

Rev 6/16/22

Subject Name = Boulder Creek NOA 0153

R:\RB3\Shared\WDR\WDR Facilities\Santa Cruz Co\Santa Cruz County Sanitation
District\CSA #7 - Boulder Creek Country Club\2022\For review

ATTACHMENT 1

**WASTEWATER SYSTEM OPERATION SUMMARY AND SITE-SPECIFIC
REQUIREMENTS AND LIMITATIONS**

1. OWNERSHIP AND WASTEWATER SYSTEM DESCRIPTION

Ownership and facility information submitted by County of Santa Cruz to the Central Coast Water Board is shown in Table 1.

Table 1. Owner and Wastewater Facility Information

Facility Name	Boulder Creek Golf and Country Club
Facility Address	16901 Big Basin Highway Boulder Creek, California 95006
Parcel Number(s)	086-402-12
Latitude/Longitude	37.151674/-122.162019
Onsite Manager	Isaac Bojorquez
Owner of Facility	Boulder Creek Golf and Country Club Helen Clary
Legally Responsible Official of Owner	Matt Machado, Director of Public Works
Owner Mailing Address	2750 Lode Street Santa Cruz, California 95062
Billing Address	2750 Lode Street Santa Cruz, California 95062
Permitted Design Flow (gallons per day, gpd)	Maximum average monthly 100,000
Baseline Flow (average annual flow) in gpd	40,000
Operators	County of Santa Cruz, Public Works Department, Sanitation Division Isaac Bojorquez, CPO System control and data analysis (SCADA) system present
Waste type and Service Area	Domestic wastewater from residential homes located within County Service Area #7 in Santa Cruz.
Threat to Water Quality	2
Complexity	B

For Internal Use	
Fee Code	58
Primary Place Type	Wastewater Treatment Facility
Facility Type	Municipal/Domestic
Facility Waste Type	Domestic Wastewater
Regulatory measure Type	Enrollee - WDR
Reclamation Included	No
EPA Approved Pretreatment Program	No

Depth to ground water is estimated to be 25 feet and generally migrates in an easterly direction. The nearest ground water well is approximately 1000 feet up gradient from the leachfields disposal area.

2. WASTEWATER SYSTEM OPERATION SUMMARY

The extended aeration treatment system is composed of conveyance piping, lift stations, sewage grinder system, equalization tank, aeration basin, clarifiers, effluent pump station, leachfields and SCADA controls system. A summary of the system is included in Table 2 below. A facility site map and dispersal system layout are shown in Attachment 2.

Table 2. Permitted Treatment & Disposal Technologies and Capacity

Permitted Design Flows	Maximum month average flow rate of 100,000 gallons per day Influent Average Flow 40,000 gallons per day
Treatment	The facility is an extended aeration wastewater treatment package plant.
Effluent Storage	70,000 gallon equalization tank when needed
Disposal	Four Leachfields
Biosolids/Sludge Production and Handling	Solids are hauled from the plant and disposed of at the County of Santa Cruz transmission line facility at East Cliff Station.

3. WASTEWATER SYSTEM-SPECIFIC REQUIREMENTS AND LIMITATIONS

County of Santa Cruz must operate the facility in accordance with the General Permit⁴ and this notice of applicability.⁵ below.

A. Effluent limits

County of Santa Cruz must comply with the site-specific limits listed in Table 3.

Table 3. Wastewater Limits for extended aeration treatment system

Constituent	Unit	Limit	Point of Compliance ¹
Flow	gpd	100,000 (monthly average) 104,000 (maximum daily flow)	Influent (IS-1)
Total Suspended Solids (TSS)	mg/L	30 (monthly average) 45 (7-day average)	Effluent after extended aeration (ES-1)
Five-Day Biochemical Oxygen Demand (BOD ₅)	mg/L	30 (monthly average) 45 (7-day average)	Effluent after extended aeration (ES-1)
Total N	% Influent versus Effluent	50% Removal	Effluent after extended aeration (ES-1)

¹ Refer to monitoring and reporting program for sampling locations

4. GROUNDWATER LIMITS

As stated in the General Permit, Section C, the discharge (from the extended aeration wastewater treatment package plant) must not pollute groundwater or surface waters, adversely affect beneficial uses of groundwater, or cause an exceedance of Basin Plan water quality objectives. Specifically, County of Santa Cruz must manage the facility to comply with water quality objectives for groundwater found in Section 3.3.4 of the *Water Quality Control Plan for the Central Coastal Basin* (Basin Plan).⁶ These objectives include:

⁴ General Permit sections B.3, B.5, and B.7 are not applicable for this facility.

⁵ General Permit section B.1.b. states that treatment and disposal of wastewater must demonstrate best practicable treatment or control for wastewater, which shall be demonstrated by compliance with the General Permit, effluent limits in the General Permit, and compliance with site-specific limits set forth in this notice of applicability.

⁶ Current edition, June 2019 is available at:

https://www.waterboards.ca.gov/centralcoast/publications_forms/publications/basin_plan/docs/2019_basin_plan_r3_complete.pdf

- 1) General objectives for taste and odors and radioactivity for all groundwaters.
- 2) Because the receiving groundwater has a designated use of municipal and domestic supply, objectives for bacteria and organic chemicals, inorganic chemicals, and radionuclides, which are established at the drinking water maximum contaminant levels (MCLs) as defined in California Code of Regulations, title 22, division 4, chapter 15 2.
- 3) Specific objectives for the groundwater basin where the discharge occurs. This facility discharges into the Big Basin near Boulder Creek, and those Basin Plan's groundwater objectives are included in Table 4.

Table 4. Basin Plan, Median Groundwater Objectives (mg/L)

Constituent	Median Groundwater Objective for Big Basin near Boulder Creek
Total Dissolved Solids (TDS)	250
Sodium	20
Chloride	30
Sulfate	50
Boron	0.2
Total Nitrogen as N	5

mg/L = milligrams per liter

The Central Coast Water Board does not require first-encountered groundwater monitoring wells at this time. If effluent water quality indicates exceedances of the Basin Plan groundwater objectives, the Central Coast Water Board may require installation of groundwater monitoring wells in the future.

ATTACHMENT 2 FIGURES





Figure 1. Site Location Map



2




Figure 3. Dispersal System Layout

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION**

MONITORING AND REPORTING PROGRAM NO. R3-2022-0045

for

**BOULDER CREEK GOLF AND COUNTRY CLUB
SANTA CRUZ COUNTY SERVICE AREA (CSA) #7
SANTA CRUZ COUNTY**

This monitoring and reporting program describes requirements for monitoring a wastewater treatment system for Boulder Creek Golf and Country Club, 16901 Big Basin Highway in Boulder Creek, California 95006

County of Santa Cruz operates the wastewater system that is subject to the notice of applicability dated September 30, 2022, for coverage in *Order WQ 2014-0153-DWQ, General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems* (General Permit).

1. SAMPLING AND ANALYSIS

All samples must be representative of the volume and nature of the discharge or matrix of materials sampled. The name of the sampler, sample type (grab or composite), time, date, location, bottle type, and any preservative used for each sample shall be recorded on the sample chain of custody form. The chain of custody form must also contain all custody information including date, time, and to whom the samples were relinquished. If composite samples are collected, the basis for sampling (time or flow weighted) shall be approved by the Central Coast Regional Water Quality Control Board (Central Coast Water Board). Unless otherwise specified below, sampling shall be performed as shown in Table 1.

Table 1. Sampling and Monitoring Schedule

Monitoring Period	Sample Collection Months
Annually	October
Semiannually	April and October
Quarterly	January, April, July, and October
Monthly	Each month of the year

Field test instruments (such as those to test pH, dissolved oxygen, and electrical conductivity) may be used provided that they are used by a State Water Resources Control Board (State Water Board) California Environmental Laboratory Accreditation Program certified laboratory, or:

1. The user is trained in proper use and maintenance of the instruments;

2. The instruments are field calibrated prior to monitoring events at the frequency recommended by the manufacturer;
3. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency; and
4. Field calibration reports are maintained and available for at least three years.

2. WATER SUPPLY MONITORING

Representative samples of the water supply must be collected and analyzed as shown in Table 2 from the production wells prior to any disinfection.

In lieu of the required water supply sampling, County of Santa Cruz may request approval to submit a Well Identification Number and the reporting year's consumer confidence report (annual water quality report or drinking water quality report), as required by the State Water Board Division of Drinking Water and/or county. County of Santa Cruz must report the results of any constituent monitored more frequently than is required by this monitoring and reporting program. County of Santa Cruz must also report detectable concentrations (above the reporting limit) for any other constituent that has a published maximum contaminant level (MCL).

Table 2. Water Supply Monitoring

Parameter	Units	Type of Sample	Sampling Frequency	Reporting Frequency
TDS	mg/L	Grab	Annually	Annually
Nitrate and Nitrite (as N)	mg/L	Grab	Annually	Annually

mg/L denotes milligrams per liter

3. MONITORING LOCATIONS

Monitoring location information, including nomenclature that shall be used when reporting data to the GeoTracker database (described below), is shown in Table 3.

Table 3. Monitoring Locations

Sample Title	GeoTracker Field Point Code	Sample Description
Influent Sample – 1	IS-1	Representative grab sample before equalization tank
Effluent Sample – 1	ES-1	Representative grab sample from pump stations prior to leachfield disposal




Figure 1. Process Flow Diagram with Sampling Locations

4. EXTENDED AERATION TREATMENT UNIT MONITORING

4.1 Flow Monitoring

County of Santa Cruz must monitor and report flow, as described in Table 4, with each monitoring report. Flow is monitored at sample location ES-1 after extended aeration, and influent flow is approximately equal to effluent flow.

Table 4. Flow Monitoring

Parameter	Units	Sample Type	Sampling Frequency	Reporting Frequency
Daily Flow	Gallons per day	Metered	Daily	Semiannual
Maximum Daily Flow	Gallons per day	Metered	Monthly	Semiannual
Mean Daily Flow	Gallons per day	Calculated	Monthly	Semiannual

4.2 Influent and Effluent Constituent Monitoring

Representative samples of County of Santa Cruz's influent (raw wastewater) into the wastewater system and effluent (treated wastewater) discharged to land must be collected and analyzed as follows. All samples must be grab.

Table 5. Influent and Effluent Monitoring

Parameter/ Constituent	Units	INFLUENT (IS-1) Sampling Frequency	EFFLUENT (ES-1) Sampling Frequency	Reporting Frequency
Biochemical Oxygen Demand, 5-Day	mg/L	Quarterly	Quarterly	Semiannual
Total Suspended Solids	mg/L	Quarterly	Quarterly	Semiannual
pH	pH units	Not Required	Quarterly	Semiannual
Total Nitrogen	mg/L	Quarterly	Quarterly	Semiannual

Parameter/ Constituent	Units	INFLUENT (IS-1) Sampling Frequency	EFFLUENT (ES-1) Sampling Frequency	Reporting Frequency
Nitrate (as N) + Nitrite (as N) or separate species ¹	mg/L	Quarterly	Quarterly	Semiannual
Total Kjeldahl Nitrogen (as N)	mg/L	Quarterly	Quarterly	Semiannual
Total Dissolved Solids	mg/L	Not Required	Quarterly	Semiannual
Chloride	mg/L	Not Required	Quarterly	Semiannual
Sodium	mg/L	Not Required	Quarterly	Semiannual

mg/L = milligram per liter MPN = most probably number

[1] Nitrate and nitrite sample may be combined

5. SEPTIC TANK SLUDGE MONITORING

Septic tanks must be inspected at least as frequently as described in Table 6. Inspections of sludge and scum depth are not required if the tanks are pumped at least annually.

Table 6. Septic Sludge Measurements¹

Parameter	Units	Measurement Type	Inspection/Reporting Frequency
Sludge depth and scum thickness in each compartment of the tank	Feet	Gauge	Annual
Distance between bottom of scum layer and bottom of outlet device	Inches	Gauge	Annual
Distance between top of sludge layer and bottom of outlet device	Inches	Gauge	Annual
Effluent filter condition (if equipped, clean as needed)	NA	NA	Annual

[1] Septic tanks must be pumped when any one of the following conditions exists:

1. The combined thickness of sludge and scum exceeds one-third of the tank depth of the first compartment.
2. The scum layer is within 3 inches of the outlet device.
3. The sludge layer is within 8 inches of the outlet device.

If a septic tank is pumped during the year, the pumping report must be submitted with the February semiannual report. County of Santa Cruz must maintain a record of all septic tank service activities for a minimum of five years. At a minimum, the record must include the date, nature of service, service company name and license number.

6. SUBSURFACE DISPOSAL AREA INSPECTIONS

County of Santa Cruz must walk the disposal areas to inspect all items in Table 7 at least weekly and after rain events. All pump controllers and automatic distribution valves

must be inspected for proper operation as recommended by the manufacturer. Shallow-rooted plants are generally desirable, deep-rooted plants such as trees must be removed as necessary. Evidence of animals burrowing must be immediately investigated, and burrowing animal populations controlled as necessary. Disposal areas must be inspected to ensure they are allowing wastewater to infiltrate as designed, there is no surfacing, and soils are not saturated.

Table 7. Subsurface Disposal Area Monitoring

Parameter	Inspection Frequency	Reporting Frequency
Pump controllers, automatic valves, etc.	Weekly	Semiannually
Nuisance Odor Condition	Weekly	Semiannually
Saturated Soil Condition	Weekly	Semiannually
Plant Growth	Weekly	Semiannually
Vectors or Animals Burrowing	Weekly	Semiannually
Disposal Area Condition	Weekly	Semiannually

A log of these inspections must be maintained onsite in a bound logbook and made available to the Central Coast Water Board upon inspection. Any problems must be promptly corrected and recorded. County of Santa Cruz must submit a summary of violations found during the inspections with each subsequent monitoring report, or a note that there were no violations.

7. SOLIDS DISPOSAL MONITORING

County of Santa Cruz must report the handling and disposal of all solids (e.g., screenings, grit, sludge, biosolids, grease, etc.) generated at the wastewater treatment system. Records must include the name/contact information for the hauling company, the type and amount of waste transported, the date removed from the wastewater system, the disposal facility name and address, and copies of analytical data required by the entity accepting the waste. These records must be submitted as part of the subsequent monitoring report.

8. REPORTING

The semiannual monitoring reports must be submitted in accordance with Table 8.

Table 8. Semiannual Monitoring Reports

Report	Monitoring Period	Report Due Date
First Semiannual Report	January 1 to June 30	August 1
Second Semiannual Report	July 1 to December 31	February 1

At a minimum, the semiannual reports must include:

- **Facility Information and Description** -- Briefly describe your facility, treatment process, and disposal process with references to figures.
- **Data Tables** -- Tabular summaries of all monitoring data (water supply, influent, effluent, and groundwater) compared to effluent limits, as appropriate. Submit the results of any pollutant or parameter monitored more frequently than is required by this monitoring program.
- **Compliance and Performance Discussion** --
 - Disclosure of any noncompliance (violations) with of the notice of applicability and/or General Permit requirements, including a description, it's cause, the exact date(s) and time(s), and the steps taken or planned to reduce, eliminate and prevent recurrence of the noncompliance.
 - An evaluation (graphs recommended) of the treatment facilities' performance, including percent removal of the main pollutants (BOD₅, TSS, Total Nitrogen, Total Coliforms) over time, nuisance conditions, system problems, etc.
 - A discussion of any data gaps and potential deficiencies in the monitoring system or reporting program.
- **Septic Tank Pumping** -- Annually, in the March 1 report, note if the septic tank was pumped or inspected and provide the results as described in Section 5.
- **Disposal Area Inspection** -- Report the results of the disposal area inspections, as described in Section 6.
- **Solids Disposal** -- If solids are disposed of offsite, comply with the reporting in Section 7.
- **Operator Information** -- List the name and contact information for the wastewater operators responsible for operation, maintenance, and/or system monitoring.
- **Flow Evaluation** -- A summary in tabular format of the maximum and average flows for each month and comparison to permitted flows.
- **Figures** -- A wastewater treatment process flow diagram with a label for the monitoring locations and a scaled facility map showing the treatment system, discharge points, and wells (supply and groundwater, if present).
- **Laboratory Sheets** -- Copies of laboratory analytical report(s) and chain of custody form(s).

9. ELECTRONIC SUBMITTAL

All monitoring reports must be provided electronically in a searchable PDF format, with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permiiting/docs/transmittal_sheet.pdf

County of Santa Cruz must submit all reports/documents and laboratory analytical data (influent, effluent, groundwater data) to the State Water Board's GeoTracker^{7,8} database consistent with applicable Electronic Submittal of Information (ESI) requirements under a wastewater system-specific global identification number **WDR100035838** at:

<https://geotracker.waterboards.ca.gov/esi/login>

Table 9 summarizes the GeoTracker electronic reporting requirements. For general questions, please contact the GeoTracker Help Desk: Geotracker@waterboards.ca.gov.

Table 9. GeoTracker Electronic Submittal Information (ESI) Data Requirements

Electronic Submittal	Description of Action	Action	Frequency
Reports and Documents	Complete copy of all documents including monitoring reports (in searchable PDF format) and any other associated documents related to the Wastewater System.	Upload directly to GeoTracker all monitoring reports (in searchable PDF format) and any other associated documents.	On or before the due dates required by this General Permit and for other documents when required by the Central Coast Water Board.
Laboratory Data	All analytical data (including geochemical data) in electronic deliverable format (EDF). This includes all water, soil, and vapor samples collected when monitoring a discharge.	Upload, or direct your State Certified Laboratory staff to upload, all laboratory data directly to GeoTracker.	On or before the due date of the required monitoring report
Depth to Groundwater	Monitoring wells must have the depth-to-water information reported. Report data only for wells defined as permanent sampling points.	Upload depth-to-water information to the GeoTracker GEO_WELL file.	On or before the due date of the required monitoring report

⁷ Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguide2.pdf

⁸ Additional information available at:

<https://geotracker.waterboards.ca.gov/>

Electronic Submittal	Description of Action	Action	Frequency
Boring Logs and Well Screen Intervals	Boring logs must be prepared by a registered professional and submitted in PDF format separately (not only as attachments to reports)	Upload boring logs (in searchable PDF format) to GeoTracker whenever a new boring is drilled.	Every time a new boring is drilled.
Location data (Geo XY)	Name, classify, and identify the location (latitude and longitude) of all sampling points. Monitoring wells must be surveyed, influent and effluent sample locations must be identified on the GeoTracker mapping tool under "non-surveyed data."	Upload the location data (surveyed and non-surveyed) to the GeoTracker Geo_XY file.	These data points are required prior to laboratory data uploads. Must be added every time a permanent monitoring point is established.
Elevation Data (Geo Z)	Mark the elevation at the top of groundwater well casings for all permanent groundwater wells. These points are required prior to depth-to-water data uploads.	Upload the survey data to the GeoTracker GEO_Z File.	One-time, for all groundwater monitoring wells.
Geo Map	Site layout, map of facilities, wastewater treatment system, and disposal area(s).	Upload the Site layout PDF to the GeoTracker site plan file.	One time, or when the facility is modified.

10. TECHNICAL REPORTS

County of Santa Cruz must submit to GeoTracker the three reports described in General Permit *Section E. 1. Technical Report Preparation Requirements* by the dates included in Table 10. If this information is already contained in an operation and maintenance manual or similar document, that may be submitted in compliance with this requirement.

Table 10. Technical Report Submittal Due Dates

Report	Report Due Date
Spill Prevention & Emergency Response Plan	90 days from date of General Permit enrollment ¹

Report	Report Due Date
Sampling and Analysis Plan	90 days from date of General Permit enrollment ¹
Sludge Management Plan	90 days from date of General Permit enrollment ¹

1. The date of General Permit enrollment is September 30, 2022

11. LEGAL REQUIREMENTS

The Central Coast Water Board's requirements that County of Santa Cruz submit the technical and monitoring reports described in this monitoring and reporting program are made pursuant to [section 13267 of the California Water Code](#). Failure to submit reports in accordance with schedules established by this General Permit and notice of applicability with attachments or failure to submit a report of sufficient technical quality to be acceptable to the Central Coast Water Board may subject County of Santa Cruz to enforcement action pursuant to [section 13268 of the Water Code](#).

The Central Coast Water Board needs the required information to ensure compliance with the notice of applicability and the General Permit. County of Santa Cruz is required to submit this information because it is subject to the General Permit and is responsible for the discharge.

The burden, including costs, of the reports bears a reasonable relationship to their need and the benefits to be obtained.

County of Santa Cruz must implement the above monitoring program as of the date of this monitoring and reporting program. The Central Coast Water Board may rescind or modify the monitoring and reporting program at any time. County of Santa Cruz must not implement any changes to this monitoring and reporting program unless and until a revised monitoring and reporting program is issued by the Central Coast Water Board.

Ordered by:

for Matthew T. Keeling
Executive Officer