



Central Coast Regional Water Quality Control Board

September 16, 2022

Sent Via Electronic Mail

Christopher Cook
Director of Operations
California American Water
511 Forest Lodge Road, Suite 100
Pacific Grove, CA 93950
e-mail: christopher.cook@amwater.com

Dear Christopher Cook:

**SPRECKELS WASTEWATER TREATMENT PLANT, 121 SPRECKELS BLVD.,
SPRECKELS, CA 93908, MONTEREY COUNTY:**

- **NOTICE OF APPLICABILITY FOR ENROLLMENT IN ORDER NO. R3-2020-0020, GENERAL WASTE DISCHARGE REQUIREMENTS FOR DISCHARGES FROM DOMESTIC WASTEWATER SYSTEMS WITH FLOWS GREATER THAN 100,000 GALLONS PER DAY;**
- **TRANSMITTAL OF MONITORING AND REPORTING PROGRAM NO. R3-2022-0047; AND**
- **TERMINATION OF INDIVIDUAL PERMIT, WASTE DISCHARGE REQUIREMENTS ORDER NO. 99-86 FOR COMMUNITY OF SPRECKELS AND WATERTEK, INCORPORATED WASTEWATER TREATMENT AND DISPOSAL FACILITIES.**

The Central Coast Regional Water Quality Control Board (Central Coast Water Board) reviewed the February 9, 2022 Notice of Intent and available documents associated with California American Water's (CA American Water) domestic wastewater treatment facility (Wastewater System) located at 121 Spreckels Boulevard in Spreckels, California. The Wastewater System, owned by CA American Water is currently regulated pursuant to *Waste Discharge Requirements Order No. 99-86 for Community of Spreckels and Watertek, Incorporated Wastewater Treatment and Disposal Facilities* (Permit No. 99-86).

On September 25, 2020, the Central Coast Water Board adopted *General Waste Discharge Requirements Order No. R3-2020-0020 for Discharges from Domestic Wastewater Systems with Flows Greater than 100,000 Gallons per Day* (General Permit).

JANE GRAY, CHAIR | MATTHEW T. KEELING, EXECUTIVE OFFICER

This letter serves as a notice of applicability for enrollment in the General Permit. This letter includes: wastewater system operation summary, specific requirements, and limitations (Attachment 1); figures (Attachment 2); and CA American Water's monitoring and reporting program requirements (Attachment 3).

This letter also serves as a notice of termination of CAW and historically Watertek's coverage in existing individual permit, Permit No. 99-86.

CA American Water must comply with the following:

1. **General Permit** – CA American Water must comply with all conditions and requirements of the General Permit. As described in the General Permit, ongoing operation, maintenance, monitoring, and reporting are required. A copy of the General Permit can be found electronically at the following link:

https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/r32020_0020.pdf

2. **Monitoring and Reporting Program** – CA American Water must comply with the requirements of the monitoring and reporting program enclosed with this letter (Monitoring and Reporting Program No. R3-2022-0047, Attachment 3). CA American Water is required to submit quarterly monitoring reports and annual reports to the Central Coast Water Board and comply with annual volumetric reporting requirements¹ established by the State Water Resources Control Board (State Water Board). The first quarterly monitoring report is due **February 1, 2023**, the first annual report is due **March 1, 2023**, and the next annual volumetric data submission must be uploaded to the State Water Board GeoTracker database by **April 30, 2023**.

Quarterly monitoring reports and annual reports must be provided electronically in searchable PDF with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permitting/docs/transmittal_sheet.pdf

All annual reports must be formatted and completed as specified in the annual report template found at the following link:

https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/wdr_annual_report_format.pdf

As described in the attached monitoring and reporting program, CA American Water must submit all reports/documents and laboratory data to the publicly

¹ See: [Volumetric Annual Reporting | California State Water Resources Control Board](#)

accessible State Water Board's GeoTracker^{2,3} database with applicable Electronic Submittal of Information (ESI) requirements under the Wastewater System – specific global identification number **WDR100029567** at:

https://www.waterboards.ca.gov/ust/electronic_submittal/index.html

3. **Fees** – CA American Water paid an annual fee of \$7,486 on January 20, 2022 for coverage in existing individual permit, Permit No. 99-86. This payment covers CA American Water's enrollment in the General Permit for the 2021-2022 fiscal year.

CA American Water must pay an annual fee to maintain coverage in the General Permit. Annual fees are determined by the State Water Board's fee program and cover the state fiscal year of July 1 through June 30. CA American Water's Wastewater System is currently assigned a threat and complexity rating of 2B. The current annual fee for 2B facilities is \$23,783 and this is anticipated to increase for the 2022-2023 fiscal year.

The 2021-2022 state fee schedule is available electronically at the following link and the 2022-2023 fee schedule will be posted here once it is approved:

https://www.waterboards.ca.gov/resources/fees/water_quality/#wdr

4. **Notification** – The Central Coast Water Board will be notified of CA American Water's enrollment at a regularly scheduled public meeting on December 8-9, 2022. Details about that meeting are available on our website at:

https://www.waterboards.ca.gov/centralcoast/board_info/agendas/

5. **Future Discharge Modifications** – Pursuant to California Water Code section 13260, CA American Water must inform the Central Coast Water Board at least 120 days prior to modifying your discharge. If there are any significant changes in either treatment or disposal methodologies, or the volume or character of the treated wastewater, CA American Water must notify the Central Coast Water Board immediately of such changes.

Attachment 1 contains the Central Coast Water Board's understanding of the Wastewater System located at 121 Spreckels Blvd., Spreckels, California 93962. Please review Attachment 1 to determine if the description is representative of

² Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguid2.pdf

³ Additional information available at: https://www.waterboards.ca.gov/ust/electronic_submittal/index.html

your current system. Pursuant to California Water Code section 13267, CA American Water must notify the Central Coast Water Board if this information is out of date or incorrect. You are required to provide staff with your updated information within **30 days** of issuance of this letter.

- 6. Responsible Party** – CA American Water is responsible for the management and disposal of the domestic wastewater in compliance with the conditions of the General Permit. Any noncompliance with this General Permit constitutes a violation of the California Water Code, and subjects CA American Water to enforcement action, and termination of enrollment under this General Permit.
- 7. Change in Ownership** – In the event of any change in control or ownership of the property, CA American Water must notify the succeeding owner or operator of the existence of this General Permit by letter, a copy of which shall be immediately forwarded to the Central Coast Water Board so that the new owner or operator can be enrolled in the General Permit and CA American Water's enrollment in the General Permit can be terminated.
- 8. Certified Operator** – CA American Water is required to comply with the operator certification requirements⁴ administered by the State Water Board's Office of Operator Certification, which currently requires a Grade I certified wastewater treatment plant operator onsite to maintain and operate the Wastewater System.
- 9. Termination of Permit** – The existing individual permit, Permit No. 99-86 is terminated, except for enforcement purposes⁵. Watertek is named as the Discharger on the 1999 individual order. Watertek sold the wastewater system to CA American Water in about 2003 and took responsibility for the system. CA American Water is responsible for compliance with Permit No. 99-86 prior to the date of this letter, including, but not limited to, any outstanding reports required by Permit No. 99-86.
- 10. Compliance Schedule** – CA American Water anticipates it will need more than two years to comply with some of the groundwater and effluent limits of the new General Permit. CA American Water has met with Central Coast Water Board staff and are evaluating the feasibility of consolidating with Monterey One Water's Regional Treatment Plant or upgrading the Spreckels wastewater system. As required in the attached monitoring and reporting program, CA American Water must request a time schedule order 12 months from the date of this notice of applicability pursuant to Water Code section 13300, which must include more details, milestones, and a schedule for upgrades or consolidation.

⁴ Title 23 Division 3. Chapter 26 Wastewater Treatment Plant Classification, Operator Certification and Contract Operator Registration.

https://www.waterboards.ca.gov/water_issues/programs/operator_certification/docs/ocr_clean.pdf

⁵ The General Permit states "... where a Wastewater System discharge is currently regulated by an individual permit, that permit is terminated upon the enrollment of the Wastewater System into this General Permit."

If you have any questions, please contact **Kristina Olmos** at (805) 549-3121 or by email at Kristina.Olmos@waterboards.ca.gov or Jennifer Epp at (805) 594-6181 or by email at Jennifer.Epp@waterboards.ca.gov.

Sincerely,

Jennifer Epp
Digitally signed by Jennifer Epp
Date: 2022.09.16 15:58:02
-07'00'
Water Boards

for Matthew T. Keeling
Executive Officer

Attachments:

Attachment 1: Wastewater System Operation Summary, Specific Requirements, and Limitations

Attachment 2: Figures

Attachment 3: Monitoring and Reporting Program Order No. R3-2022-0047

cc:

Robert Moss, CA American Water, robert.moss@amwater.com

Jack Wang, CA American Water, jack.wang@amwater.com

Jennifer Epp, Central Coast Water Board, Jennifer.Epp@Waterboards.ca.gov

Jesse Woodward, Central Coast Water Board, Jesse.Woodward@Waterboards.ca.gov

Kristina Olmos, Central Coast Water Board, Kristina.Olmos@Waterboards.ca.gov

WDR Program, GeoTracker RB3-WDR@Waterboards.ca.gov

ECM/CIWQS = CW-258186

GeoTracker No. = GT- WDR100029567

Rev 9/24/2021

ECM Subject Name = Spreckels Wastewater Treatment Plant NOA for R3-2020-2020

r:\rb3\shared\wdr\wdr facilities\monterey co\spreckels wwtp\big order enrollment\final permit\spreckels_r3-2020-0020_noa_final.docx

**ATTACHMENT 1
WASTEWATER SYSTEM OPERATION SUMMARY, SPECIFIC REQUIREMENTS,
AND LIMITATIONS**

1. OWNERSHIP AND WASTEWATER SYSTEM INFORMATION

Ownership and wastewater system information submitted by CA American Water to the Central Coast Water Board is shown in Table 1.

Table 1. Ownership and Wastewater System Information

Name	Spreckels Wastewater Treatment Plant
Physical Address	121 Spreckels Blvd., Spreckels, CA 93962
Latitude	36°36'55.0"
Longitude	-121°39'12.1"
Mailing Address	511 Forest Lodge Road, Suite 100 Pacific Grove, CA 93950
Owner	CA American Water
Operator	CA American Water phone: 831-233-1938 e-mail: robert.moss@amwater.com
Legally Responsible Official	Chris Cook phone: 831-646-3241 e-mail: christopher.cook@amwater.com
Raw Wastewater Characteristics	Sewer Connections: 282 Population Served: 2600 Domestic (%): 99% Industrial (%): 1%
Permitted Design Flow, Average Monthly (gallons per day, gpd)	110,000
Baseline Flow (average annual flow) in gpd from 2021	61,200
Threat to Water Quality	2
Complexity	B
For Internal Use	
Fee Code	58
Place Type	Wastewater Treatment Facility
Facility Type	Municipal/Domestic
Facility Waste Type	Domestic Wastewater
Regulatory measure Type	Enrollee - WDR
Reclamation Included	No

2. WASTEWATER SYSTEM OPERATION SUMMARY

Spreckels Wastewater Treatment Plant (Wastewater System) is a Class I wastewater treatment facility. CA American Water must staff a Grade I chief plant operator for proper operation of the Wastewater System. The current chief plant operator is Robert Moss Grade 3, license number 41116.

In the notice of intent, CA American Water proposes that the Wastewater System is designed to treat and dispose of 180,000 gallons per day to a secondary treatment level.⁶ The Wastewater System consists of the treatment technologies shown in Table 2. The Central Coast Water Board is permitting the operation and disposal of the system as described below. CA American Water must not change operation or disposal technology without Central Coast Water Board notification and review.

Table 2. Treatment Technology and Original Design Capacity

Headworks/Preliminary Treatment	The headworks consist of two lift stations (Lift Station 1 and Lift Station 3). The stations do not have any influent screening. Manual maintenance is performed to remove large debris from the suction side of influent pumps.
Primary and Secondary Treatment	The system consists of a 12-acre facultative pond equipped with floating aerators. The pond depth is estimated to be 10 feet and has a capacity of 30 million gallons.
Wastewater Disposal Method	The facultative pond is not lined, and also serves as a disposal pond.
Biosolids/Sludge Production and Handling	Solids accumulated in the treatment pond are removed by dredging and disposed of at a nearby municipal landfill facility as needed. No sludge removal has occurred since CA American Water has owned the facility.
	The ultimate destination of biosolids produced is Monterey Regional Waste Management District - Landfill Facility located at 14201 Del Monte Boulevard in Marina California.

A summary of historic and recent average effluent concentrations is included in Table 3, which were reported in Spreckels Wastewater Treatment Plant's quarterly monitoring reports. The Central Coast Water Board used reported effluent water quality data to establish the effluent and groundwater limitations in section 3.

⁶ The system was originally permitted to discharge to land in 1964, and the original design documents are not available. However, the previous individual wastewater permits and file include reference to the original design, along with more recent pond evaluations.

Table 3. Effluent Water Quality for Select Constituents

Constituents	Units	Historical Average ^[1]	Annual Average for 2021
Biochemical Oxygen Demand, 5-Day	mg/L ^[2]	NR ^[3]	73
Total Suspended Solids	mg/L	NR ^[3]	90
Total Dissolved Solids	mg/L	1311	1368
Chloride	mg/L	287	337
Sodium	mg/L	212	238
Sulfate	mg/L	267	245

[1] Based on water quality data reported by CA American Water in their 2004 to 2020 monitoring reports. Boron and total nitrogen were not required to be reported, so no data is available.

[2] mg/L denotes milligrams per liter.

[3] not required per historical monitoring and reporting program

3. WASTEWATER SYSTEM SPECIFIC REQUIREMENTS AND LIMITATIONS

CA American Water must operate the Wastewater System in accordance with the General Permit and this Notice of Applicability. CA American Water must comply with the wastewater specific limitations specified in Table 4 through Table 7.

A. Flow Limitations:

Table 4. Flow Limitations

Flow	Units	Limit	Point of Compliance
Maximum Daily Dry Weather	Gallons per day	180,000	Influent
Average Monthly	Gallons per day	110,000	Influent

The facility encounters significant increased flow during wet weather events likely resulting from inflow and infiltration. The wet weather may bring the incoming influent flow over the permitted maximum daily dry flow of 180,000 gallons per day. The attached Monitoring and Reporting Program No. R3-2022-0047 requires an annual report submittal to evaluate and address the inflow and infiltration resulting in significant increased flow so the system can stay within the permitted limits.

B. Effluent Limitations:

Based on reported water quality data, effluent water quality for 5-day Biochemical Oxygen Demand (BOD₅) and Total Suspended Solids (TSS) (see Table 3) exceed the General Permit effluent limits for treatment ponds. Therefore, pursuant to the General Permit, California America Water must comply with Permit No. 99-86 limits for two years as shown in Table 5. Permit No. 99-86 did not contain effluent limits for BOD₅, therefore there is no effluent limit for BOD₅ for the first 24 months from the date of this notice of

applicability. **After 24 months from the date of this notice of applicability, treatment pond effluent limitations shown in Table 6 apply.**

Table 5. Interim Effluent Limitations: Treatment Ponds

Constituent	Units	Sample Maximum
Total Suspended Solids	mg/L ^[1]	150
Settleable Solids	mL/L ^[2]	1.0
pH	Not Applicable	6.5 to 8.3

[1] mg/L denotes milligrams per liter

[2] mL/L denotes milliliters per liter

Table 6. Effluent Limitations: Treatment Pond (after 24 months)

Constituent	Units	30-Day Average	7-Day Average	Sample Maximum
Biochemical Oxygen Demand, 5-Day	mg/L	45	65	Not Applicable
Total Suspended Solids	mg/L	45	65	Not Applicable
Settleable Solids	mL/L	0.3	Not Applicable	0.5
pH	Not Applicable	Between 6.5 and 8.4	Not Applicable	Not Applicable

Based on existing water quality, **Table 7 effluent limits for TDS, sodium and sulfate are immediately attainable and therefore apply as of the date of this notice of applicability.** Chloride, boron, and total nitrogen effluent limits apply in 24-months from the date of this notice of applicability, or California America Water could choose to install groundwater monitoring wells and verify compliance in groundwater per Table 8.

**Table 7. Effluent Limitations
Based on - Salinas Valley 180-foot Aquifer**

Constituents	Units	25-Month Rolling Median	Compliance Date
Total Dissolved Solids	mg/L	1500	Immediately
Chloride	mg/L	250 ^[1]	24 months (September 17, 2024)
Sodium	mg/L	250	Immediately
Sulfate	mg/L	600	Immediately
Boron	mg/L	0.5 ^[1]	24 months (September 17, 2024)

Constituents	Units	25-Month Rolling Median	Compliance Date
Total Nitrogen	mg/L	10 ^[1]	24 months (September 17, 2024)

[1] For these constituents, California America Water could instead choose to install groundwater monitoring wells and verify compliance in groundwater as shown in Table 8.

C. Groundwater Limitations:

CA American Water must comply with Table 8 groundwater limitations. Currently, California America Water is not required to monitor groundwater, and has no groundwater wells present. The General Permit allows a Discharger two years to comply with effluent or groundwater limits. Thus, within two years, CA American Water must either install wells and monitor groundwater to demonstrate compliance with chloride and total nitrogen limits in Table 8, improve the system to comply with Table 7 limits at the effluent, or it could propose to consolidate with a neighboring wastewater system.

**Table 8. Groundwater Limitations
for Salinas Valley 180-foot Aquifer**

Constituents	Units	25-Month Rolling Median ^[1]
Total Dissolved Solids	mg/L	1500
Chloride	mg/L	250
Sodium	mg/L	250
Sulfate	mg/L	600
Boron	mg/L	0.5
Total Nitrogen	mg/L	10

[1] Rolling Median is the median from all data collected over the most recent 25 months

Central Coast Water Board staff anticipates CA American Water will need additional time, more than 24-months, to achieve compliance with the final effluent limitations provided in Table 6 and the chloride and total nitrogen limit in either groundwater or effluent. Within twelve months from the date of this notice of applicability, CA American Water must notify the Central Coast Water Board and refer to the General Permit to request a compliance time schedule order pursuant to Water Code section 13300 for consideration by the Central Coast Water Board.

ATTACHMENT 2
FIGURES



Figure 1. Site Map (Source: Annual Report)



Figure 2. Treatment and Disposal Pond (disposal only permitted in pond)
(Source: Annual Report)



Figure 3. Spreckels Collection System (Source: Annual Report)




Figure 4. Process Flow Diagram




Figure 5. Parcel Map of Treatment and Disposal Pond

ATTACHMENT 3
MONITORING AND REPORTING PROGRAM

CENTRAL COAST REGIONAL WATER QUALITY CONTROL BOARD

MONITORING AND REPORTING PROGRAM NO. R3-2022-0047 (SEPTEMBER 16, 2022 MODIFICATION OF MRP NO. R3-2020-0020)

FOR

SPRECKELS WASTEWATER SYSTEM SPRECKELS, MONTEREY COUNTY

This Monitoring and Reporting Program (MRP) applies to the monitoring and reporting requirements for Spreckels Wastewater Treatment System (Wastewater System) enrolled in *General Waste Discharge Requirements Order No. R3-2020-0020 for Discharges from Domestic Wastewater Systems with Flows Greater than 100,000 Gallons per Day* (General Permit).

California American Water (CA American Water) owns and operates the Wastewater System that is subject to the General Permit and notice of applicability. CA American Water must not implement any changes to this MRP unless and until a revised MRP is issued by the Central Coast Regional Water Quality Control Board (Central Coast Water Board).

The State Water Resources Control Board (State Water Board) and Regional Water Quality Control Boards are transitioning to the use of the publicly accessible State Water Board's GeoTracker database for the tracking of environmental and regulatory data for sites that operate under waste discharge requirements. The MRP directs CA American Water to submit reports (both technical and monitoring reports) and analytical data electronically to the State Water Board's GeoTracker database (see MRP section VIII.C).

I. SAMPLING AND ANALYSIS

CA American Water must collect representative samples in accordance with the most recently approved sampling and analysis plan contained in the Operations and Maintenance Manual and validate analytical results prior to submittal to the Central Coast Water Board. All samples (e.g., wastewater, groundwater, soil, sludge, etc.) must be representative of the volume and nature of the discharge or matrix of materials sampled.

All samples must be collected by a qualified person, trained in proper procedures for collecting the samples. The name of the sampler, sample type (grab or composite), time, date, location, bottle/container type, and any preservative used for each sample must be recorded on the sample chain of custody form. The chain of custody form must also contain all custody information including date, time, and to whom samples were relinquished. If composite samples are collected, the basis for sampling (time or flow weighted) must be included in the sampling and analysis plan contained in the

Operations and Maintenance Manual for Central Coast Water Board review and approval.

- A. Sampling Schedule** – Unless otherwise specified below, sampling must be performed in accordance with Table 1.

Table 1. Sampling Schedule

Monitoring Period	Sample Collection Time
Quarterly	January, April, July, and October
Semiannual	April and October
Annual	October

Field test instruments (such as those used to test pH, dissolved oxygen, and electrical conductivity, etc.) may be used if they are used by a State Water Board Environmental Laboratory Accreditation Program accredited laboratory, or:

1. The user is trained in proper use and maintenance of the instruments;
2. The instruments are field calibrated prior to monitoring events at the frequency recommended by the manufacturer;
3. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency; and
4. Field calibration reports are maintained and available for at least three years.

- B. Monitoring Location Descriptions** – All samples including influent samples (IS), effluent samples (ES), groundwater monitoring well (MW), etc. must be collected at the locations described in Table 2. These locations must be consistent with the Central Coast Water Board-approved sampling and analysis plan. **CA American Water must upload the GeoTracker field point information for each sampling location in the GeoTracker database once, prior to uploading laboratory data** (see Table 9).

Table 2. Sample Identification Details

GeoTracker Field Point Class	GeoTracker Field Point Name (Sample ID)	GeoTracker Field Point Description
Influent Sample	IS-1	Grab sample of raw wastewater collected at Lift Station #1
Influent Sample	IS-2	Grab sample of raw wastewater collected at Lift Station #3
Effluent Sample	ES-1	Treated wastewater sample collected from the treatment pond

II. WATER SUPPLY MONITORING

Representative samples of Spreckels' raw water supply (sampled before use or treatment) must be collected and analyzed, at a minimum, for constituents specified in Table 3.

In lieu of the required water supply sampling, CA American Water may request Central Coast Water Board approval to submit a Well Identification Number and the reporting year's consumer confidence report (annual water quality report or drinking water quality report), as required by the State Water Board Division of Drinking Water and/or county, provided, at a minimum, all of the required constituents are sampled at the frequency specified in Table 3. CA American Water must report the results of any constituent monitored more frequently than is required by the monitoring program shown in Table 3. CA American Water must also report detectable concentrations (above the reporting limit) for any other constituent that has a published maximum contaminant level (MCL).

CA American Water must evaluate and provide a tabular summary of the water supply data with the annual monitoring report.

Table 3. Water Supply Monitoring

Constituent	Units ^[1]	Sample Type	Sampling Frequency
Nitrate (as N)	mg/L	Grab	Annually
Total Dissolved Solids	mg/L	Grab	Annually
Chloride	mg/L	Grab	Annually
Sodium	mg/L	Grab	Annually
Sulfate	mg/L	Grab	Annually
Boron	mg/L	Grab	Annually
Carbonate	mg/L	Grab	Annually
Bicarbonate	mg/L	Grab	Annually
Calcium	mg/L	Grab	Annually
Potassium	mg/L	Grab	Annually
Magnesium	mg/L	Grab	Annually

[1] mg/L denotes milligrams per liter

III. INFLUENT AND EFFLUENT MONITORING

A. Influent and Effluent Flow Monitoring – CA American Water must monitor and report flow in gallons per day, as described in Table 4, with each monitoring report.

See MRP section VIII.A.3 for supplemental volumetric annual reporting requirements established by the State Water Board.

Table 4. Influent and Effluent Flow Monitoring

	INFLUENT	INFLUENT	EFFLUENT	EFFLUENT
Parameter	Sample Type	Reporting Frequency	Sample Type	Reporting Frequency
Daily Flow	Metered	Daily	Metered	Daily
Maximum Daily Flow ^[1]	Metered	Monthly	Metered	Monthly
Average Daily Flow ^[1]	Calculated	Monthly	Calculated	Monthly

[1] The General Permit notice of applicability specifies the Wastewater System's maximum permitted flow. In the monitoring reports, CA American Water must evaluate and provide a comparison of monitored flow to the permitted flow.

B. Wastewater System Monitoring – Representative samples of Spreckels' influent (raw wastewater) into the Wastewater System and effluent (treated wastewater) discharged to land must be collected and analyzed in accordance with the monitoring requirements (including sample type and frequency) summarized in the tables below. See Figure 1 for the location of samples and GeoTracker field points.




Figure 1. Process Flow Diagram and Sample Locations

- 1. Pond Monitoring** – The treatment and disposal pond must be monitored as specified in Table 5.

Table 5. Treatment and Disposal Pond Monitoring

Parameter/ Constituent	Units	Sample Type	Sampling/Monitoring Frequency
Freeboard	0.1 feet	Measured	Weekly
Dissolved Oxygen	mg/L	Grab	Monthly
Sludge Depth	0.1 feet	Measured	Annually

- 2. Influent and Effluent Monitoring** – At a minimum, influent and effluent must be monitored as specified in Table 6. Influent pump station 1 (IS-1) must be a 24-hour composite sample, while pump station 3 (IS-2) and effluent pond sample (ES-1) must be grab.

Table 6. Influent and Effluent Monitoring for Pond Treatment Systems

Parameter/Constituent	Units	INFLUENT (IS-1 and IS-2) Sampling Frequency	EFFLUENT (ES- 1) Sampling Frequency
pH	units	Not required	Weekly
Biochemical Oxygen Demand, 5-Day	mg/L	Monthly	Monthly
Total Suspended Solids	mg/L	Monthly	Monthly
Settleable Solids	mg/L	Not Required	Weekly
Total Nitrogen ^[1]	mg/L	Quarterly	Quarterly
Nitrate (as N) + Nitrite (as N) or separate species	mg/L	Quarterly	Quarterly
Total Kjeldahl Nitrogen (as N)	mg/L	Quarterly	Quarterly
Ammonia (as N)	mg/L	Quarterly	Quarterly
Total Dissolved Solids	mg/L	Quarterly	Quarterly
Chloride	mg/L	Quarterly	Quarterly
Sodium	mg/L	Quarterly	Quarterly
Sulfate	mg/L	Quarterly	Quarterly
Boron	mg/L	Not Required	Quarterly
Carbonate	mg/L	Not Required	Annually

Parameter/Constituent	Units	INFLUENT (IS-1 and IS-2) Sampling Frequency	EFFLUENT (ES-1) Sampling Frequency
Bicarbonate	mg/L	Not Required	Annually
Calcium	mg/L	Not Required	Annually
Potassium	mg/L	Not Required	Annually
Magnesium	mg/L	Not Required	Annually

[1] Total nitrogen is the sum of total inorganic nitrogen (nitrate + nitrite + ammonium + ammonia) and organic nitrogen.

IV. WASTEWATER DISPOSAL MONITORING

CA American Water must monitor the disposal areas (the treatment and disposal pond). Inspections (observations) must be conducted as described in Table 7. Notations must be made in a bound logbook and problems must be promptly corrected and recorded. A log of these inspections must be maintained onsite and made available to Central Coast Water Board upon inspection. Observations do not need to be reported in the monitoring reports unless a violation of permit conditions is observed. If violations are observed, planned, and implemented mitigation measures to address the violations must be reported.

CA American Water must evaluate and summarize wastewater disposal application rates and loading rates (pounds/acre/day), violations found during the inspections, etc. with each monitoring report.

Table 7. Wastewater Disposal Monitoring

Constituent	Units	Sample Type	Monitoring Frequency
Local Precipitation ^[1]	Inches/day	Weather Station	Each precipitation event
Evaporation ^[2]	Inches	Weather Station	Daily
Acreage Applied ^[3]	Acres	Measured	Daily
Average Monthly Biochemical Oxygen Demand, 5-Day (BOD) Applied ^[3]	lbs/acre/day	Calculated	Monthly
Average Quarterly Total Nitrogen Applied ^[3]	lbs/acre/day	Calculated	Quarterly
Containment Berm Condition	Not applicable	Observation	Weekly
Nuisance (Odors/Vectors)	Not applicable	Observation	Weekly

[1] CA American Water must have a rain gauge or use a NOAA or USGS rain station, such as <http://scacis.rcc-acis.org/>.

- [2] Weather station may be site-specific station, onsite evaporation pan, or nearby governmental weather reporting station.
- [3] Acreage applied is the footprint of the disposal pond.
- [4] Loading rates must be calculated from wastewater flow volumes, applied acreage, and concentrations reported in effluent analytical testing as follows:

Total Nitrogen /BOD Applied (pounds/acre/day) =

$$\frac{X \text{ [mg/L]} \times Q \text{ [million gallons per day]} \times 8.34 \text{ [(conversion from mg/L to pounds/million gallons per day)]}}{\text{Acreage Applied [acres]}}$$

Where X = Total nitrogen, or BOD concentration

Where Q = Application Rate (influent flow rate to treatment pond)

V. SLUDGE/BIOSOLIDS DISPOSAL MONITORING

CA American Water must report the handling and disposal of all sludge/biosolids generated at the Wastewater System. Records must include the date removed from the Wastewater System, name/contact information for the hauling company, the type and volume of waste transported, the disposal facility name and address, and copies of analytical data required by the entity accepting the waste. These records must be submitted as part of the annual monitoring report.

CA American Water must also monitor sludge/biosolids consistent with a Central Coast Water Board approved sludge management plan and in accordance with the requirements specified by the receiving party, including a regulated landfill and/or regulated composting facility.

If sludge/biosolids are not removed during the year, CA American Water must explain the absence of this monitoring in the annual report.

VI. GROUNDWATER MONITORING

Groundwater monitoring is currently not required. CA American Water does not have monitoring wells to verify compliance with groundwater limitations. CA American Water must submit a groundwater monitoring well workplan (as described section IX.C.) if it chooses the point of compliance as groundwater for nitrate and chloride.

VII. Inflow and Infiltration (I&I) Reduction

CA American Water must evaluate and report ongoing efforts to reduce I&I annually. Information must include, at minimum, the following:

- a. Continued monitoring and reporting on precipitation events and their correlation to increased flows received at the wastewater treatment plant.
- b. Ongoing investigations and identification of sources contributing to I&I.
- c. Manhole repair/replacement activities conducted during the previous year.
- d. Sewer pipe repair/replacement work conducted during the previous year.
- e. A working plan for the upcoming years activities to reduce I&I.
- f. Maps of defects addressed in the previous year and those that the CA American Water will be addressing the following year.

VIII. REPORTING REQUIREMENTS

A. QUARTERLY AND ANNUAL MONITORING REPORTS

Quarterly and annual monitoring reports are due as described in Table 8.

Table 8. Quarterly and Annual Monitoring Reporting

Report	Monitoring Period	Report Due Date
First Quarter Monitoring Report	January 1 to March 31	May 1
Second Quarter Monitoring Report	April 1 to June 30	August 1
Third Quarter Monitoring Report	July 1 to September 30	November 1
Fourth Quarter Monitoring Report	October 1 to December 31	February 1
Annual Report	January 1 to December 31	March 1
State Water Board Volumetric Annual Reporting	January 1 to December 31	April 30

1. Quarterly Monitoring Reporting – At a minimum, the quarterly reports must include:

- i. Results of all required monitoring in tabular format.
- ii. The results of any pollutant or parameter monitored more frequently than is required by this monitoring program. Values obtained through additional monitoring must be used in calculations as appropriate.
- iii. A comparison of monitoring data to the discharge specifications, applicable effluent limitations, disclosure of any violations of the notice of applicability and/or General Permit, and an explanation of any violation of those requirements. **CA American Water must calculate 7-day averages, 30-day averages and 25-month rolling medians for select analytes when comparing monitoring data to applicable effluent limitations specified in the General Permit.** Data must be presented in tabular format.
- iv. Copies of laboratory analytical report(s) and chain of custody form(s).

2. Annual Reporting – CA American Water must submit annual reports in compliance with Standard Provisions 2013¹, (and any updates to the Standard Provisions) Section C, General Reporting Requirements, Item 16 using the most recent annual report template provided by Central Coast Water Board. The current annual report template can be found at the following link. In addition, CA American Water must include an I&I report as described in Section VII above.

¹ See Attachment E, Standard Provisions, 2013:
https://www.waterboards.ca.gov/centralcoast/board_decisions/docs/wdr_standard_provisions_2013.pdf

https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/wdr_annual_report_format.pdf

- 3. State Water Board Volumetric Annual Reporting** – CA American Water must electronically certify and submit a summary of the monthly influent and effluent flow volume by April 30th of each calendar year via the State Water Board's Internet GeoTracker database².

The following information is required:

- a. Monthly volume of wastewater collected and treated by the wastewater treatment plant (i.e. total monthly influent volume).
- b. Monthly volume of wastewater treated, specifying level of treatment, including treated wastewater discharged.
- c. If applicable, monthly volume of recycled water distributed, and annual volume of treated wastewater distributed for beneficial use in compliance with California Code of Regulations, title 22 use categories.

Additional information about volumetric annual reporting of wastewater and recycled water and the Recycled Water Policy is available at the Recycled Water Policy Volumetric Annual Reporting Website³.

B. VERBAL NON-COMPLIANCE REPORTING

CA American Water must verbally (or via email) notify and report to Central Coast Water Board noncompliance of limits related to pond freeboard, flow rate, bypass or overflow, and wastewater containment failure, pursuant to General Permit section VI.C.2.

C. ELECTRONIC GEOTRACKER SUBMITTAL

All monitoring reports must be provided electronically in a searchable PDF format, with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permitting/docs/transmittal_sheet.pdf

² See: <https://geotracker.waterboards.ca.gov/>

³ See: [Volumetric Annual Reporting | California State Water Resources Control Board](#)

CA American Water must submit all reports/documents and laboratory analytical data to the State Water Board's GeoTracker^{4,5} database consistent with applicable Electronic Submittal of Information (ESI) requirements under the Wastewater System-specific global identification number **WDR100029567** at:

<https://geotracker.waterboards.ca.gov/esi/login>

For general questions, please contact the GeoTracker Help Desk at:

Geotracker@waterboards.ca.gov.

Table 9 summarizes all the GeoTracker electronic reporting requirements. Central Coast Water Board may request submittal of some documents on paper, particularly drawings or maps that require a large size to be readable, or in other electronic formats where evaluation of data is required.

Table 9. GeoTracker Electronic Submittal Information Data Requirements

Electronic Submittal	Description of Action	Action	Frequency
Reports and Documents	Complete copy of all documents including monitoring reports (in searchable PDF format) and any other associated documents related to the Wastewater System.	Upload directly to GeoTracker all monitoring reports (in searchable PDF format) and any other associated documents.	On or before the due dates required by this General Permit and for other documents when required by the Central Coast Water Board.
Laboratory Data	All analytical data (including geochemical data) in electronic deliverable format (EDF). This includes all water, soil, and vapor samples collected when monitoring a discharge.	Upload, or direct your California ELAP-accredited laboratory staff to upload, all EDF laboratory data directly to GeoTracker.	On or before the due date of the required monitoring report.
Depth to Groundwater	Monitoring wells must have the depth-to-water information reported. Report data only for wells defined as permanent sampling points.	Upload depth-to-water information to the GeoTracker GEO_WELL file.	On or before the due date of the required monitoring report.

⁴ Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguid2.pdf

⁵ Additional information available at:

<https://geotracker.waterboards.ca.gov/>

Electronic Submittal	Description of Action	Action	Frequency
Boring Logs and Well Screen Intervals	Boring logs must be prepared by a registered professional and submitted in PDF format separately (not only as attachments to reports).	Upload boring logs (in searchable PDF format) to GeoTracker GEO_BORE file whenever a new boring is drilled.	Every time a new boring is drilled.
Field Points, Location Data (Geo XY) ^[1]	Name, classify, and identify the location (latitude and longitude) of all sampling points. Monitoring wells must be surveyed, influent and effluent sample locations must be identified on the GeoTracker mapping tool under “non-surveyed data.” These data points are required prior to laboratory data uploads.	Upload the location data (surveyed and non-surveyed) to the GeoTracker Geo_XY file.	Every time a permanent monitoring point is established.
Elevation Data (Geo Z) ^[2]	Survey and mark the elevation at the top of groundwater well casings for all permanent groundwater wells. These points are required prior to depth-to-water data uploads.	Upload the survey data to the GeoTracker GEO_Z file.	One-time, for all groundwater monitoring wells.
Geo Map	Site layout, map of facilities, Wastewater System including treatment and disposal area(s).	Upload the Site layout PDF to the GeoTracker site plan file.	Year one and every five years thereafter and when the facilities are modified.

[1] Geo XY required for all wells. New wells must be surveyed. For existing wells, use original well installation survey data. CA American Water must also upload sample locations (e.g., influent and effluent samples) that are not defined as a **permanent monitoring well** and have not been surveyed by a licensed professional.

[2] Geo Z required for all wells. New wells must be surveyed. For existing wells, use original well installation survey data.

IX. TECHNICAL REPORTS

The technical reports are due as described in Table 10.

Table 10. Technical Report Submittal Due Dates

Report	Report Due Date ^[1]
Operations and Maintenance Manual	9 months (June 17, 2023)
Time Schedule Compliance Plan	12 months (September 17, 2023)
Groundwater Monitoring Well Workplan ^[2]	13 months (October 17, 2023)
Climate Change Adaptation Plan	24 months (September 17, 2024)

[1] Reports are due within the time specified after issuance of notice of applicability to CA American Water. (September 16, 2022)

[2] Required if CA American Water choose the point of compliance as groundwater for salts and nitrate.

A. Operations and Maintenance Manual – In addition to the required components specified in Standard Provisions⁶ A.12 and A.28 (and any updates to the Standard Provisions) and General Permit section VI.A.2, the Operations and Maintenance Manual must contain the following components. Each component must contain an implementation schedule and identification of adequate funding to implement the component.

- 1. Sampling and Analysis Plan** – CA American Water’s Operation and Maintenance Manual must contain a sampling and analysis plan that meets the requirements specified herein. Anyone performing sampling on behalf of CA American Water must be familiar with the sampling and analysis plan. At a minimum, the sampling and analysis plan must contain the following:
 - a. A wastewater treatment process flow schematic with the monitoring locations labeled and scaled Wastewater System maps with treatment components, discharge locations, monitoring locations, groundwater wells, storage locations (e.g., chemical, sludge, emergency overflow ponds, etc.), buildings, etc.
 - b. Sample identification details in tabular format. The table must include the sample titles, GeoTracker field point information, sample description(s), and sampling frequencies.
 - c. Sample chain-of-custody procedures and documentation.

⁶ See Attachment E, Standard Provisions, 2013:
https://www.waterboards.ca.gov/centralcoast/board_decisions/docs/wdr_standard_provisions_2013.pdf

- d. Sample handling/preservation procedures.
- e. A description of the analytical methods.
- f. A description of sample containers, preservatives, and holding times.
- g. For water supply monitoring, a description of the location and method of data collection (e.g., onsite well sampling, use of consumer confidence report, etc.).
- h. For groundwater monitoring, a description of the well purging and field methods.

2. Sludge Management Plan – CA American Water’s Operation and Maintenance Manual must contain a sludge management plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. At a minimum, the plan must describe the following:

- a. An estimated volume/amount and quality of sludge and scum that will be generated.
- b. How sludge, scum, and supernatant will be stored and disposed of to protect groundwater quality.
- c. If sludge will be subject to further treatment, describe the treatment and storage requirements.
- d. Procedures for cleaning of digesters or storage vessels and the treatment and disposal of the residuals. If drying of residuals is planned, describe how that will be performed to prevent nuisance odors, prevent vectors, and protect groundwater quality.

3. Wastewater Disposal Management Plan – CA American Water’s Operation and Maintenance Manual must contain a wastewater disposal management plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. At a minimum, the wastewater disposal management plan must include:

- a. A description of the wastewater disposal area and a map denoting acreage.
- b. Loading calculations based on flow volumes, applied acreage, and biochemical oxygen demand, salts (total dissolved solids, sodium, chloride, sulfate, boron), and nitrogen analytical results.
- c. A description of wastewater disposal and water quality protection practices.

4. Spill Prevention and Emergency Response Plan – CA American Water’s Operation and Maintenance Manual must contain a spill prevention and emergency response plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. The spill prevention and

emergency response plan must describe operation and maintenance activities to prevent accidental releases of wastewater and to effectively respond to such releases and minimize the environmental impact. At a minimum, the spill prevention and emergency response plan must address the following:

- a. Operation and Control of Wastewater System - A description of the wastewater treatment equipment, operational controls, flow measurement and calibration procedures, and treatment system schematic including valve/gate locations.
- b. Sludge Handling - A description of the sludge handling equipment, operational controls, and disposal procedures.
- c. Collection System Maintenance - A description of collection system cleaning and maintenance, equipment tests, and alarm functionality tests to minimize the potential for wastewater spills originating in the collection system or headworks. For collection systems subject to State Water Board Order No. 2006-0003-DWQ, Statewide General Waste Discharge Requirements for Sanitary Sewer Systems (or its replacement), reports prepared to comply with State Water Board Order No. 2006-0003-DWQ satisfy this requirement.
- d. Emergency Response - A description of emergency response procedures including for emergencies such as power outage, severe weather, flooding, or inadequate freeboard (for systems with wastewater treatment, storage, or disposal ponds or treated non-potable recycled water storage ponds). An equipment and telephone list for contractors/consultants, emergency personnel, and equipment vendors.
- e. Finance - At a minimum, discuss current fees, projected fees, current budget for spill prevention and emergency response, projected budget for spill prevention and emergency response.
- f. Notification Procedures - Coordination procedures with fire, police, Governor's Office of Emergency Services (CalOES), Central Coast Water Board, and local county health department personnel.

5. Training Records Log – CA American Water's Operation and Maintenance Manual must contain updated training records logs that demonstrates CA American Water is complying with General Permit section VI.B.3.

B. Time Schedule Compliance Plan – As set forth in General Permit sections V.A and VI.A.5, if CA American Water anticipates that additional time is needed to achieve compliance with the effluent limitations, CA American Water must prepare and submit for Central Coast Water Board review and approval, a time schedule compliance plan. At a minimum, the time schedule compliance plan must address the following:

1. Comparison of the current effluent quality to the effluent and groundwater limitations in General Permit Tables 3-6.

2. A detailed description and chronology of efforts, since issuance of the notice of applicability, to reduce wastes.
3. Justification of the need for additional time to achieve the effluent limitations in General Permit Tables 3-6.
4. A detailed time schedule of specific actions CA American Water will take to achieve the BOD₅ and TSS effluent limitations, and the chloride and nitrate effluent or groundwater limitations (depending on CA American Water's preferred point of compliance.)
5. A demonstration that the time schedule requested is as short as possible, considering the technological, operation, and economic factors that affect the design, development, and implementation of the measures that are necessary to comply with the effluent limitation(s).
6. If the requested time schedule exceeds one year, the proposed schedule must include interim requirements and the date(s) for their achievement. The interim requirements shall include both of the following:
 - i. Effluent, or groundwater, limitation(s) for the pollutant(s) of concern.
 - ii. Actions, measurable milestones, and tangible products leading to compliance with the effluent limitation(s).

C. Groundwater Monitoring Workplan – If, in the Time Schedule Compliance Workplan, CA American Water proposes groundwater as the point of compliance for nitrogen and chloride, it must submit a Groundwater Monitoring Workplan. This workplan is not required if CA American Water will consolidate or upgrade the system to treat nitrogen and meet the nitrogen effluent limit. **The workplan must be submitted 13 months from the** issuance of notice of applicability to CA American Water.

At a minimum, the workplan must include a preliminary hydrogeologic conceptual site model and propose the installation of at least three shallow groundwater monitoring wells to establish groundwater gradient, groundwater flow velocity and direction, and evaluate groundwater quality influenced by the wastewater disposal. The number and location of the proposed groundwater monitoring well network must be on a scale sufficient to determine potential impacts and be sufficiently representative of groundwater conditions upgradient and downgradient of the permitted disposal area. The groundwater monitoring wells should not be installed prior to Central Coast Water Board approval of the groundwater monitoring workplan and preliminary hydrogeologic conceptual site model.

The groundwater monitoring wells must be installed within first encountered groundwater and in accordance with California Department of Water Resources Bulletin No. 74-81 and Supplement No. 74-90, California Water Code sections 13710 through 13755, and any local permitting requirements. The locations and top-of-casing elevations for the newly installed monitoring wells must be surveyed by a

licensed land surveyor. CA American Water must install⁷ the Central Coast Water Board approved groundwater monitoring well network within **90 days** of receiving Central Coast Water Board approval.

D. Climate Change Adaptation – The Climate Change Adaptation Plan must, at a minimum, include the following components:

1. Hazards and Vulnerabilities – Identify climate change hazards, at a minimum accounting for the hazards listed below, applicable to the Wastewater System. Using up-to-date tools, data, and guidance from the State of California (e.g., Cal-Adapt⁸, Sea-Level Rise Guidance from Ocean Protection Council, reports from the Climate-Safe Infrastructure Working Group, the Climate Adaptation Planning Guide, and California Climate Assessment Regional Reports), assess the Wastewater System's vulnerability to identified hazards that could cause reduction, loss, or failure of treatment processes and/or critical structures at the Wastewater System. Identify and justify the resources (e.g., models and tools, design parameters) used to inform identification of these hazards and vulnerabilities.

- a. Sea Level Rise – Saltwater intrusion, flooding and inundation, and increased coastal erosion.
- b. Precipitation Pattern Changes.
 - I. Drought – Decreased influent quantity and quality.
 - II. Peak Events – Flooding and increased influent quantity.
- c. Temperature fluctuations and extremes.
- d. Increased wildfires.
- e. Increased power outages.

2. Resiliency Actions – Identify actions to build Wastewater System and operational resilience to identified vulnerabilities, accounting for options that minimize resource impacts.

⁷ Well installation must be supervised by a California licensed Civil Engineer or Professional Geologist.

⁸ Cal-Adapt is an online resource with downscaled climate project data. It provides users with projections and more detailed downloadable data supporting a range of needs and array of climate models and emissions scenarios. Cal-Adapt offers climate projections for the major stressors facing California, including the following: temperature averages and extremes, precipitation averages and extremes, sea-level rise, wildfires, and drought. The Governor's Office of Planning and Research (OPR) recommends agencies use Representative Concentration Pathway (RCP) 8.5 for analyses considering impacts through 2050, because there are minimal differences between emissions scenarios during the first half of the 21st century.

X. LEGAL REQUIREMENTS

The Central Coast Water Board's requirements that the CA American Water submit the technical and monitoring reports described in this MRP are made pursuant to [section 13267 of the California Water Code](#). Failure to submit reports in accordance with schedules established by this General Permit and notice of applicability with attachments or failure to submit a report of sufficient technical quality to be acceptable to the Central Coast Water Board may subject CA American Water to enforcement action pursuant to section 13268 of the California Water Code. Pursuant to [section 13268 of the Water Code](#), a violation of a request made pursuant to section 13267 may subject CA American Water to civil liability assessment of up to \$1,000 per day in which the violation occurs.

The Central Coast Water Board needs the required information to ensure compliance with the notice of applicability and the General Permit. CA American Water is required to submit this information because it is subject to the General Permit and is responsible for the discharge.

The burden, including costs, of the reports bears a reasonable relationship to their need and the benefits to be obtained. The requirement for the reports is necessary to ensure compliance with the General Permit, notice of applicability, and monitoring and reporting program to protect water quality.

CA American Water must implement the above monitoring program on October 1, 2022. The Central Coast Water Board may rescind or modify this MRP at any time.

Ordered By:

Jennifer Epp  Digitally signed by Jennifer Epp
Date: 2022.09.16 15:59:20 -07'00'
Water Boards

for Matthew T. Keeling
Executive Officer

R:\RB3\Shared\WDR\WDR Facilities\Monterey Co\Spreckels WWTP\Big Order
Enrollment\final permit\Spreckels_BigOrder_MRP.docx
Last modified: 04/21/2022