

order

California Regional Water Quality Control Board
North Coast Region

ORDER NO. 89-40
ID. NO. 1B790540SON

WASTE DISCHARGE REQUIREMENTS

FOR

UNITED STATES ARMY, CORPS OF ENGINEERS
WARM SPRINGS DAM RECREATION AREA
DOMESTIC WASTEWATER TREATMENT AND DISPOSAL SYSTEM

3333 Skaggs Springs Road
Geyserville, California 95441
Sonoma County

The California Regional Water Quality Control Board, North Coast Region, finds that:

1. The United States Army Corps of Engineers, Sacramento District owns and operates the Warm Springs Dam Recreation Area (hereafter the discharger) located on Skaggs Springs Road in the center of Section 17, TION, RIOW, MDB&M, as shown on Attachment "A" incorporated herein and made a part of this Order.
2. The discharger operates domestic waste collection, treatment, and disposal facilities designed to accommodate wastes from 4,000 visitors and picnickers, 15 operational personnel, and 20 permanent residents.

Wastewater sources include restrooms in the fish hatchery building, visitors center, and administration building, comfort stations in the picnic and day use area downstream of the dam, and four permanent residences for operational personnel.

3. The existing wastewater treatment and disposal facilities are designed to handle wastewater flows up to 22,400 gpd and include a pump station, two 10,000 gallon septic tanks, and leachfield.
4. The Regional Board adopted Waste Discharge Requirements Order No. 79-54 on February 22, 1979.
5. The Board adopted Water Quality Control Plans for the Klamath River Basin (1A) and the North Coastal Basin (1B) on March 20, 1975. The Klamath River Basin Plan (1A) was combined with the North Coastal Basin Plan (1B) to form the Water Quality Control Plan for the North Coast Region. The Plan for the North Coast Region was adopted by the Board on April 28, 1988 and approved by the State Water Resources Control Board on November 15, 1988. The Plan includes water quality objectives and receiving water limitations.

6. Beneficial uses of the waters of the Russian River and its tributaries include:

- a. municipal and domestic water supply
- b. agricultural water supply
- c. industrial service water supply
- d. industrial process water supply
- e. water contact recreation
- f. non-contact water recreation
- g. groundwater recharge
- h. warm fresh water habitat
- i. cold freshwater habitat
- j. fish migration
- k. fish spawning
- l. wildlife habitat

7. Beneficial uses of the areal groundwaters include:

- a. domestic water supply
- b. agricultural water supply
- c. industrial water supply

8. This project is exempt from provisions of the California Environmental Quality Act of 1970 as an existing facility (Title 14, Division 7, Chapter 3, Section 15301). No changes in facilities or operation are proposed.
9. The Regional Board finds that operation of this facility will not have adverse water quality related effects if operations are conducted in accordance with prohibitions, specifications, and provisions contained in this Order.
10. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge.
11. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

THEREFORE, IT IS HEREBY ORDERED that Waste Discharge Requirements Order No. 79-54 be rescinded and that the U.S. Army Corps of Engineers, Sacramento District, shall comply with the following:

A. DISCHARGE PROHIBITIONS

1. The discharge of waste to surface waters is prohibited.
2. The discharge of waste to land that is not under the control of the discharger except as provided for in Provision C.2, is prohibited.
3. The discharge of all wastewater shall be kept underground at all times.
4. An adequate replacement area equivalent to the initial disposal area shall be reserved at the time of the initial installation of all leachfields. Incompatible uses of the initial disposal area and the replacement area are prohibited.

5. The discharge of any pollutant not identified and authorized by the waste discharge requirements or the discharge of any pollutant in a manner or quantity which differs from that stated in the report of waste discharge is prohibited.

B. DISCHARGE SPECIFICATIONS

1. The average daily wastewater flow shall not exceed 22,400 gallons per day.

C. DISCHARGE PROVISIONS

1. Neither the treatment nor the disposal of waste shall cause a nuisance or pollution as defined in Section 13050 of the California Water Code.
2. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of at a legal point of disposal and in accordance with the provisions of Title 23, Chapter 3, Subchapter 15 of the California Water Code or any point approved by the Executive Officer.
3. The discharger shall comply with the Contingency Planning and Notification Requirements, Order No. 74-151, Monitoring and Reporting Program No. 89-40 and the General Provisions for Monitoring and Reporting and any modifications to these documents as specified by the Executive Officer. Such documents are attached to this Order and incorporated herein.
4. The design and installation of the domestic waste disposal system shall be in compliance with Sonoma County health ordinances and regulations.
5. In the event the discharger is unable to comply with any of the conditions of this Order due to:
 - a. breakdown of waste treatment equipment;
 - b. accidents caused by human error or negligence; or
 - c. other causes such as acts of nature;

the discharger shall notify the Executive Officer by telephone as soon as he or his agents have knowledge of the incident and confirm this notification in writing within two weeks of the telephone notification. The written notification shall include pertinent information explaining reasons for the noncompliance and shall indicate what steps were taken to correct the problem and the dates thereof, and what steps are being taken to prevent the problem from recurring.

6. This Board requires the discharger to file a report of waste discharge at least 120 days before making any material change or proposed change in the character, location, or volume of the discharge.
7. The discharger shall permit the Regional Board:
 - a. Entry upon premises in which an effluent source is located or in which any required records are kept;

- b. Access to copy any records required to be kept under terms and conditions of this Order;
 - c. Inspection of monitoring equipment or records; and
 - d. Sampling of any discharge.
8. The discharger shall maintain in good working order and operate as efficiently as possible any facility or control system installed by the discharger to achieve compliance with the waste discharge requirements.
9. The requirements prescribed herein do not authorize the commission of any act causing injury to the property of another, nor protect the discharger from his liabilities under federal, state, or local law.
10. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the discharger, the discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this Board.

Certification

I, Benjamin D. Kor, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, North Coast Region, on April 26, 1989.

Original Signed By:

Benjamin D. Kor
Executive Officer

California Regional Water Quality Control Board
North Coast Region

MONITORING AND REPORTING PROGRAM NO. 89-40

FOR

UNITED STATES ARMY CORPS OF ENGINEERS
WARM SPRINGS DAM RECREATION AREA
DOMESTIC WASTEWATER TREATMENT AND DISPOSAL SYSTEM

Sonoma County

MONITORING

1. Waste Volume

The discharger shall measure and record daily the volume of waste discharged to the waste facilities.

2. Disposal Field Inspections

- a. The discharger shall inspect the disposal field monthly and shall note and record any odors, evidence of surfacing wastewater or other signs of malfunction.
- b. The discharger shall inspect all wet wells and pumps monthly and shall record the maintenance provided to them.

3. Septic Tank Inspection

The discharger shall inspect the septic tank(s) annually to determine the need for pumping. When the level of solids in any tank is equal to or in excess of one third of the total depth of the tank, the tank shall be pumped.

4. Groundwater Monitoring

- a. The discharger shall measure and record the elevation of water in all monitoring wells on a weekly basis. Reference datum shall be ground surface at the well.
- b. The discharger shall sample any standing water in the wells for analysis of the following:

<u>Constituents</u>	<u>Units</u>	<u>Sampling Frequency</u>
Total Coliform	MPN/100 ml	monthly
Fecal Coliform	MPN/100 ml	monthly
Nitrate Nitrogen	mg/l	monthly

MONITORING AND REPORTING
PROGRAM NO. 89-40

-2-

REPORTING

The discharger shall submit monthly monitoring reports to the Regional Board by the 15th day of the following month. The report shall include all items specified above and the dates on which monitoring or inspection was performed.

In addition to the above, the discharger shall have all flow measuring devices tested annually and their accuracy certified. This certification shall be submitted annually with the monitoring report for the month of August.

Ordered by _____

Benjamin D. Kor
Executive Officer

April 26, 1989

California Regional Water Quality Control Board
North Coast Region

CONTINGENCY PLANNING AND NOTIFICATION REQUIREMENTS

FOR

ACCIDENTAL SPILLS AND DISCHARGES

ORDER NO. 74-151

The California Regional Water Quality Control Board, North Coast Region, finds that:


1. Section 13225 of the Porter-Cologne Water Quality Control Act requires the Regional Board to perform general duties to assure positive water quality control.
2. The Regional Board has been advised of situations in which preparations for, and response to accidental discharges and spills have been inadequate.
3. Persons discharging waste or conveying, supplying, storing, or managing wastes or hazardous materials have the primary responsibility for contingency planning, incident reporting and continuous and diligent action to abate the effects of such unintentional or accidental discharge.

THEREFORE, IT IS HEREBY ORDERED THAT:

- I. All persons who discharge wastes or convey, supply, store, or otherwise manage wastes or other hazardous material shall:
 - A. Prepare and submit to this Regional Board, according to a time schedule prescribed by the Executive Officer, a contingency plan defining the following:
 1. Potential locations and/or circumstances under which accidental discharge incidents might be expected to occur,
 2. Possible water quality effects of accidental discharges,
 3. The conceptual plan for cleanup and abatement of accidental discharge incidents, including:
 - a. The individual who will be in charge of cleanup and abatement activities on behalf of the discharger,
 - b. The equipment and manpower available to the discharger to implement the cleanup and abatement plans,
 - B. Immediately report to the Regional Board any accidental discharge incidents. Such notification shall be made by telephone as soon as the responsible person or his agent has knowledge of the incident.

- C. Immediately begin diligent and continuous action to cleanup and abate the effects of any unintentional or accidental discharge. Such action shall include temporary measures to abate the discharge prior to completing permanent repairs to damaged facilities.
- D. Confirm the telephone notification in writing within two weeks of the telephone notification. The written notification shall include: reasons for the discharge, duration and volume of the discharge, steps taken to correct the problem and steps being taken to prevent the problem from recurring.
- II. Upon original receipt of phone report (I.B), the Executive Officer shall immediately notify all affected agencies and known users of waters affected by the unintentional or accidental discharge.
- III. Provide updated information to the Regional Board in the event of change of staff, size of the facility, or change of operating procedures which will affect the previously established contingency plan.
- IV. The Executive Officer or his employees shall maintain liaison with the discharger and other affected agencies and persons to provide assistance in cleanup and abatement activities.
- V. The Executive Officer shall transmit copies of this Order to all persons whose discharges of waste handling activities are governed by Waste Discharge Requirements or an NPDES Permit. Such transmittal shall include a current listing of telephone numbers of the Executive Officer and his key employees to facilitate compliance with Item I.B of this Order.

Ordered by


Benjamin D. Kor
Executive Officer

July 24, 1974
(Retyped January, 1986)

Your primary notification should be to the Regional Board office at Santa Rosa at (707) 576-2220. During off hours, you will be able to leave a recorded message at that number and, if you have a spill or discharge emergency, you will also be referred to the State Office of Emergency Services (OES) at (800) 852-7550. OES maintains a roster of key employees and will relay your notification to Regional Board staff.

California Regional Water Quality Control Board
North Coast Region

GENERAL MONITORING AND REPORTING PROVISIONS

February 3, 1971
(Retyped July, 1982)

GENERAL PROVISIONS FOR SAMPLING AND ANALYSIS

Unless otherwise noted, all sampling, sample preservation, and analyses shall be conducted in accordance with the current edition of "Standard Methods for the Examination of Water and Waste Water" or approved by the Executive Officer.

All analyses shall be performed in a laboratory certified to perform such analyses by the California State Department of Health or a laboratory approved by the Executive Officer.

All samples shall be representative of the waste discharge under the conditions of peak load.

GENERAL PROVISIONS FOR REPORTING

For every item where the requirements are not met, the discharger shall submit a statement of the actions undertaken or proposed which will bring the discharge into full compliance with requirements at the earliest time and submit a timetable for correction.

By January 30 of each year, the discharger shall submit an annual report to the regional board. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year. In addition, the discharger shall discuss the compliance record and the corrective actions taken or planned which may be needed to bring the discharge into full compliance with the waste discharge requirements.

The discharger shall file a written report within 90 days after the average dry-weather flow for any month that equals or exceeds 75 percent of the design capacity of the waste treatment or disposal facilities. The report shall contain a schedule for studies, design, and other steps needed to provide additional capacity or limit the flow below the design capacity prior to the time when the waste flow rate equals the capacity of the present units.

