



Central Valley Regional Water Quality Control Board

1 October 2019

Mike Finnigan
Deputy Public Works Director
City of Yuba City
302 Burns Drive
Yuba City, CA 95991

CERTIFIED MAIL
7015 0640 0006 6080 5710

SELF-MONITORING REPORT REVIEW AND NOTICE OF VIOLATION, CITY OF YUBA CITY, YUBA CITY WASTEWATER TREATMENT FACILITY, SUTTER COUNTY

The discharge of wastewater by the City of Yuba City (Discharger) from the Yuba City Wastewater Treatment Facility (Facility) was regulated by Waste Discharge Requirements (WDRs) Order R5-2013-0094-01 (CA0079260) prior to 1 April 2019 and is currently regulated by WDRs Order R5-2019-0017-01. The WDRs Monitoring and Reporting Program (MRP) requires monitoring for constituents and other parameters and specifies the location and frequency of monitoring. Central Valley Water Board staff has reviewed the monthly electronic self-monitoring reports (eSMRs) submitted by the Discharger for the monitoring periods **April 2019** through **July 2019**, **First Quarter 2019**, and **Second Quarter 2019**.

The review of the eSMR identified the violations listed below.

Effluent Limitation Violations

The discharge resulted in violations of effluent limitations contained in the WDRs, as listed below. These violations appear to be subject to mandatory minimum penalties (MMPs), which will be assessed at a later date.

Table A. Effluent Limitation Violations

Date	Parameter	Units	WDRs Limit	Measured	Period	CIWQS
4 Apr 2019	Settleable Solids	ml/L	≤ 0.2	0.7	Max Daily	1064650
23 Apr 2019	pH	std	≤ 8.5	9.2	Instantaneous Maximum	1064651
3 May 2019	Total Coliform	MPN/100 ml	≤ 23	33	7-Day Median	1060250
6 May 2019	Total Coliform	MPN/100 ml	≤ 23	540	7-Day Median	1060252
10 May 2019	Total Coliform	MPN/100 ml	≤ 23	460	7-Day Median	1064655
6 May 2019	Total Coliform	MPN/100 ml	≤ 240	920	> once in 30 days	1060251

KARL E. LONGLEY SCD, P.E., CHAIR | PATRICK PULUPA, ESQ., EXECUTIVE OFFICER

Monitoring and Reporting Program Violations

The following MRP violations occurred:

Table B. Monitoring and Reporting Program Violations

Date	Monitoring Location	Parameter	Required monitoring frequency	Reported monitoring frequency	CIWQS
Week ending 4/27/19	EFF-001	Total Coliform	3/week	2/week	1064654
Apr 2019	EFF-001	River Flow	1/month	0/month	
Apr 2019	EFF-001	Depth over Diffuser	1/month	0/month	
May 2019	EFF-001	River Flow	1/month	0/month	1064656
May 2019	EFF-001	Depth over Diffuser	1/month	0/month	
Jun 2019	EFF-001	River Flow	1/month	0/month	1064657
Jun 2019	EFF-001	Depth over Diffuser	1/month	0/month	
Jul 2019	EFF-001	River Flow	1/month	0/month	1064658
Jul 2019	EFF-001	Depth over Diffuser	1/month	0/month	

Submittals Required by the WDRs

The reports listed below were required by the WDRs during the period reviewed under cover of this letter. The next report required is the 2019 Annual Operations Report (MRP X.D.1), which is due 30 January 2020.

Table C. Submittal Required by the WDRs

Report	Due Date	Submitted
First Quarter 2019 Pretreatment Report	1 May 2019	1 May 2019
Analytical Methods Report	8 Apr 2019	8 Apr 2019
Diffuser Maintenance Report	1 Jul 2019	1 Jul 2019

Comments regarding the eSMR

1. Section IV.A.d requires reporting of the 1-hour average and 4-day average for Chlorine Residual when discharging at EFF-001 on 28 July 2019, but did not calculate the 1-hr average. Please ensure that future eSMRs include calculation of the 1-hour average and 4-day average for Chlorine Residual when applicable to avoid reporting violations.
2. Section VII.B.2 of the MRP requires semi-annual reporting of the depth to groundwater at all groundwater monitoring locations. Groundwater monitoring results were submitted for the first half of 2019 in the First Quarter 2019 eSMR, but the results do not include the depth to groundwater at any of the groundwater monitoring locations. Please ensure that depth to groundwater is included with all future submittals of groundwater monitoring results to avoid monitoring violations.
3. Section IX.B.1.a of the MRP requires quarterly sludge testing for priority pollutants at BIO-001. However, results of sludge testing are not included in either the First Quarter 2019 or Second Quarter 2019 eSMRs. Please ensure that required sludge testing results are

included in all future quarterly eSMRs to avoid monitoring violations.

4. Section V.A.5.b requires weekly reporting of the 95th percentile concentration for Dissolved Oxygen at RSW-001 and RSW-002. However, no results were reported for the 95th percentile concentration for Dissolved Oxygen in any of the eSMRs reviewed under cover of this letter. Please ensure that weekly results for the 95th percentile concentration for Dissolved Oxygen at RSW-001 and RSW-002 are included in all future eSMRs to avoid reporting violations.
5. Section VIII.A.2 of the MRP requires weekly visual monitoring of receiving water conditions, with summaries submitted in monthly eSMRs. However, visual observations are not included in the eSMRs for May, June, and July 2019. Please ensure that monthly summaries of receiving water conditions are included in all future eSMRs to avoid reporting violations.
6. Section IX.D.2 of the MRP requires weekly visual inspection of the ponds, with summaries submitted in monthly eSMRs. However, visual observations are not included in any of the eSMRs reviewed under cover of this letter. Please ensure that monthly summaries of pond conditions are included in all future eSMRs to avoid reporting violations.
7. Section IX.D.2 of the MRP requires weekly estimates of the volume of wastewater in each pond. However, the volume of wastewater in each pond is not reported—even when reporting of other information indicates ponds were in use—in any of the eSMRs reviewed under cover of this letter. Please ensure that estimates of wastewater volume are included for applicable ponds in all future eSMRs to avoid reporting violations.
8. Section V.A.17 of the WDRs requires comparison of turbidity results at RSW-002 with turbidity results at RSW-001. However, turbidity comparisons are not included in any of the eSMRs reviewed under cover of this letter. Please ensure that turbidity comparisons between RSW-002 and RSW-001 are included in all future eSMRs.
9. Section V.A.15 of the WDRs requires comparison of temperature results at RSW-002 with temperature results at RSW-001. However, temperature comparisons are not included in any of the eSMRs reviewed under cover of this letter. Please ensure that temperature comparisons between RSW-002 and RSW-001 are included in all future eSMRs.
10. Chlorine residual and bisulphite results are reported without units. Please ensure that the units are identified for chlorine residual and bisulphite in all future eSMRs.
11. To facilitate review of eSMRs, please include results for Acute Toxicity, Chlorine Residual, Bisulphite, and groundwater monitoring in the CIWQS Data File (CDF) spreadsheet rather than uploading them as separate files.
12. To facilitate review of eSMRs, please indicate in the cover letter for each monthly eSMR which ponds were used that month, if any, and the dates each pond was in use.

If you have any questions, please contact Jon Rohrbough at (916) 464-4822 or Jon.Rohrbough@waterboards.ca.gov.



Xuan Luo, Ph.D., P.E.
Senior Water Resource Control Engineer
NPDES Compliance and Enforcement Unit