

Central Valley Regional Water Quality Control Board

23 March 2016

Mark Rowney, General Manager
Mariposa Public Utility District
P.O. Box 494
Mariposa, CA 95338

CERTIFIED MAIL
7015 0640 0003 6852 2407

**MINOR MODIFICATIONS TO WASTE DISCHARGE REQUIREMENTS ORDER R5-2014-0042
(NPDES PERMIT NO. CA0079430); MARIPOSA PUBLIC UTILITY DISTRICT;
WASTEWATER TREATMENT FACILITY; MARIPOSA COUNTY**

Thank you for the 10 February 2016 email that expressed consent to pursue minor modifications to Waste Discharge Requirements Order R5-2014-0042 (Order) to address inconsistencies in turbidity monitoring requirements. Pursuant to Code of Federal Regulations, Title 40, Part 122.63, permits may be modified to institute minor changes, including the correction of typographical errors and the addition of more frequent monitoring.

The Order includes typographical errors in Attachment E (Monitoring and Reporting Program or MRP), specifically in the naming of the filter effluent monitoring site (FIL-001). Additionally, Attachment E (MRP) inadvertently excludes monitoring site description and monitoring requirements for the filter influent. These filter monitoring sites were introduced correctly in the Order, Provision VI.C.4.a., but the naming convention and expectations did not carry through to Attachment E (MRP). To restore consistency in the Order, Attachment E (MRP) has been modified to follow the filtration specifications introduced in Order, Provision VI.C.4.a.

This letter serves as notification that the following typographical errors have been fixed and the following monitoring requirements have been added to the Order to correct the inconsistencies in turbidity monitoring expectations.

1. **Attachment E – Monitoring and Reporting Program, Table E-1 Monitoring Station Locations.** Revise the following rows of Table E-1 in underline/strikeout format:

Table E-1 Monitoring Station Locations

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
--	<u>FIL-001</u>	<u>Monitoring of the filter influent to be measured upstream of the filter system.</u>
--	FIL-001 2	Monitoring of the filter effluent to be measured immediately downstream of the filters prior to the disinfection system.

2. **Attachment E – Monitoring and Reporting Program, Provision IX.C.1 and Table E-8 Ultraviolet Light Disinfection System Monitoring Requirements.** Revise MRP, Provision IX.C.1. and the relevant rows of Table E-8 as follows in underline/strikeout format:

C. Filtration System and Ultraviolet Light (UV) Disinfection System

1. Monitoring Locations UVS-001, and FIL-001, and FIL-002

Beginning on 4 December 2017, the Discharger shall monitor the UV disinfection system as follows:

Table E-8. Ultraviolet Light Disinfection System Monitoring Requirements

Parameter	Units	Sample Type	Monitoring Location	Minimum Sampling Frequency
<u>Turbidity</u>	<u>NTU</u>	<u>Meter</u>	<u>FIL-001</u>	<u>Continuous^{1,2,3}</u>
<u>Turbidity</u>	<u>NTU</u>	<u>Meter</u>	<u>FIL-002</u>	<u>Continuous^{1,2}</u>
UV Dose ³⁴	⁴⁵	Calculated	UVS-001	Continuous ¹

³ Monitoring at FIL-001 is only required when the Discharger is not using coagulation.

³⁴ Report daily minimum hourly UV dose and daily average UV dose. The minimum hourly average dose shall consist of lowest hourly average dose provided in any channel that had at least one bank of lamps operating during the hour interval. For channels that did not operate for the entire hour interval, the dose will be averaged based on the actual operation time.

⁴⁵ Units are millijoule per square centimeter (mJ/cm²)

The corrected order may be downloaded from the Central Valley Water Board's internet website at: http://www.waterboards.ca.gov/centralvalley/board_decisions/adopted_orders/#mariposa

If you have any questions regarding these minor modifications, please contact Nicolette Dentoni at (559) 444-2505 or at Nicolette.Dentoni@waterboards.ca.gov.

for 
Pamela C. Creedon
Executive Officer

cc: David Smith, U.S. Environmental Protection Agency, Region IX, San Francisco
Peter Kozelka, U.S. Environmental Protection Agency, Region IX, San Francisco
Carl Carlucci, State Water Resources Control Board, Division of Drinking Water, Fresno
Sarah Windsor, Friends of Mariposa Creek, Mariposa
Debbie Webster, Central Valley Clean Water Association, Sacramento
Bill Jennings, California Sportfishing Protection Alliance, Woodland

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mark Rowney, General Manager
Mariposa Public Utility District
P.O. Box 494
Mariposa, CA 95338



9590 9403 0882 5223 6350 18

2. Article Number (Transfer from carrier label)

7015 0640 0003 6852 2407

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X Susan Wages

☐ Agent☐ Addressee

B. Received by (Printed Name)

Susan Wages

C. Date of Delivery

MAR 25 2016

D. Is delivery address different from item 1? ☐ Yes
If YES, enter delivery address below: ☐ No

MAR 28 2016

3. Service Type

☐ Adult Signature☐ Adult Signature Restricted Delivery☒ Certified Mail®☐ Certified Mail Restricted Delivery☐ Collect on Delivery☐ Collect on Delivery Restricted Delivery☐ Insured Restricted Delivery

(over \$500)

☐ Priority Mail Express®☐ Registered Mail™☐ Registered Mail Restricted Delivery☐ Return Receipt for Merchandise☐ Signature Confirmation™☐ Signature Confirmation Restricted Delivery

PS Form 3811, July 2015 PSN 7530-02-000-9053

Domestic Return Receipt

USPS TRACKING#



9590 9403 0882 5223 6350 18



First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

United States
Postal Service

• Sender: Please print your name, address, and ZIP+4® in this box•

**CALIFORNIA REGIONAL WATER
QUALITY CONTROL BOARD**

Central Valley Region

1685 E Street

Fresno, CA 93706

ND