

Attachment 1 – Summary of System Specific General Order ¹

A. Prohibitions:

Section A.1-A.11 - See General Order for Prohibition details.

B. Requirements by Wastewater System Type:

Section B.1.a-B.1.i - See General Order for requirements applying to All Wastewater Systems.

Section B.1.a – **15,000** gpd Maximum Daily Wastewater Flow Limit

8,000 gpd Annual Average Daily Wastewater Flow Limit

Section B.3.a-B.3.g - See General Order for requirements applying to Aerobic Treatment Units

Section B.6.a-B.6.h - See General Order for requirements applying to Subsurface Disposal Systems

Section B.8.a-B.8.f - See General Order for requirements applying to Sludge/Solids/Biosolids Disposal

C. Groundwater and Surface water Limitations:

C.1. a. - b. - See General Order and Chapter 3 of Water Quality Control Plan for the North Coast Region ([Basin Plan](https://www.waterboards.ca.gov/northcoast/water_issues/programs/basin_plan/180710/BPChapter3WaterQualityObjectives.pdf)) (https://www.waterboards.ca.gov/northcoast/water_issues/programs/basin_plan/180710/BPChapter3WaterQualityObjectives.pdf) for Groundwater and Surface water Limitations.

D. Effluent Limitations:

D.1.a – 90mg/l Biochemical Oxygen Demand (BOD) monthly average

E. Provisions:

E.1.a – Spill Prevention and Emergency Response Plan – Have on-site.

E.1.b – Sampling and Analysis Plan – Have on-site.

E.1.c – Sludge Management Plan – Submit to Regional Water Board within 90 days issuance of NOA. Have on-site.

E.2.h – Copy of NOA letter, and General Order – Have on-site.

¹ The General Order is available on the [State Water Board website](https://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf) at:
https://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf