



California Regional Water Quality Control Board

Central Valley Region

Katherine Hart, Chair



Matthew Rodriguez
Secretary for
Environmental Protection

11020 Sun Center Drive, #200, Rancho Cordova, California 95670-6114
(916) 464-3291 • FAX (916) 464-4645
<http://www.waterboards.ca.gov/centralvalley>

Edmund G. Brown Jr.
Governor

20 January 2012

Hector De LaRosa
City Manager
City of Rio Vista
One Main Street
Rio Vista, CA 94571

CERTIFIED MAIL NO.
7010 3090 0000 5045 2118

**MINOR MODIFICATIONS TO WASTE DISCHARGE REQUIREMENTS ORDER
R5-2010-0081 (NPDES No. CA0083771), CITY OF RIO VISTA NORTHWEST
WASTEWATER TREATMENT PLANT, SOLANO COUNTY**

This minor modification letter is to correct a typographical error contained in the Monitoring and Reporting Program (MRP) of Waste Discharge Requirements Order R5-2010-0081 (Order). Pursuant to the Code of Federal Regulations, Title 40 Part 122.63, minor modification of permits is allowed to correct typographical errors.

In the MRP, Section IV.A.1, Table E-3 "Effluent Monitoring" contains a footnote for the turbidity monitoring requirement that requires the sampling of total coliform organisms in the event that the turbidity exceeds 1 Nephelometric Turbidity Units (NTU). This is a typographical error and should be 10 NTU to be consistent with the Ultraviolet Disinfection System Operating Specifications (Section VI.C.4.a of the Order). Therefore, this letter serves as notification that footnote 13 to Table E-3 is changed as follows.

¹³ *Report daily average turbidity and maximum. If the turbidity exceeds 10 NTU, collect a sample for total coliform organisms and report the duration of the turbidity exceedance.*

If you have any questions regarding this minor modification or other NPDES permit-related requirements, please contact Jim Marshall of our office at (916) 464-4772 or jdmarsshall@waterboards.ca.gov.

Pamela C. Creedon
Executive Officer

cc: Christopher McAuliffe, Veolia Water North America

California Environmental Protection Agency