



# California Regional Water Quality Control Board

## Santa Ana Region



Linda S. Adams  
Secretary for  
Environmental Protection

3737 Main Street, Suite 500, Riverside, California 92501-3348  
Phone (951) 782-4130 • FAX (951) 781-6288 • TDD (951) 782-3221  
[www.waterboards.ca.gov/santaana](http://www.waterboards.ca.gov/santaana)

Arnold Schwarzenegger  
Governor

June 25, 2007

Mr. Stephen Schultz  
Wastewater Systems Manager  
5950 Acorn Street  
Riverside, CA 92504

### REVISED MONITORING AND REPORTING PROGRAM R8-2006-0009

Dear: Mr. Schultz

Attached is an amended copy of Monitoring and Reporting Program R8-2006-0009. As you have requested, your monitoring and reporting program has been amended to reflect the changes in the influent monitoring locations and to modify the requirement for the wetlands sampling stations. Influent monitoring locations M-INF A through D have been eliminated and have been replaced with a single monitoring site, M-INF. The new influent point is called "Combined influent monitoring and sampling station".

We have also added clarification that effluent monitoring locations M-002, M-003, and M-004 should be sampled and monitored only when you are operating the wetlands for nitrogen removal credit.


If you have any questions, please contact me at (951) 782-3284, or contact Gary Stewart of my staff at (951) 782-4379.

Sincerely,

for Gerard Thibeault  
Executive Officer

Enclosure: Revised M&RP R8-2006-0009

California Environmental Protection Agency



## Attachment E – Monitoring and Reporting Program – Amended on June 25, 2007

### Table of Contents

|                                                                                      |           |
|--------------------------------------------------------------------------------------|-----------|
| <b>Attachment E – Monitoring and Reporting Program (MRP)</b>                         | <b>2</b>  |
| <b>I. General Monitoring Provisions</b>                                              | <b>2</b>  |
| A. General Monitoring Provision                                                      | 2         |
| B. Minimum Level (ML) Requirements                                                   | 5         |
| <b>II. Monitoring Locations</b>                                                      | <b>5</b>  |
| <b>III. Influent Monitoring Requirements</b>                                         | <b>6</b>  |
| A. Monitoring Locations at M-INFA through M-INFD                                     | 6         |
| <b>IV. Effluent Monitoring Requirements</b>                                          | <b>7</b>  |
| A. Tertiary Effluent Monitoring Locations M-001A and M-001B                          | 8         |
| B. Tertiary Effluent Monitoring Locations M-002 and M-004                            | 10        |
| C. Tertiary Effluent Monitoring Locations M-003                                      | 10        |
| D. Secondary Effluent Monitoring Locations M-001A and M-001B with 20:1 Dilution      | 11        |
| <b>V. Whole Effluent Toxicity Testing Requirements</b>                               | <b>12</b> |
| A. Toxicity Monitoring Requirements at M-001A                                        | 12        |
| <b>VI. Land Discharge Monitoring Requirements – Not Applicable</b>                   | <b>14</b> |
| <b>VII. Reclamation Monitoring Requirements</b>                                      | <b>14</b> |
| A. Monitoring Locations REC-001, REC-002, REC-003 and REC-004                        | 14        |
| B. Monitoring Location M-001A                                                        | 14        |
| C. Monitoring Users                                                                  | 15        |
| <b>VIII. Receiving Water Monitoring Requirements – Surface Water and Groundwater</b> | <b>15</b> |
| A. Monitoring Location R-001U for Surface Water                                      | 15        |
| B. Monitoring Location R-001D for Surface Water:                                     | 16        |
| C. Monitoring Location R-002 for Surface Water:                                      | 16        |
| D. Groundwater-Not Applicable                                                        | 16        |
| <b>IX. Other Monitoring Requirements</b>                                             | <b>17</b> |
| A. Biosolids Monitoring at B-001                                                     | 17        |
| B. Water Supply Monitoring:                                                          | 17        |
| C. Pretreatment Monitoring and Reporting:                                            | 17        |
| <b>X. Reporting Requirements</b>                                                     | <b>20</b> |
| A. General Monitoring and Reporting Requirements                                     | 20        |
| B. Self Monitoring Reports (SMRs)                                                    | 22        |
| C. Discharge Monitoring Reports (DMRs)                                               | 25        |
| D. Other Reports – Not Applicable                                                    | 25        |

## **ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)**

The Code of Federal Regulations (CFR) at 40 CFR §122.48 requires that all NPDES permits specify monitoring and reporting requirements. CWC sections 13267 and 13383 also authorize the Regional Water Quality Control Board (RWQCB) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements that implement the federal and California regulations.

### **I. GENERAL MONITORING PROVISIONS**

#### **A. General Monitoring Provision**

1. All sampling and sample preservation shall be in accordance with the current edition of *"Standard Methods for the Examination of Water and Wastewater"* (American Public Health Association).
2. All laboratory analyses shall be performed in accordance with test procedures under 40 CFR 136 (revised as of May 14, 1999) "Guidelines Establishing Test Procedures for the Analysis of Pollutants," promulgated by the United States Environmental Protection Agency (EPA), unless otherwise specified in this MRP. In addition, the Regional Water Board and/or EPA, at their discretion, may specify test methods that are more sensitive than those specified in 40 CFR 136. Unless otherwise specified herein, organic pollutants shall be analyzed using EPA method 8260, as appropriate.
3. Chemical, bacteriological, and bioassay analyses shall be conducted at a laboratory certified for such analyses by the California Department of Health Services in accordance with the provision of Water Code Section 13176, and must include quality assurance/quality control data with their reports, or EPA or at laboratories approved by the Regional Water Board's Executive Officer.
4. Whenever the Discharger monitors any pollutant more frequently than is required by this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the discharge monitoring report specified by the Executive Officer.
5. In conformance with federal regulations 40 CFR 122.45(c), analyses to determine compliance with the effluent limitations for metals shall be conducted using the total recoverable method. For Chromium (VI), the dissolved method in conformance with 40 CFR 136 may be used to measure compliance with the Chromium (VI) limitation.

6. For effluent wastewater monitoring:

The Discharger shall require its testing laboratory to calibrate the analytical system down to the minimum level (ML)<sup>1</sup> specified in Attachment "I" for priority pollutants with effluent limitations in this Order, unless an alternative minimum level is approved by the Regional Water Board's Executive Officer. When there is more than one ML value for a given substance, the Discharger shall use the ML values, and their associated analytical methods, listed in Attachment "I" that are below the calculated effluent limitation. The Discharger may select any one of those cited analytical methods for compliance determination. If no ML value is below the effluent limitation, then the lowest ML value and its associated analytical method, listed in Attachment "I" shall be used. Any internal quality control data associated with the sample must be reported when requested by the Executive Officer. The Regional Water Board will reject the quantified laboratory data if quality control data is unavailable or unacceptable.

7. The Discharger shall have, and implement an acceptable written quality assurance (QA) plan for laboratory analyses. Duplicate chemical analyses must be conducted on a minimum of ten percent (10%) of the samples, or at least one sample per month, whichever is greater. A similar frequency shall be maintained for analyzing spiked samples. When requested by the Regional Water Board or EPA, the Discharger will participate in the NPDES discharge monitoring report QA performance study.

8. Monitoring shall be in accordance with the following:

Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

- a) The monitoring and reporting of influent, effluent, and sludge shall be done more frequently as necessary to maintain compliance with this Order and or as specified in this order.
- b) A "grab" sample is defined as any individual sample collected in less than 15 minutes.
- c) A composite sample is defined as a combination of no fewer than eight individual grab samples obtained over the specified sampling period. The volume of each individual grab sample shall be proportional to the discharge flow rate at the time of sampling. The compositing period shall equal the specific sampling period, or 24 hours, if no period is specified.
- d) 24-hour composite samples shall be collected continuously during a 24-hour operation of the facility.

---

<sup>1</sup> Minimum level is the concentration at which the entire analytical system must give a recognizable signal and acceptable point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

- e) Daily samples shall be collected on each day of the week.
- f) Monthly samples shall be collected on any representative day of each month.
- g) Quarterly samples shall be collected by any representative day of January, April, July, and October.
- h) Annual samples shall be collected in accordance with the following schedule:

| Year | Annual Samples |
|------|----------------|
| 2006 | July           |
| 2007 | October        |
| 2008 | January        |
| 2009 | April          |
| 2010 | July           |
| 2011 | April          |

9. The Discharger shall assure that records of all monitoring information are maintained and accessible for a period of at least five years (this retention period supercedes the retention period specified in Section IV.A. of Attachment D) from the date of the sample, report, or application. This period of retention shall be extended during the course of any unresolved litigation regarding this discharge or by the request of the Regional Water Board at any time. Records of monitoring information shall include:
- a) The information listed in Attachment D- IV Standard Provisions – Records, subparagraph B. of this Order;
  - b) The laboratory which performed the analyses;
  - c) The date(s) analyses were performed;
  - d) The individual(s) who performed the analyses;
  - e) The modification(s) to analytical techniques or methods used;
  - f) All sampling and analytical results, including
    - 1) Units of measurement used;
    - 2) Minimum reporting level for the analysis (minimum level, practical quantitation level (PQL));
    - 3) Results less than the reporting level but above the method detection limit (MDL);
    - 4) Data qualifiers and a description of the qualifiers;
    - 5) Quality control test results (and a written copy of the laboratory quality assurance plan);
    - 6) Dilution factors, if used; and
    - 7) Sample matrix type.
  - g) All monitoring equipment calibration and maintenance records;
  - h) All original strip charts from continuous monitoring devices;
  - i) All data used to complete the application for this Order; and,

- j) Copies of all reports required by this Order.
  - k) Electronic data and information generated by the Supervisory Control And Data Acquisition (SCADA) System.
10. The flow measurement system shall be calibrated at least once per year or more frequently, to ensure continued accuracy.
11. All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy. In the event that continuous monitoring equipment is out of service for greater than a 24-hour period, the Discharger shall obtain a representative grab sample each day the equipment is out of service. The Discharger shall correct the cause(s) of failure of the continuous monitoring equipment as soon as practicable. In its monitoring report, the Discharger shall specify the period(s) during which the equipment was out of service and if the problem has not been corrected, shall identify the steps which the Discharger is taking or proposes to take to bring the equipment back into service and the schedule for these actions.

## B. Minimum Level (ML) Requirements

For priority pollutants the methods must meet the lowest minimum levels (MLs) specified in Attachment I of this Order, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board. When there is more than one ML value for a given substance listed in Attachment I – ML Table<sup>2</sup>, the Discharger shall select any one of those cited analytical methods for compliance determination when the associated ML is below the calculated effluent limitation.

If no ML value is below the effluent limitation, then the Discharger shall select as the reporting level (RL), the lowest ML value and its associated analytical method listed in Attachment I.

## II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table 1. Monitoring Station Locations

| Discharge Point Name | Monitoring Location Name | Monitoring Location Description                   | Latitude         | Longitude         |
|----------------------|--------------------------|---------------------------------------------------|------------------|-------------------|
| --                   | M-INF                    | Combined influent monitoring and sampling station | 33° 57' 52.33" N | 117° 27' 13.58" W |

<sup>2</sup> The ML table includes all ML values and their associated analytical methods.

Table 1. Monitoring Station Locations

| Discharge Point Name | Monitoring Location Name | Monitoring Location Description                                                                                                              | Latitude         | Longitude         |
|----------------------|--------------------------|----------------------------------------------------------------------------------------------------------------------------------------------|------------------|-------------------|
| 001                  | M-001A                   | Effluent to Reach 3 of Santa Ana River, close to the end of effluent pipeline                                                                | 33° 57' 48.30" N | 117° 27' 40.95" W |
| 001                  | M-001B                   | At the end of the chlorine contact tank 3 for coliform testing, same monitoring location as REC-001                                          | 33° 57' 42.24" N | 117° 27' 40.98" W |
| 002                  | M-002                    | Effluent to Reach 3 of Santa Ana River, after splitter box                                                                                   | 33° 57' 48.87" N | 117° 28' 35.97" W |
| 003                  | M-003                    | Effluent to Reach 3 of Santa Ana River, at "Flow Meter & Sampler" after 14 wetland ponds                                                     | 33° 57' 48.73" N | 117° 29' 52.95" W |
| 004                  | M-004                    | Effluent commingled with water from Hole Lake channeled to farm field, then to Reach 3 of Santa Ana River, at "Flow Meter" after structure 2 | 33° 57' 44" N    | 117° 29' 7.29" W  |
| 005                  | REC-004                  | Recycled water for Riverside Energy Resource Center                                                                                          | 33° 57' 44.38" N | 117° 27' 32.33" W |
| 006                  | REC-001                  | Recycled water for irrigation of urban forest, at the end of the chlorine contact tank 3                                                     | 33° 57' 42.15" N | 117° 27' 41.49" W |
| 007                  | REC-002                  | Recycled water for irrigation of Golf Course, at the end of the chlorine contact tank 1                                                      | 33° 57' 44.38" N | 117° 27' 32.33" W |
| 008                  | REC-003A                 | Recycled water for irrigation of Toro turf, at the end of the chlorine contact tank 3, same as REC-001                                       | Same as REC-001  | Same as REC-001   |
| 008                  | REC-003B                 | Recycled water for irrigation of Toro turf, at the end of the effluent line, close to M-001A                                                 | 33° 57' 47.25" N | 117° 27' 39.79" W |
| --                   | R-001U                   | Receiving surface water, upstream of Santa Ana River at the Metropolitan Water District pipeline crossing.                                   | 33° 58' 4.53" N  | 117° 26' 52.93" W |
| --                   | R-001D                   | Santa Ana river, downstream of the most downstream point of discharge                                                                        | 33° 57' 29.69" N | 117° 1' 42.75" W  |
| --                   | R-002                    | Santa Ana River                                                                                                                              | --               | --                |
| --                   | B-001                    | Biosolids monitoring at end of dewatering                                                                                                    | 33° 57' 44.24" N | 117° 27' 27.67" W |

### III. INFLUENT MONITORING REQUIREMENTS

#### A. Monitoring Location at M-INF

1. A sampling station shall be established for the point of inflow to the treatment plant. The sampling station shall be located upstream of any in-plant return flows and where representative samples of the influent of the treatment plant can be obtained.

2. The Discharger shall monitor the combined influent into the facility at M-INF as follows:

**Table 2. Influent Monitoring**

| Parameter                                                                                | Units    | Sample Type            | Minimum Sampling Frequency | Required Analytical Test Method                       |
|------------------------------------------------------------------------------------------|----------|------------------------|----------------------------|-------------------------------------------------------|
| Flow                                                                                     | mgd      | Recorder/<br>Totalizer | Continuous                 | --                                                    |
| Specific Conductance                                                                     | µmhos/cm | Recorder               | "                          | See Sections I.A.2., I.A.3. & I.B., above of this MRP |
| pH                                                                                       | pH units | Recorder               | Continuous                 | "                                                     |
| BOD <sub>5</sub>                                                                         | mg/L     | 24-hr Composite        | Weekly                     | "                                                     |
| Suspended Solids                                                                         | "        | "                      | Weekly                     | "                                                     |
| Ammonia-Nitrogen                                                                         | "        | Grab                   | Monthly                    | "                                                     |
| Total Inorganic Nitrogen                                                                 | "        | 24-hr Composite        | "                          | "                                                     |
| Total Dissolved Solids                                                                   | "        | 24-hr Composite        | Monthly                    | "                                                     |
| Boron                                                                                    | "        | "                      | Quarterly                  | "                                                     |
| Chloride                                                                                 | "        | "                      | "                          | "                                                     |
| Fluoride                                                                                 | "        | "                      | "                          | "                                                     |
| Sulfate                                                                                  | "        | "                      | "                          | "                                                     |
| Total Hardness                                                                           | mg/L     | "                      | "                          | "                                                     |
| Arsenic                                                                                  | µg/L     | "                      | "                          | "                                                     |
| Cadmium                                                                                  | "        | "                      | "                          | "                                                     |
| Chromium, VI or Total chromium                                                           | µg/L     | 24-hr Composite        | Quarterly                  | See Sections I.A.2., I.A.3. & I.B., above of this MRP |
| Copper                                                                                   | "        | "                      | "                          | "                                                     |
| Cyanide (Free)                                                                           | µg/L     | Grab                   | Quarterly                  | "                                                     |
| Lead                                                                                     | "        | 24-hr Composite        | "                          | "                                                     |
| Mercury                                                                                  | "        | "                      | "                          | "                                                     |
| Nickel                                                                                   | "        | "                      | "                          | "                                                     |
| Silver                                                                                   | "        | "                      | "                          | "                                                     |
| Zinc                                                                                     | µg/L     | 24-hr Composite        | Quarterly                  | "                                                     |
| Volatile organic portion of EPA Priority Pollutants <sup>3</sup><br>(See Attachment "G") | µg/L     | Grab                   | Annually                   | "                                                     |
| Remaining EPA Priority Pollutants <sup>4</sup><br>(See Attachment "G")                   | µg/L     | 24-hr Composite        | Annually                   | "                                                     |

#### IV. EFFLUENT MONITORING REQUIREMENTS

The Discharger shall monitor tertiary effluent at monitoring locations as follows. If more than one analytical test method is listed for a given parameter, the Discharger may select from the listed methods and associated Reporting Level<sup>5</sup>:

## A. Tertiary Effluent Monitoring Locations M-001A and M-001B

1. The Discharger shall monitor tertiary effluent at monitoring location M-001A as follows:

**Table 3a. Effluent Monitoring at M-001A**

| <u>Parameter</u>                             | <u>Units</u>     | <u>Sample Type</u>     | <u>Minimum Sampling Frequency</u>   | <u>Required Analytical Test Method and Reporting Level as noted herein</u>               |
|----------------------------------------------|------------------|------------------------|-------------------------------------|------------------------------------------------------------------------------------------|
| Flow                                         | mgd              | Recorder/<br>Totalizer | Continuous                          | ---                                                                                      |
| pH                                           | pH units         | "                      | "                                   | See Sections I.A.2., I.A.3. & I.B., above of this MRP                                    |
| Specific Conductance                         | µmhos/cm         | Recorder               | Continuous                          | See Sections I.A.2., I.A.3. & I.B., above of this MRP                                    |
| Total Chlorine Residual                      | mg/L             | "                      | "                                   | "                                                                                        |
| Turbidity                                    | NTU <sup>6</sup> | Recorder/Turbidimeter  | Continuous <sup>7</sup>             | "                                                                                        |
| Ammonia-Nitrogen                             | mg/L             | 24-hr Composite        | Weekly                              | "                                                                                        |
| BOD <sub>5</sub>                             | "                | "                      | "                                   | "                                                                                        |
| Nitrate Nitrogen                             | "                | "                      | "                                   | "                                                                                        |
| Suspended Solids                             | "                | "                      | "                                   | "                                                                                        |
| Temperature                                  | °C               | grab                   | Weekly                              | "                                                                                        |
| Total Dissolved Solids                       | mg/L             | 24-hr Composite        | Monthly                             | "                                                                                        |
| Total Inorganic Nitrogen                     | "                | "                      | "                                   | "                                                                                        |
| Total Hardness                               | "                | "                      | "                                   | "                                                                                        |
| Toxicity Monitoring                          | ----             | See Section V, Below   | Monthly,<br>See Section V,<br>Below | "                                                                                        |
| Cyanide (Free)                               | µg/L             | grab                   | Monthly                             | See Sections I.A.2., I.A.3. & I.B., above of this MRP                                    |
| Chromium (VI) or Total Chromium <sup>8</sup> | "                | 24-hr Composite        | "                                   | See Sections I.A.2., I.A.3. & I.B., above of this MRP and RL 5 µg/L, Total Cr, RL 2 µg/L |

<sup>3</sup> EPA priority pollutants are those remaining volatile organic pollutants listed in Attachment "G" which are not specifically listed in this monitoring program table.

<sup>4</sup> Remaining EPA priority pollutants are those pollutants listed in Attachment "G" which are not volatile organics and pollutants not specifically listed in this monitoring program table.

<sup>5</sup> Reporting Level (RL) Selection: When there is more than one ML value for a given substance, the Regional Water Board shall include as RLs in the permit, all ML values, and their associated analytical methods, listed in Appendix 4 of the SIP that are below the calculated effluent limitation. The Discharger may select any one of those cited analytical methods for compliance determination. If no ML value is below the effluent limitation, then the Regional Water Board shall select as the RL the lowest ML value and its associated analytical method listed in Appendix 4 for inclusion in the permit.

<sup>6</sup> NTU = Nephelometric Turbidity Units

<sup>7</sup> Turbidity analysis shall be continuous, performed by a continuous recording turbidimeter. Compliance with the daily average operating filter effluent turbidity shall be determined by averaging the levels of recorded turbidity taken at a minimum of four-hour intervals over a 24-hour period. The results of the daily average turbidity determinations shall be reported monthly.

<sup>8</sup> Cr(VI) and Hg shall be monitored monthly for one year, if all reported data are "ND" at approved reporting level, the monitoring frequency may be reduced to quarterly with prior approval from the Executive Officer or designee.

**Table 3a. Effluent Monitoring at M-001A**

| <u>Parameter</u>                                                                   | <u>Units</u> | <u>Sample Type</u> | <u>Minimum Sampling Frequency</u> | <u>Required Analytical Test Method and Reporting Level as noted herein</u> |
|------------------------------------------------------------------------------------|--------------|--------------------|-----------------------------------|----------------------------------------------------------------------------|
| Mercury                                                                            | "            | "                  | "                                 | See Sections I.A.2., I.A.3. & I.B., above of this MRP                      |
| Cadmium                                                                            | µg/L         | 24-hr Composite    | Quarterly                         | See Sections I.A.2., I.A.3. & I.B., above of this MRP and RL 0.5 µg/L      |
| Copper                                                                             | "            | "                  | "                                 | See Sections I.A.2., I.A.3. & I.B., above of this MRP and RL 5 µg/L        |
| Lead                                                                               | "            | 24-hr Composite    | "                                 | See Sections I.A.2., I.A.3. & I.B., above of this MRP and RL 5 µg/L        |
| Selenium                                                                           | "            | "                  | "                                 | See Sections I.A.2., I.A.3. & I.B., above of this MRP and RL 2 µg/L        |
| Silver                                                                             | "            | "                  | "                                 | See Sections I.A.2., I.A.3. & I.B., above of this MRP and RL 1 µg/L        |
| Aluminum                                                                           | mg/L         | "                  | Quarterly                         | See Sections I.A.2., I.A.3. & I.B., above of this MRP                      |
| Boron                                                                              | mg/L         | 24-hr Composite    | Quarterly                         | "                                                                          |
| Calcium                                                                            | mg/L         | 24-hr Composite    | Quarterly                         | See Sections I.A.2., I.A.3. & I.B., above of this MRP                      |
| Carbonate                                                                          | "            | "                  | "                                 | "                                                                          |
| Chloride                                                                           | "            | "                  | "                                 | "                                                                          |
| Fluoride                                                                           | "            | "                  | "                                 | "                                                                          |
| Magnesium                                                                          | "            | "                  | "                                 | "                                                                          |
| Manganese                                                                          | "            | "                  | "                                 | "                                                                          |
| Sodium                                                                             | "            | "                  | "                                 | "                                                                          |
| Sulfate                                                                            | "            | "                  | "                                 | "                                                                          |
| Total organic carbon                                                               | "            | "                  | Quarterly                         | "                                                                          |
| Arsenic                                                                            | µg/L         | 24-hr Composite    | Quarterly (See IV.A.3., below)    | "                                                                          |
| Barium                                                                             | "            | "                  | "                                 | "                                                                          |
| Cobalt                                                                             | "            | "                  | "                                 | "                                                                          |
| Iron                                                                               | "            | "                  | "                                 | "                                                                          |
| Nickel                                                                             | "            | "                  | "                                 | "                                                                          |
| Zinc                                                                               | "            | "                  | "                                 | "                                                                          |
| Chloroform                                                                         | µg/L         | Grab               | "                                 | "                                                                          |
| Phenolic Compounds                                                                 | µg/L         | Grab               | Quarterly (See IV. A.3., below)   | "                                                                          |
| Remaining volatile organic portion of EPA Priority Pollutants (See Attachment "G") | "            | "                  | Annually (See IV. A.4., below)    | "                                                                          |
| Remaining EPA Priority Pollutants (See Attachment "G")                             | "            | "                  | Annually (See IV. A.4., below)    | "                                                                          |

2. The Discharger shall monitor tertiary treated effluent at M-001B as follows:

**Table 3b. Effluent Monitoring at M-001B**

| <u>Parameter</u>   | <u>Units</u>                | <u>Sample Type</u> | <u>Minimum Sampling Frequency</u> | <u>Required Test Method</u>                           |
|--------------------|-----------------------------|--------------------|-----------------------------------|-------------------------------------------------------|
| Coliform Organisms | MPN per 100 ml <sup>9</sup> | Grab               | Daily <sup>10</sup>               | See Sections I.A.2., I.A.3. & I.B., above of this MRP |

3. The monitoring frequency for those priority pollutants that are detected during the required quarterly monitoring at a concentration greater than fifty percent of the most stringent applicable receiving water objectives (freshwater or human health (consumption of organisms only) as specified for that pollutant<sup>11</sup> in Attachment J) shall be accelerated to monthly. To return to the monitoring frequency specified, the Discharger shall request and receive approval from the Regional Water Board's Executive Officer or designee.
4. The monitoring frequency for those priority pollutants that are detected during the required annual monitoring at a concentration greater than fifty percent of the most stringent applicable receiving water objectives (freshwater or human health (consumption of organisms only) as specified for that pollutant<sup>12</sup> in 40 CFR 131.38) shall be accelerated to quarterly for one year. To return to the monitoring frequency specified, the Discharger shall request and receive approval from the Regional Water Board's Executive Officer or designee.

#### **B. Tertiary Effluent Monitoring Location M-004**

1. When the Discharger is operating the wetlands for nitrogen removal credit, the Discharger shall monitor tertiary treated effluent at M-004 as follows:

**Table 3c. Effluent Monitoring at M-004**

| <u>Parameter</u> | <u>Units</u> | <u>Sample Type</u> | <u>Minimum Sampling Frequency</u> | <u>Required Test Method</u> |
|------------------|--------------|--------------------|-----------------------------------|-----------------------------|
| Flow             | mgd          | Recorder/Totalizer | Continuous                        | ---                         |

#### **C. Tertiary Effluent Monitoring Locations M-002 and M-003**

1. When the Discharger is operating the wetlands for nitrogen removal credit, the Discharger shall monitor tertiary treated effluent at M-002 and M-003 as follows:

<sup>9</sup> MPN/100mL = Most Probable Number per 100 milliliters

<sup>10</sup> Weekdays excluding holidays

<sup>11</sup> For those priority pollutants without specified criteria values, accelerated monitoring is not required.

<sup>12</sup> For those priority pollutants without specified criteria values, accelerated monitoring is not required.

**Table 3d. Effluent Monitoring at M-002 and M-003**

| <u>Parameter</u>         | <u>Units</u> | <u>Sample Type</u>     | <u>Minimum Sampling Frequency</u> | <u>Required Test Method</u>                              |
|--------------------------|--------------|------------------------|-----------------------------------|----------------------------------------------------------|
| Flow <sup>13</sup>       | mgd          | Recorder/<br>Totalizer | Continuous                        | ---                                                      |
| Total Inorganic Nitrogen | mg/L         | Composite              | Monthly                           | See Sections I.A.2., I.A.3. & I.B.,<br>above of this MRP |

**D. Secondary Effluent Monitoring Locations M-001A and M-001B with 20:1 Dilution**

1. The Discharger shall monitor secondary treated effluent at M-001A when 20:1 dilution is provided by the Santa Ana River at the time of the discharge, as follows:

**Table 3e. Secondary Effluent Monitoring at M-001A with 20:1 Dilution**

| <u>Parameter</u>        | <u>Units</u> | <u>Sample Type</u>     | <u>Minimum Sampling Frequency</u> | <u>Required Test Method</u>                              |
|-------------------------|--------------|------------------------|-----------------------------------|----------------------------------------------------------|
| Flow                    | mgd          | Recorder/<br>Totalizer | Continuous                        | --                                                       |
| pH                      | pH units     | Grab                   | Daily                             | See Sections I.A.2., I.A.3. & I.B.,<br>above of this MRP |
| Suspended Solids        | mg/L         | "                      | "                                 | "                                                        |
| BOD <sub>5</sub>        | "            | "                      | "                                 | "                                                        |
| Total Chlorine Residual | "            | "                      | "                                 | "                                                        |

2. The Discharger shall monitor secondary treated effluent at M-001B when 20:1 dilution is provided by the Santa Ana River at the time of the discharge, as follows:

**Table 3f. Secondary Effluent Monitoring at M-001B with 20:1 Dilution**

| <u>Parameter</u>   | <u>Units</u>                    | <u>Sample Type</u> | <u>Minimum Sampling Frequency</u> | <u>Required Test Method</u>                              |
|--------------------|---------------------------------|--------------------|-----------------------------------|----------------------------------------------------------|
| Coliform Organisms | MPN per<br>100 ml <sup>14</sup> | Grab               | Daily <sup>15</sup>               | See Sections I.A.2., I.A.3. & I.B.,<br>above of this MRP |

<sup>13</sup> Flow may be measured at M-004

<sup>14</sup> MPN/100mL = Most Probable Number per 100 milliliters

<sup>15</sup> Weekdays excluding holidays

## **V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS**

### **A. Toxicity Monitoring Requirements at M-002**

1. The Discharger shall conduct critical life stage chronic toxicity testing in accordance with Method 1002.0 - Survival and Reproduction test for water flea, *Ceriodaphnia dubia* as specified in "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms", Fourth Edition, Environmental Monitoring Systems Laboratory, U.S. Environmental Protection Agency 2002, Cincinnati, Ohio (October 2002, EPA-821-R-02-013).
2. The Discharger shall establish procedures to ensure that the toxicity testing laboratory notifies the Discharger of the results of toxicity testing by the end of the next business day following the completion of such tests.
3. A minimum of one monthly chronic toxicity test shall be conducted on 24-hour composite samples. A grab sample taken at peak flow may be substituted for a composite sample when the M-002 site is not available and the Van Buren sample site is used.
4. The Discharger shall increase the frequency of chronic toxicity testing to, at a minimum of every two weeks whenever any test result exceeds 1.0 TUC. The first test under the accelerated schedule shall be conducted within two weeks of receiving notice of the test that exceeds 1.0 TUC, and every two weeks thereafter. The Discharger may resume the regular test schedule when two consecutive chronic toxicity tests result in 1.0 TUC, or when the results of the Initial Investigation Reduction Evaluation conducted by the Discharger have adequately addressed the identified toxicity problem.
5. The presence of chronic toxicity shall be estimated as specified in Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms. Fourth Edition. EPA-821-R-02-013.
6. Results for both survival and reproduction endpoints shall be reported in TUC, where  $TUC = 100/NOEC$  or  $100/IC_p$  or  $EC_p$  (p is the percent effluent). The no observed effect concentration (NOEC) is the highest concentration of toxicant to which organisms are exposed in a chronic test, that causes no observable adverse effect on the tests organisms (e.g., the highest concentration of toxicant to which the values for the observed responses are not statistically significant different from the controls). The inhibition concentration (IC) is a point estimate of the toxicant concentration that causes a given percent reduction in a non-quantal biological measurement (e.g., reproduction or growth) calculated from a continuous model (the EPA Interpolation Method). The effective concentration (EC) is a point estimate of the toxicant concentration that would cause a given percent reduction in quantal biological measurement (e.g., larval development, survival) calculated from a continuous model (e.g., probit).

7. Additional Testing Requirements.

- a. A series of at least five dilutions and a control will be tested. Five dilutions of the series shall be within 60% to 100% effluent concentration.
- b. If organisms are not cultured in-house, concurrent testing with reference toxicants shall be conducted. Where organisms are cultured in-house, monthly reference toxicant testing is sufficient. Reference toxicants shall also be conducted using the same test conditions as the effluent toxicity test (e.g., same test duration, etc).
- c. If either of the reference toxicant test or the effluent tests do not meet all test acceptability criteria as specified in the manual<sup>16</sup>, then the Discharger must re-sample and re-test within 14 days or as soon as the Discharger receives notification of failed tests.
- d. Control and dilution water should be receiving water or lab water. If the dilution water used is different from the culture water, a second control, using culture water shall also be used.

8. Quality Assurance/Control:

- a. A quality assurance/quality control (QA/QC) program shall be instituted to verify the results of the effluent toxicity-monitoring program. The QA/QC program shall include but shall not be limited to the following: (1) Selection of an independent testing laboratory; (2) Approval by the Regional Board's Executive Officer or Executive Officer's designee of the independent testing laboratory; (3) Once during the year, the Discharger shall split samples with the independent laboratory for conducting chronic toxicity testing; (4) Results from the independent laboratory shall be submitted to the Regional Board and the Discharger for evaluation; (5) The Discharger shall review the test acceptability criteria in accordance with the EPA test protocols, EPA-821-R-02-013.
  - b. Results from the independent laboratory of the annual QA/QC split samples are to be used for Quality Assurance/Quality Control (QA/QC) purposes only and not for purposes of determining compliance with other requirements of this Order.
9. The use of alternative methods for measuring chronic toxicity may be considered by the Executive Officer on a case-by-case basis. The use of a different test species, in lieu of conducting the required test species may be considered/approved by the Executive Officer on a case-by case basis upon submittal of the documentation supporting Discharger's determination that a different species is more sensitive and appropriate.

---

<sup>16</sup> Refers to USEPA Manual "Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms. Fourth Edition. EPA-821-R-02-013.

10. Reporting: Results of all toxicity testing conducted within the month following the reporting period shall be submitted monthly in accordance with "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms", third edition, Environmental Monitoring Systems Laboratory, U.S. Environmental Protection Agency 2002, Cincinnati, Ohio (October 2002, EPA-821-R-02-013). The report shall include a determination of the median value of all chronic toxicity testing results conducted during the two previous months.
11. Whenever an Initial Investigation Reduction Evaluation is conducted, the results of the evaluation shall be submitted upon completion. In addition, monthly status reports shall be submitted as part of the Discharger's monitoring report.

## **VI. LAND DISCHARGE MONITORING REQUIREMENTS – Not Applicable**

## **VII. RECLAMATION MONITORING REQUIREMENTS**

### **A. Monitoring Locations REC-001, REC-002, REC-003 and REC-004**

The Discharger shall monitor recycled wastewater at REC-001, REC-002, REC-003 and REC-004

**Table 4a. Reclaimed Water Monitoring at REC-001, REC-002, REC-003 and REC-004**

| Parameter          | Units          | Sample Type        | Minimum Sampling & Testing Frequency | Required Analytical Test Method                       |
|--------------------|----------------|--------------------|--------------------------------------|-------------------------------------------------------|
| Flow               | mgd            | Recorder/Totalizer | Continuous                           | ---                                                   |
| Coliform Organisms | MPN per 100 ml | Grab               | Daily <sup>17</sup>                  | See Sections I.A.2., I.A.3. & I.B., above of this MRP |

### **B. Monitoring Location M-001A**

The Discharger shall monitor recycled wastewater at M-001A for REC-001, REC-002, and REC-003

<sup>17</sup> Weekdays excluding holidays – Coliform for REC-002 and REC-004 is measured in chlorine contact basin #1, Coliform for REC-001 and REC-003 is measured at M-001B.

**Table 4b. Reclaimed Water Monitoring at M-001A**

| Parameter                | Units    | Sample Type     | Minimum Sampling & Testing Frequency | Required Analytical Test Method                       |
|--------------------------|----------|-----------------|--------------------------------------|-------------------------------------------------------|
| BOD <sub>5</sub>         | mgd      | 24-hr composite | Monthly                              | See Sections I.A.2., I.A.3. & I.B., above of this MRP |
| Suspended Solids         | mg/L     | 24-hr composite | Monthly                              | "                                                     |
| Total Inorganic Nitrogen | mg/L     | 24-hr composite | Monthly                              | "                                                     |
| pH                       | pH units | Grab            | Monthly                              | "                                                     |

### C. Monitoring Users

Whenever recycled water is supplied to a user, the Discharger shall record on a permanent log: the volume of recycled water supplied; the user of recycled water; the locations of those sites including the names of the groundwater management zones underlying the recycled water use sites; type of use (e.g. irrigation, industrial, etc); and the dates at which water is supplied. The Discharger shall submit annually a summary report of the recorded information by groundwater management zone.

## VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER AND GROUNDWATER

### A. Monitoring Location R-001U for Surface Water

1. The Discharger shall make measurement of the receiving water flow at R-001U in the Santa Ana River and determine whether a 20:1 dilution exists at the point of discharge before discharging secondary treated effluent. A dilution of 20:1 or more is required at the point of discharge. Flow measurements shall be made prior to any direct discharge to the river and shall continue on a daily basis until the discharge is terminated. By June 1, 2006, the Discharger shall submit for approval by the Executive Officer a proposed plan for measuring the receiving water flow at R-001U in the Santa Ana River. The proposed plan can be included in the report required in Section VI.C.2.b. of the Order and shall be implemented upon approval.

2. The Discharger shall monitor receiving water at R-001U as follows:

**Table 5a. Receiving Water Monitoring at R-001U**

| Parameter               | Units   | Sample Type | Minimum Sampling & Testing Frequency | Required Analytical Test Method                       |
|-------------------------|---------|-------------|--------------------------------------|-------------------------------------------------------|
| Dissolved Oxygen        | mg/L    | Grab        | Weekly                               | See Sections I.A.2., I.A.3. & I.B., above of this MRP |
| Temperature             | °C      | "           | "                                    | "                                                     |
| pH                      | pH unit | Grab        | "                                    | "                                                     |
| EPA Priority Pollutants | µg/L    | "           | Annually                             | "                                                     |

**B. Monitoring Location R-001D for Surface Water:**

1. The Discharger shall monitor receiving water at R-001D as follows:

**Table 5b. Receiving Water Monitoring at R-001D**

| Parameter                                        | Units   | Sample Type | Minimum Sampling & Testing Frequency | Required Analytical Test Method                       |
|--------------------------------------------------|---------|-------------|--------------------------------------|-------------------------------------------------------|
| Dissolved Oxygen                                 | mg/L    | Grab        | Weekly                               | See Sections I.A.2., I.A.3. & I.B., above of this MRP |
| Temperature                                      | °C      | "           | "                                    | "                                                     |
| pH                                               | pH unit | Grab        | "                                    | "                                                     |
| Color change, foam, deposition of material, odor | --      | observe     | Weekly                               | "                                                     |

**C. Monitoring Location R-002 for Surface Water:**

Unless otherwise directed by the Regional Water Board Executive Officer, the Discharger shall implement the approved plan for the annual sampling and testing of mercury levels in fish flesh samples collected from the Santa Ana River. The frequency of monitoring and submission of reports shall be as stipulated in the approved plan.

**D. Groundwater-Not Applicable**

## IX. OTHER MONITORING REQUIREMENTS

### A. Biosolids Monitoring at B-001

1. Biosolids monitoring shall be conducted as follows:

**Table 6. Biosolids Monitoring at B-001**

| Parameter                  | Units | Sample Type                     | Minimum Sampling & Testing Frequency | Required Analytical Test Method                       |
|----------------------------|-------|---------------------------------|--------------------------------------|-------------------------------------------------------|
| Priority Pollutants        | mg/kg | A composite of six grab samples | Semi-annually                        | See Sections I.A.2., I.A.3. & I.B., above of this MRP |
| Moisture Content (% solid) | mg/kg | Grab                            | quarterly                            | "                                                     |

2. The Discharger shall maintain a permanent log of solids hauled away from the treatment facilities for use/disposal elsewhere, including the date hauled, the volume or weight (in dry tons), type (screening, grit, raw sludge, biosolids), application (agricultural, composting, etc), and destination. This information shall be reported semi-annually.

### B. Water Supply Monitoring:

1. A sample of each source of the water supplied to the sewered area shall be obtained at least annually and analyzed for total dissolved solids concentration expressed in "mg/L".
2. Monthly reports shall be submitted stating the amount (in percentage or acre-feet) supplied to the sewered area from each source of water and the resulting flow-weighted water supply quality for total dissolved solids.

### C. Pretreatment Monitoring and Reporting:

1. The Discharger shall submit to the Regional Water Board and the EPA Region 9, a quarterly compliance status report. The quarterly compliance status reports shall cover the periods January 1 - March 31, April 1 - June 30, July 1 - September 30, and October 1 - December 31. Each report shall be submitted by the end of the month following the quarter, except that the report for October 1 - December 31 may be included in the annual report. This quarterly reporting requirement shall commence for the first full quarter following issuance of this Order. The reports shall identify:
  - a. All significant industrial users (SIUs) which violated any standards or reporting requirements during that quarter;
  - b. The violations committed (distinguish between categorical and local limits);
  - c. The enforcement actions undertaken; and

- d. The status of active enforcement actions from previous periods, including closeouts (facilities under previous enforcement actions which attained compliance during the quarter).
2. Annually, the Discharger shall submit a report to the Regional Water Board, the State Water Resources Control Board and the EPA Region 9 describing the pretreatment activities within the service area during the previous year. In the event that any control authority within the service area is not in compliance with any conditions or requirements of this Order or their approved pretreatment program (such as due to industrial user discharges, interjurisdictional agency agreement implementation issues, or other causes,) then the Discharger shall also include the reasons for non-compliance and state how and when the Discharger and the control authority shall comply with such conditions and requirements. This annual report shall cover operations from January 1 through December 31 of each fiscal year and is due on April 1 of each year. The report shall contain, but not be limited to, the following information:
    - a. A summary of analytical results from representative, flow-proportioned, 24-hour composite sampling of the POTW's influent and effluent wastewaters for those pollutants which are known or suspected to be discharged by industrial users (IUs) as identified by EPA under Section 307(a) of the CWA. The summary will include the result of annual full priority pollutant scan, with quarterly samples analyzed only for those pollutants<sup>18</sup> detected in the full scan. The Discharger shall also provide any influent or effluent monitoring data for non-priority pollutants which the Discharger believes may be causing or contributing to Interference, Pass Through or adversely impacting sludge quality. Sampling and analysis shall be performed in accordance with the techniques prescribed in 40 CFR 136 and amendments thereto.
    - b. A discussion of any upset, interference, or pass-through incidents at the treatment plant (if any), which the Discharger knows or suspects were caused by IUs of the POTW system. The discussion shall include the following:
      - 1) The reasons why the incidents occurred, the corrective actions taken, and, if known, the name and address of the IU(s) responsible.
      - 2) A review of the applicable pollutant limitations to determine whether any additional limitations, or changes to existing requirements, may be necessary to prevent pass through, interference or noncompliance with sludge disposal requirements.
    - c. A complete and updated list of the Discharger's significant industrial users (SIUs), including names, North American Industry Classification System (NAICS) and addresses, and a list of any SIU deletions and/or additions. The Discharger shall provide a brief explanation for each deletion. The SIU list shall identify the SIUs subject to Federal Categorical Standards by specifying which set(s) of standards are applicable to each SIU. The list shall also indicate which SIUs are subject to local limitations more stringent than Federal Categorical Standards and those, which are not subject to local limits.

---

<sup>18</sup> *The Discharger is not required to analyze for asbestos.*

- d. A list or table characterizing the industrial compliance status of each SIU, including:
  - 1) SIU name;
  - 2) Industrial category;
  - 3) The type (processes) of wastewater treatment in place;
  - 4) Number of samples taken by the POTW during the year;
  - 5) Number of samples taken by the SIU during the year;
  - 6) Whether all needed certifications (if allowed) were provided by SIUs which have limits for total toxic organics;
  - 7) Federal and Regional Standards violated during the year, reported separately;
  - 8) Whether the SIU at any time in the year was in Significant Noncompliance (SNC)<sup>19</sup>, as defined by 40 CFR 403.12 (f)(2)(vii); and
  - 9) A summary of enforcement actions against the SIU taken during the year, including the type of action, final compliance date, and amount of fines assessed/collected (if any). Proposed actions, if known, should be included.
  - 10) Number of inspections conducted at each SIU during the year.
- e. A compliance summary table which includes:
  - 1) SIU's which were in SNC at any time during the year;
  - 2) The total number of SIUs which are in SNC with pretreatment compliance schedules during the year;
  - 3) The total number of notices of violation and administrative orders issued against SIUs during the year;
  - 4) The total number of civil and criminal judicial actions filed against SIUs during the year;
  - 5) The number of SIUs which were published as being in SNC during the year; and
  - 6) The number of IUs from which penalties were collected during the year.
- f. A short description of any significant changes in operating the pretreatment program which differ from the previous year including, but not limited to changes concerning:
  - 1) The program's administrative structure;
  - 2) Local industrial discharge limitations;
  - 3) Monitoring program or monitoring frequencies;
  - 4) Legal authority or enforcement policy;
  - 5) Funding mechanisms; and
  - 6) Resource requirements and/or staffing levels.
- g. A summary of the annual pretreatment budget, including the cost of pretreatment program functions and equipment purchases.
- h. A summary of public participation activities to involve and inform the public.

---

<sup>19</sup> SNC is determined at the beginning of each quarter based on data of the previous six months.

- i. A description of any changes in sludge disposal methods and a discussion of any concerns not described elsewhere in the report.
3. The cumulative number of industrial users that the Discharger has notified regarding Baseline Monitoring Reports and the cumulative number of industrial user responses.
4. The Discharger shall submit the quarterly compliance status reports and the annual pretreatment report to EPA Region 9, the State Board and the Regional Water Board.

## **X. REPORTING REQUIREMENTS**

### **A. General Monitoring and Reporting Requirements**

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. All analytical data shall be reported with method detection limit<sup>20</sup> (MDLs) and with identification of either reporting level, practical quantitation levels (PQLs<sup>21</sup>) or limits of quantitation (LOQs).
3. Laboratory data for effluent samples must quantify each constituent down to the PQLs specified in Attachment "H" for non-priority pollutants and down to the MLs specified in Attachment "I" for priority pollutants. Any internal quality control data associated with the sample must be reported when requested by the Executive Officer. The Regional Water Board will reject the quantified laboratory data if quality control data are unavailable or unacceptable.
4. Discharge monitoring data shall be submitted in a format acceptable by the Regional Water Board. Specific reporting format may include preprinted forms and/or electronic media. The results of all monitoring required by this Order shall be reported to the Regional Water Board, and shall be submitted in such a format as to allow direct comparison with the limitations and requirements of this order.
5. The Discharger shall tabulate the monitoring data to clearly illustrate compliance and/or noncompliance with the requirements of the Order.
6. The Discharger shall submit to the Regional Water Board reports necessary to determine compliance with effluent limitations in this Order and shall follow the chemical nomenclature and sequential order of priority pollutant constituents shown in Attachment "G" – Priority Pollutant Lists. The Discharger shall report with each sample result:

---

<sup>20</sup> The standardized test procedure to be used to determine the method detection limit (MDL) is given at Appendix B, "Definition and Procedure for the Determination of the Method Detection Limit" of 40 CFR 136.

<sup>21</sup> PQL is the lowest concentration of a substance that can be determined within  $\pm 20$  percent of the true concentration by 75 percent of the analytical laboratories tested in a performance evaluation study. Alternatively, if performance data are not available, the PQL is the method detection limit (MDL)  $\times 5$  for carcinogens and MDL  $\times 10$  for noncarcinogens.

- a) The reporting level achieved by the testing laboratory; and
  - b) The laboratory's current MDL, as determined by the procedure found in 40 CFR 136 (revised as of May 14, 1999).
  - c) For receiving water monitoring and for those priority pollutants without effluent limitations, the Discharger shall require its testing laboratory to quantify constituent concentrations to the lowest achievable MDL as determined by the procedure found in 40 CFR 136 (revised as of May 14, 1999). In situations where the most stringent applicable receiving water objective (freshwater or human health (consumption of organisms only), as specified for that pollutant in 40 CFR 131.38<sup>22</sup> is below the minimum level value specified in Attachment "I" and the Discharger cannot achieve an MDL value for that pollutant below the ML value, the Discharger shall submit justification why a lower MDL value cannot be achieved. Justification shall be submitted together with monthly monitoring reports.
7. For non-priority pollutants monitoring, all analytical data shall be reported with identification of practical quantitation levels and with method detection limits, as determined by the procedure found in 40 CFR 136 (revised as of May 14, 1999).
  8. For every item of monitoring data where the requirements are not met, the monitoring report shall include a statement discussing the reasons for noncompliance, and of the actions undertaken or proposed which will bring the discharge into full compliance with requirements at the earliest time, and an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Regional Water Board by letter when compliance with the time schedule has been achieved.
  9. The monthly reports for June and December shall include a roster of plant personnel, including job titles, duties, and level of State certification for each individual.
  10. At any time during the term of this Order when electronic submittal of monitoring reports has become the norm, the State or Regional Water Board may notify the Discharger to discontinue submittal of hard copies of reports. When such notification is given, the Discharger shall stop submitting hard copies of required monitoring reports.
  11. The Discharger shall report monitoring results for specific parameters in accordance with the following table:

**Table 7. Reporting Requirements**

| Parameter               | Measurement              |
|-------------------------|--------------------------|
| Flow                    | Daily total flow         |
| pH                      | Daily high and daily low |
| Total Chlorine Residual | Daily Maximum            |
| Electrical Conductivity | Daily High               |
| Turbidity               | Daily maximum            |

<sup>22</sup> See Federal Register/ Vol. 65, No. 97 / Thursday, May 18, 2000 / Rules and Regulations.

12. The Discharger shall file a written report with the Regional Board within ninety (90) days after the average dry-weather waste flow for any month equals or exceeds 75 percent of the design capacity of the waste treatment and/or disposal facilities. The Discharger's senior administrative officer shall sign a letter that which transmits that report and certifies that the policy making body is adequately informed about it. The report shall include:
  - a. Average daily flow for the month, the date on which the instantaneous peak flow occurred, the rate of that peak flow, and the total flow for the day.
  - b. The Discharger's best estimate of when the average daily dry-weather flow rate will equal or exceed the design capacity of the treatment facilities.
  - c. The Discharger's intended schedule for studies, design, and other steps needed to provide additional capacity for the waste treatment and/or disposal facilities before the waste flow rate equals the capacity of present units.

#### **B. Self Monitoring Reports (SMRs)**

1. At any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit Self-Monitoring Reports (SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit hard copy SMRs in accordance with the requirements described in subsection B.5 below. The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. The Discharger shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. Additionally, the Discharger shall report in the SMR the results of any special studies, acute and chronic toxicity testing, TRE/TIE, PMP, and Pollution Prevention Plan required by Special Provisions – VI.C. list of this Order. The Discharger shall submit monthly, quarterly, and annual SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. If the Discharger monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

**Table 8. Monitoring and Reporting Schedule**

| Sampling Frequency | Monitoring Period Begins On | Monitoring Period                                                                                                     | SMR Due Date                                                           |
|--------------------|-----------------------------|-----------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------|
| Continuous         | April 21, 2006              | All                                                                                                                   | Submit with monthly SMR                                                |
| Daily              | April 21, 2006              | (Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling. | Submit with monthly SMR                                                |
| Weekly             | April 21, 2006              | Sunday through Saturday                                                                                               | Submit with monthly SMR                                                |
| Monthly            | May 1, 2006                 | 1 <sup>st</sup> day of calendar month through last day of calendar month                                              | 30 days from the end of the monitoring period, submit as monthly SMR   |
| Quarterly          | May 1, 2006                 | January 1 through March 31<br>April 1 through June 30<br>July 1 through September 30<br>October 1 through December 31 | 30 days from the end of the monitoring period, submit with monthly SMR |
| Semiannually       | July 1, 2006                | January 1 through June 30<br>July 1 through December 31                                                               | 30 days from the end of the monitoring period, submit with monthly SMR |
| Annually           | March 1, 2006               | January 1 through December 31                                                                                         | 30 days from the end of the monitoring period, submit with monthly SMR |

4. Reporting Protocols. The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current Method Detection Limit (MDL), as determined by the procedure in 40 CFR Part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration<sup>23</sup> of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy ( $\pm$  a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.

<sup>23</sup> See definition in Attachment "A"

- d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from *extrapolation* beyond the lowest point of the calibration curve.
5. The Discharger shall submit SMRs (with an original signature) when required by subsection B.1 above in accordance with the following requirements:
  - a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment.
  - b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
  - c. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the address listed below:

California Regional Water Quality Control Board  
Santa Ana Region  
3737 Main Street, Suite 500  
Riverside, CA 92501-3348

6. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and identify the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
7. By April 1 of each year, the Discharger shall submit an annual report to the Regional Water Board. The annual report shall include the following:
  - a. Tabular and graphical summaries of the monitoring data obtained during the previous year;
  - b. A discussion of the compliance record and the corrective actions taken or planned, which may be needed to bring the discharge into full compliance with the waste discharge requirements;
  - c. A summary of the quality assurance (QA) activities for the previous year; and

- d. For priority pollutant constituents that do not have effluent limitations but are required to be monitored, the Discharger shall evaluate the monitoring data obtained during the previous year and determine whether detected constituents are at levels that would warrant reopening the permit to include effluent limitations for such constituent(s). To conduct this evaluation, the concentration of detected constituents shall be compared to the most stringent applicable receiving water objectives (freshwater or human health (consumption of organisms only) as specified for that pollutant<sup>24</sup> in 40 CFR 131.38<sup>25</sup>). For metals and selenium, site-specific translators approved by the Regional Board may be applied in this evaluation. The Discharger shall include a discussion of the corrective actions taken or planned to address values above receiving water objectives.

### **C. Discharge Monitoring Reports (DMRs)**

1. As described in Section X.B.1 above, at any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.
2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharger shall submit the original DMR and one copy of the DMR to the address listed below:

State Water Resources Control Board  
Discharge Monitoring Report Processing Center  
Post Office Box 671  
Sacramento, CA 95812

3. All discharge-monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated or modified cannot be accepted.

Regional Administrator  
U. S. Environmental Protection Agency  
Region 9 – Attention WTR – 7  
75 Hawthorne Street  
San Francisco, CA 94105

### **D. Other Reports – Not Applicable**

---

<sup>24</sup> For those priority pollutants without specified criteria values, accelerated monitoring is not required.

<sup>25</sup> See Federal Register/ Vol. 65, No. 97 / Thursday, May 18, 2000 / Rules and Regulations