
Central Valley Regional Water Quality Control Board

3 June 2025

WDID: 5A04NC00082

Glen Sturdevant
Sewerage Commission – Oroville Region
Oroville WWTP
P.O. Box 1350
Oroville, CA 95965

CERTIFIED MAIL:
7019 0700 0002 1109 1460

NOTICE OF APPLICABILITY, WATER QUALITY ORDER 2003-0003-DWQ-0260, STATEWIDE WASTE DISCHARGE REQUIREMENTS FOR DISCHARGES TO LAND WITH A LOW THREAT TO WATER, OROVILLE WASTEWATER TREATMENT PLANT CONSTRUCTION DEWATERING PROJECT, OROVILLE, BUTTE COUNTY

On 12 May 2025 Robert Barton of Myers & Sons Construction, LLC submitted a Notice of Intent (NOI) on behalf of Sewerage Commission – Oroville Region to obtain coverage under Water Quality Order 2003-0003-DWQ, *Statewide General Waste Discharge Requirements for Discharges to Land with a Low Threat to Water Quality* (hereafter General Order) for construction dewatering discharge for the above referenced project. The submittal contains all information required to evaluate applicability of the General Order. This letter serves as formal notice that the General Order is applicable to the Oroville Wastewater Treatment Plant (Facility) and the dewatering of the construction project as described below. You are hereby assigned the following General Order enrollment number, 2003-0003-DWQ-0260 for the Oroville Wastewater Treatment Plant (WWTP) Construction Dewatering Project (Project). Please include this number on all correspondence related to this discharge.

You should familiarize yourself with the entire General Order and its attachments enclosed with this letter. Your enrollment into this General Order shall continue until the Central Valley Water Quality Control Board (Central Valley Water Board) receives an official written request for termination.

PROJECT LOCATION AND DESCRIPTION

The Project is located at the Oroville WWTP, 2880 S. 5th St, Oroville, Butte County more specifically near the current water clarifiers. Construction operations are to start in mid-2025 and are expected to be completed in late 2026, though dewatering efforts are expected to cease around December 2025. The project proposes the construction of an additional secondary clarifier and also a mixed liquor distribution box. During the construction and or installing of new improvements at the Facility, groundwater will likely

be encountered and dewatering will be required to complete excavations and installation of site improvements. The dewatering will be accomplished by installation of a series of wells constructed as needed in the vicinity of excavations at the site. It is proposed that thirteen (13) wells in total will be needed, nine (9) for the secondary clarifier and four (4) for the mixed liquor distribution box. These wells will pump ground water to depress the water table in the construction areas to allow for excavation and or installation of proposed improvements.

The site dewatering will occur sporadically with concurrent construction phases of the project. Water removed from construction sites will be pumped from wells and either discharged into the WWTP, if sufficient capacity is available or, it will be land applied to areas to the south of the construction site onto and to remain on the Facilities property with no runoff onto neighboring properties. The maximum daily discharge volume is estimated at 2.304 MGD but discharge amounts will likely be much less than this. The Discharge Monitoring Plan submitted by the contractor proposes that daily monitoring of the dewatering infrastructure will occur and will be monitored to confirm that there are no contaminants (i.e. visible pollutants, such as oils, grease, sheens, discoloration or signs of contact with concrete) in waters discharged to either the WWTP or the land application area. If pollutants are observed, pumping shall cease until the source of the pollution can be addressed. If cement contact occurs, the Contractor shall measure the pH of the water. If pollutants are found to be present after sampling and testing those waters will be collected in Baker tanks for treatment prior to discharge to the prescribed methods in the submitted Discharge Monitoring Plan.

The Water Quality Control Plan for the Sacramento River and San Joaquin River Basins, Fifth Editions, revised May 2018 (hereafter Basin Plan), designates beneficial uses, establishes water quality objectives, contains implementation plans and policies for protecting waters of the basin, and incorporates by reference plans and policies adopted by the State Water Resources Control Board. Pursuant to §13263(a) of the California Water Code (CWC), waste discharge requirements must implement the Basin Plan.

FACILITY SPECIFIC REQUIREMENTS

The General Order and this Notice of Applicability regulates construction dewatering for the Oroville WWTP Construction Dewatering Project.

1. Water generated during construction dewatering shall be disposed of as described in the Notice of Intent and in accordance with the requirements contained in the General Order.
2. Construction dewatering discharge at a location or in a manner different from that described in the Notice of Intent or this Notice of Applicability is prohibited.

3. All technical reports required herein that involve evaluation, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code, section 6735, 7835, and 7835.1. As required by these laws, completed technical reports must bear the signature(s) and seal(s) of the registered professional(s) in a manner such that all work can be clearly attributed to the professional responsible for the work.
4. Monitoring results shall be submitted on a semi-annual basis in accordance with the General Order's Monitoring and Reporting Program. For the January through June reporting period, the monitoring report is due August 15. For the July through December reporting period, the monitoring report is due February 15. The report is due even if sampling is not performed (note the reason, i.e. dewatering was not performed) or the report will be deemed deficient.
5. The Discharger shall submit the required annual fee (as specified in the annual billing issued by the State Water Resources Control Board) until the Notice of Applicability is officially terminated.
6. Failure to abide by the conditions of the General Order, including its monitoring and reporting requirements, and this letter authorizing applicability could result in enforcement actions, as authorized by provisions of the California Water Code.

Facility Information

Facility Name	Oroville WWTP Construction Dewatering Project
Contact	Robert Barton
Program	WDR
Order Number	2003-0003-DWQ-0260
WDID	5A04NC00082
Flow Total	2.304 million gallons per day maximum estimate

Billing Information

Name	Sewerage Commission – Oroville Region
Contact	Glen Sturdevant
Email	gsturdevant@sc-or.org
Address	PO Box 1350, Oroville, CA, 95965
Phone	(530)534-0353

The Central Valley Water Board has gone to a Paperless Office System. All regulatory documents, MRPs, submissions, materials, data, monitoring reports, and correspondence should be converted to a searchable Portable Document Format (PDF)

and submitted electronically. Documents that are less than 50MB should be emailed to:
centralvalleyredding@waterboards.ca.gov.

Documents that are 50MB or larger should be transferred to a disc and mailed to the appropriate regional water board office, in this case 364 Knollcrest Drive, Suite 205, Redding, CA 96002. To ensure that your submittals are routed to the appropriate staff, the following information block should be included in any email used to transmit documents to this office.

Program: WDR

WDID: 5A04NC00082

Facility Name:

Order: 2003-0003-DWQ-0245

Oroville WWTP Construction Dewatering Project

If you have any questions regarding submitting an updated report of waste discharge, making changes to your permitted operations, compliance or enforcement please contact Josh Smith at (530) 224-4205, Joshua.Smith@waterboards.ca.gov, or the footer address.

For PATRICK PULUPA
Executive Officer

JS: cc

Enclosure: GO 2003-0003-DWQ

cc electronically
w/ enclosure:

Robert Barton, Myers & Sons Construction, Sacramento
Robin Tully, Tully Consulting Group, Dixon

cc electronically
w/out enclosure:

Butte County Environmental Health, Oroville
State Water Board, Sacramento
Christopher Moskal, SWRCB, OCC, Sacramento