

Attachment 1 - Summary of System Specific General Order¹

General Order Section	Initial Page	Numeric Limitation	Requirement (refer to General Order for details)
-----------------------	--------------	--------------------	--

A. PROHIBITIONS

A.1-A.11	15	--	Prohibitions
----------	----	----	--------------

B. REQUIREMENTS BY WASTEWATER SYSTEM TYPE

B.1.a-B.1.i	16	--	All Wastewater Systems
B.1.a	16	210 gpd	Wastewater Flow Limit
B.3.a-B.3.g	21	--	Aerobic Treatment Systems
B.7.a-B.7.h	26	--	Land Application and/or Recycled Water Systems
B.8.a-B.8.f	26	--	Sludge/Solids/Biosolids Disposal

C. GROUNDWATER AND SURFACE WATER LIMITATIONS

C.1	27	--	Groundwater and Surface Water Limitations
-----	----	----	---

D. EFFLUENT LIMITATIONS

D.1.a	27	30 mg/l	Biochemical Oxygen Demand (BOD) monthly average
D.1.a	27	45 mg/l	BOD 7-day average
D.1.a	27	30 mg/l	Total Suspended Solids (TSS), monthly average
D.1.a	27	45 mg/l	TSS 7-day average

E. PROVISIONS

Technical Report Requirements (within 90 days of issuance of NOA)			
E.1.a	28	Have on-site.	Spill Prevention and Emergency Response Plan
E.1.b	29	Have on-site.	Sampling and Analysis Plan
E.1.c	30	Submit to Regional Water Board within 90 days issuance of NOA. Have on-site	Sludge Management Plan
E.2.h	32	Have on-site	Copy of NOA, and General Order

200928_Attachment_1_KnightsBridge_NOA

¹ The General Order is available on the [State Water Board website](https://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf) at:
https://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf