



Linda S. Adams
Secretary for
Environmental
Protection

California Regional Water Quality Control Board Central Valley Region

Katherine Hart, Chair

1685 E Street, Fresno, California 93706
(559) 445-5116 • Fax (559) 445-5910
<http://www.waterboards.ca.gov/centralvalley>



Arnold
Schwarzenegger
Governor

26 August 2010

Mr. James Clayton
Cascade Mobile Home Park
33 Castellina Dr.
Newport Coast, CA 92657

Mr. Phil Hoon
Cascade Mobile Home Park
5 Bon Air Rd. #225
Larkspur, CA 94939

Ms. Marilyn Scheller
18330 Wards Ferry Rd. #C
Sonora, CA 95370

REQUEST FOR ADDITIONAL INFORMATION, CASCADE MOBILE HOME PARK, SONORA CASCADE PROPERTIES I, LP, TUOLUMNE COUNTY

Central Valley Water Board staff reviewed the Report of Waste Discharge (RWD) submitted 30 March 2010 on behalf of Sonora Cascade Properties I, LP, for Cascade Mobile Home Park (Park), which is about four miles southeast of Sonora. The submittal included a complete Form 200, a fee in the amount of \$1,380, and a technical report describing the ongoing discharge of effluent from the Park's Wastewater Treatment Facility (WWTF). Belt Engineering and Scientific, Inc., Condor Earth Technologies, Inc., and Double J Enterprises, Inc., prepared the technical report. By email dated 29 April 2010, Steve Popenoe of our staff informed Mr. Clayton and Mr. Hoon that the RWD was incomplete. The email from staff did not provide details about what information is still required.

The RWD provides enough information for us to enroll the Park under the State Water Board Water Quality Order No. 97-10-DWQ, *General Waste Discharge Requirements for Discharges to Land by Small Domestic Wastewater Treatment Systems* (General Order). A copy of the General Order is posted on the State Water Board website at the address below.

http://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/wqo97.shtml

If you are amenable to obtaining coverage of your discharge under the General Order, please submit a request for such in writing by **11 October 2010**. Otherwise, we will need the following information to prepare individual tentative WDRs:

1. An analysis demonstrating compliance with State Water Resources Control Board Resolution 68-16, Policy with Respect to Maintaining High Quality Waters of the State (Antidegradation Policy). Compliance with the Antidegradation Policy requires a constituent-by-constituent analysis of the impact the discharge will have on the quality of waters of the state (antidegradation analysis). For the Central Valley Water Board to authorize any anticipated degradation, it must be shown that: (a) the degradation is consistent with maximum benefit to the people of the State; (b) the degradation will not

California Environmental Protection Agency



unreasonably affect present and anticipated future beneficial uses; (c) the degradation does not result in water quality less than that prescribed in state and regional policies, including violation of one or more water quality objectives; and (d) the discharger employs best practicable treatment or control to minimize degradation.

2. A detailed description of design or management practices you will implement to prevent collection system overflows and resulting waste discharges into surface water.
3. An appropriate sludge management plan.
4. A statistically valid characterization of the concentrations of hexavalent chromium in source water and WWTF effluent.
5. A demonstration of design or management practices you will implement to prevent waste from entering surface waters. As part of the demonstration, you need to include a water balance incorporating a 100-year return period wet year, with rainfall distributed monthly according to average monthly precipitation data. With justification, reasonable estimates of effluent flow, pond capacity, percolation, and evaporation may be used.

By 11 October 2010, submit the information requested above, or a written request for coverage under the General Order.

If you have any questions regarding this matter, please contact Steve Popenoe at (559) 444-2418.

Original signed by:

W. DALE HARVEY
Senior WRC Engineer
RCE No. 55628

cc: Ms. Christy McKinnon, Tuolumne County Division of Environmental Health
Mr. Raymond Ainger, Dept of Housing and Community Development, Sacramento
Mr. Robert Belt, Belt Engineering and Scientific, Inc., Sonora