



Central Coast Regional Water Quality Control Board

August 24, 2022

Sent Via Electronic Mail

Juan Ramon Gomez
General Manager/CPO
Los Alamos Community Services District
82 North Saint Joseph
Los Alamos, CA 93440
e-mail: jrgomez@losalamoscsd.com

Dear Juan Ramon Gomez:

LOS ALAMOS WASTEWATER TREATMENT PLANT, 8690 BELL STREET, LOS ALAMOS, CA 93440, SANTA BARBARA COUNTY:

- **NOTICE OF APPLICABILITY FOR ENROLLMENT IN ORDER NO. R3-2020-0020, GENERAL WASTE DISCHARGE REQUIREMENTS FOR DISCHARGES FROM DOMESTIC WASTEWATER SYSTEMS WITH FLOWS GREATER THAN 100,000 GALLONS PER DAY;**
- **TRANSMITTAL OF MONITORING AND REPORTING PROGRAM NO. R3-2022-0049; AND**
- **TERMINATION OF INDIVIDUAL PERMIT, WASTE DISCHARGE REQUIREMENTS ORDER NO. R3-2005-0133 FOR LOS ALAMOS COMMUNITY SERVICES DISTRICT WASTEWATER TREATMENT AND DISPOSAL FACILITIES, SANTA BARBARA COUNTY**

The Central Coast Regional Water Quality Control Board (Central Coast Water Board) reviewed the April 20, 2022 notice of intent and available documents associated with Los Alamos Community Services District's domestic wastewater treatment facility (Wastewater System) located at 8690 Bell Street in Los Alamos, CA, California. The Wastewater System, owned by Los Alamos Community Services District is currently regulated pursuant to *Waste Discharge Requirements Order No. R3-2005-0113 for Los Alamos Community Services District Wastewater Treatment and Disposal Facilities Santa Barbara County* (Order No. R3-2005-0113).

On September 25, 2020, the Central Coast Water Board adopted *General Waste Discharge Requirements Order No. R3-2020-0020 for Discharges from Domestic Wastewater Systems with Flows Greater than 100,000 Gallons per Day* (General Permit).

JANE GRAY, CHAIR | MATTHEW T. KEELING, EXECUTIVE OFFICER

This letter serves as a notice of applicability for enrollment in the General Permit. This letter includes: wastewater system operation summary, specific requirements, and limitations (Attachment 1); figures (Attachment 2); and Los Alamos Community Services District's monitoring and reporting program requirements (Attachment 3).

This letter also serves as a notice of termination of Los Alamos Community Services District's coverage in existing individual permit, Order No. R3-2005-0113.

Los Alamos Community Services District must comply with the following:

1. **General Permit** – Los Alamos Community Services District must comply with all conditions and requirements of the General Permit. As described in the General Permit, ongoing operation, maintenance, monitoring, and reporting are required. A copy of the General Permit can be found electronically at the following link:

https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/r32020_0020.pdf

2. **Monitoring and Reporting Program** – Los Alamos Community Services District must comply with the requirements of the monitoring and reporting program enclosed with this letter (monitoring and reporting program no. R3-2022-0049, Attachment 3). Los Alamos Community Services District must start implementing the monitoring on **October 1, 2022**. The first quarterly monitoring report is due **November 1, 2022** and the first annual report is due **March 1, 2023**. Los Alamos Community Services District is also required to comply with annual volumetric reporting requirements¹ established by the State Water Resources Control Board (State Water Board), due annually to the GeoTracker database on April 30th.

Quarterly monitoring reports and annual reports must be provided electronically in searchable PDF with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permitting/docs/transmittal_sheet.pdf

All annual reports must be formatted and completed as specified in the annual report template found at the following link:

https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/wdr_annual_report_format.pdf

Los Alamos Community Services District must submit all reports/documents and laboratory data (using the transmittal sheet as the cover page) to the publicly

¹ See: [Volumetric Annual Reporting | California State Water Resources Control Board](#)

accessible State Water Board's GeoTracker^{2,3} database with applicable Electronic Submittal of Information (ESI) requirements under the Wastewater System – specific global identification number over the internet at:

<https://geotracker.waterboards.ca.gov/esi/login.asp>

The attached monitoring and reporting program outlines the GeoTracker electronic reporting requirements. The Central Coast Water Board may request submittal of some documents on paper, particularly drawings or maps that require a large size to be readable, or in other electronic formats where evaluation of data is required.

3. **Fees** – Los Alamos Community Services District paid an annual fee of \$7,486 on December 8, 2021 for coverage in existing individual permit, Order No. R3-2005-0113. This payment covers Los Alamos Community Services District's enrollment in the General Permit for the 2021-2022 fiscal year.

Los Alamos Community Services District must pay an annual fee to maintain coverage in the General Permit. Annual fees are determined by the State Water Board's fee program and cover the state fiscal year of July 1 through June 30. Your current annual fee is \$23,783. Los Alamos Community Services District's Wastewater System is currently assigned a threat and complexity rating of 2B. A copy of the current state fee schedule is available electronically at the following link:

https://www.waterboards.ca.gov/resources/fees/water_quality/#wdr

4. **Notification** – The Central Coast Water Board will be notified of Los Alamos Community Services District's enrollment at a regularly scheduled public meeting on October 13-14, 2022. Details about that meeting are available on our website at:

https://www.waterboards.ca.gov/centralcoast/board_info/agendas/

5. **Future Discharge Modifications** – Pursuant to California Water Code section 13260, Los Alamos Community Services District must inform the Central Coast Water Board at least 120 days prior to modifying your discharge. If there are any significant changes in either treatment or disposal methodologies, or the volume or character of the treated wastewater, Los Alamos Community Services District must notify the Central Coast Water Board immediately of such changes.

² Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/

³ Additional information available at: <http://geotracker.waterboards.ca.gov/>

Attachment 1 contains the Central Coast Water Board's understanding of the Wastewater System located at 8690 Bell Street, Los Alamos, CA 93440. Please review Attachment 1 to determine if the description is representative of your current system. Pursuant to California Water Code section 13267, Los Alamos Community Services District must notify the Central Coast Water Board if this information is out of date or incorrect. You are required to provide staff with your updated information within **30 days** of issuance of this letter.

- 6. Responsible Party** – Los Alamos Community Services District is responsible for the management and disposal of the domestic wastewater in compliance with the conditions of the General Permit. Any noncompliance with this General Permit constitutes a violation of the California Water Code, and subjects Los Alamos Community Services District to enforcement action, and termination of enrollment under this General Permit.
- 7. Change in Ownership** - In the event of any change in control or ownership of the property, Los Alamos Community Services District must notify the succeeding owner or operator of the existence of this General Permit by letter, a copy of which shall be immediately forwarded to the Central Coast Water Board so that the new owner or operator can be enrolled in the General Permit and Los Alamos Community Services District's enrollment in the General Permit can be terminated.
- 8. Certified Operator** – Los Alamos Community Services District is required to comply with the operator certification requirements⁴ administered by the State Water Board's Office of Operator Certification, which currently requires a Class II certified operator onsite to maintain and operate the Wastewater System.
- 9. Termination of Permit** – The existing individual permit, Order No. R3-2005-0113 is terminated, except for enforcement purposes⁵. Los Alamos Community Services District is responsible for compliance with Order No. R3-2005-0113 prior to the date of this letter.
- 10. Compliance Schedule** – As required in the attached monitoring and reporting program, Los Alamos Community Services District must request a time schedule order 12 months from the date of this notice of applicability pursuant to Water Code section 13300, which must include more details, milestones, and a schedule for upgrades.

⁴ Title 23 Division 3. Chapter 26 Wastewater Treatment Plant Classification, Operator Certification and Contract Operator Registration.

https://www.waterboards.ca.gov/water_issues/programs/operator_certification/docs/ocr_clean.pdf

⁵ The General Permit states "... where a Wastewater System discharge is currently regulated by an individual permit, that permit is terminated upon the enrollment of the Wastewater System into this General Permit."

August 24, 2022

If you have any questions, please contact **Cecile Blancarte at (805) 542-4782 or by email at Cecile.Blancarte@waterboards.ca.gov** or Jennifer Epp at (805) 594-6181 or by email at Jennifer.Epp@waterboards.ca.gov.

Sincerely,

Jennifer Epp
Digitally signed by Jennifer Epp
Date: 2022.08.23 17:26:21
-07'00'
Water Boards

for Matthew T. Keeling
Executive Officer

Attachments:

Attachment 1: Wastewater System Operation Summary, Specific Requirements, and Limitations

Attachment 2: Figures

Attachment 3: Monitoring and Reporting Program Order No. R3-2020-0049

cc:

Candyce Clark, Los Alamos Community Services District, cclark@losalamoscscsd.com

Alejandra Celio, Bethel Engineering, alejandra@dbaengineers.com

Lori Speer, Bethel Engineering, lori@dbaengineers.com

Jennifer Epp, Central Coast Water Board, Jennifer.Epp@Waterboards.ca.gov

Jesse Woodard, Central Coast Water Board, Jesse.Woodard@waterboards.ca.gov

Cecile Blancarte, Central Coast Water Board, Cecile.Blancarte@Waterboards.ca.gov

WDR Program, GeoTracker RB3-WDR@Waterboards.ca.gov

ECM/CIWQS = CW-237395

GeoTracker No. = GT- WDR100030112

Rev 4/27/2022

ECM Subject Name = Los Alamos Wastewater Treatment Plant NOA for R3-2020-0020

\\ca.epa.local\RB\RB3\Shared\WDR\WDR Facilities\Santa Barbara Co\Los Alamos WWTP\Big Order Enrollment\Los Alamos-NOA R3-2020-0020.docx

ATTACHMENT 1
WASTEWATER SYSTEM OPERATION SUMMARY, SPECIFIC REQUIREMENTS,
AND LIMITATIONS

1. OWNERSHIP AND WASTEWATER SYSTEM INFORMATION

Ownership and wastewater system information submitted by Los Alamos Community Services District to the Central Coast Water Board is shown in Table 1.

Table 1. Ownership and Wastewater System Information

Name	Los Alamos Wastewater Treatment Plant
Physical Address	8690 Bell Street Los Alamos, CA 93440
Latitude	34.753501
Longitude	-120.294309
Mailing Address	82 North Saint Joseph, Los Alamos, CA 93440
Owner	Los Alamos Community Services District
Operator	Los Alamos Community Services District phone: (805) 344-4195 e-mail: jrgomez@losalamoscscsd.com
Legally Responsible Official	Los Alamos Community Services District phone: (805) 344-4195 e-mail: jrgomez@losalamoscscsd.com
Raw Wastewater Characteristics	Sewer Connections: 614 Population Served: 1,654 Domestic (%): 100% Industrial (%): 0%
Permitted Design Flow (gallons per day, gpd)	200,000
Baseline Flow (average annual flow) in gpd	123,000
Threat to Water Quality	2
Complexity	B
For Internal Use	
Fee Code	58
Primary Place Type	Wastewater Treatment Facility
Facility Type	Municipal/Domestic
Facility Waste Type	Domestic Wastewater
Regulatory measure Type	Enrollee - WDR
Reclamation Included	No

2. WASTEWATER SYSTEM OPERATION SUMMARY

Los Alamos Wastewater Treatment Plant wastewater treatment facility (Wastewater System) is a Class I wastewater system. Los Alamos Community Services District must staff a Grade I chief plant operator for proper operation of the Wastewater System. The current chief plant operator is Juan Ramon Gomez, Grade 3, License Number 10693.

In the notice of intent, Los Alamos Community Services District proposes that the Wastewater System is designed to treat and dispose of 200,000 gallons per day to a secondary treatment level. The Wastewater System consists of the treatment technologies and treatment capabilities shown in Table 2. The Central Coast Water Board is permitting the operation and disposal of the system as described below. Los Alamos Community Services District must not change operation or disposal technology without Central Coast Water Board notification and review.

Table 2. Treatment Technology and Capacity

Headworks/Preliminary Treatment	The headworks consists of a comminutor with a 2-inch bypass bar screen.
	Headworks capacity (gpd): 400,000
Primary and Secondary Treatment	Influent wastewater flows into Pond 1, a lined facultative pond where it undergoes aerobic processing of organic substances near the surface. Settled sludges undergo anaerobic fermentation in the anaerobic lower region of the pond. Effluent is pumped from Pond 1 into Pond 2, a facultative pond for further treatment before being land applied through spray irrigation. Each pond is mechanically equipped with surface aerators. Each pond is 18 feet deep and has a holding capacity of 1.4 million gallons. The average detention time of seven days.
	Primary treatment capacity (gpd): 200,000
	Secondary treatment capacity (gpd): 0
Tertiary Treatment	N/A
	Tertiary treatment capacity (gpd): 0
Disinfection	N/A
	Disinfection Capacity (gpd): 0
Wastewater Disposal Method	The wastewater disposal methods include land applying onto 47.6 acres and evaporation/percolation via 64.4 acre-feet of basins.
	Disposal capacity (gpd): 200,000
Biosolids/Sludge Production and Handling	Solids are removed every five to eight years using a solids waste hauler.
	5- year production of biosolids: 155 dry tons
	The ultimate destination of biosolids produced is determined at the time of removal by Synagro WWT, Inc.

A summary of historic and recent average effluent concentrations is included in Table 3, which were reported in Los Alamos Community Services District quarterly monitoring reports. The Central Coast Water Board used reported effluent water quality data to establish the effluent and groundwater limitations in section 3.

Table 3. Effluent Water Quality for Select Constituents

Constituents	Units	Historical Average	Annual Average for 2021^[4]
Biochemical Oxygen Demand, 5-Day	mg/L	50 ^[2]	67
Total Suspended Solids	mg/L	77 ^[2]	92
Total Dissolved Solids	mg/L	806 ^[2]	920
Chloride	mg/L	157 ^[2]	165
Sodium	mg/L	145 ^[2]	171
Sulfate	mg/L	No Data	No Data
Boron	mg/L	No Data	No Data
Total Nitrogen	mg/L	67 ^[3]	No Data
Nitrate as Nitrogen	mg/L	0.12 ^[3]	No Data

[1] mg/L denotes milligrams per liter

[2] Based on water quality data reported by Los Alamos Community Services District in their 2011 to 2021 monitoring reports.

[3] Based on water quality data reported by Los Alamos Community Services District for samples collected in March and April 2022.

[4] Based on water quality data reported by Los Alamos Community Services District in the 2022 Notice of Intent.

3. WASTEWATER SYSTEM SPECIFIC REQUIREMENTS AND LIMITATIONS

Los Alamos Community Services District must operate the Wastewater System in accordance with the General Permit and this notice of applicability. Los Alamos Community Services District must comply with the wastewater specific limitations specified in Table 4 through Table 8. Los Alamos Community Services District land applies treated wastewater and thus organic loading limitations specified in Table 8 apply.

Interim effluent limitations shown in Table 5 apply for up to 24 months from the date of this notice of applicability. After 24 months, effluent limitations shown in Table 6 apply.

A. Flow Limitations:

Table 4. Flow Limitations

Flow	Units	Limit	Point of Compliance
Maximum Daily	Gallons per day	200,000	Influent

B. Effluent Limitations:

Based on reported water quality data, effluent water quality for 5-day Biochemical Oxygen Demand (BOD₅) and Total Suspended Solids (TSS) (see Table 3 in General Permit) exceed the General Permit effluent limits for treatment ponds. Therefore, pursuant to the General Permit, Los Alamos Community Services District must comply with their individual permit No. R3-2005-0113 limits for two years providing them time to modify the Wastewater System in order to meet the General Permit effluent limitations. The individual permit No. R3-2005-0113 set effluent limits for land applying wastewater. Therefore, to avoid backsliding of prior regulatory limits, effluent limits for BOD₅, TSS, total dissolved solids, settleable solids, sodium, chloride, and pH are in effect for the first 24 months from the date of this notice of applicability. **In 24 months from the date of this notice of applicability, treatment pond effluent limitations shown in Table 6 apply.**

Table 5. Interim Effluent Limitations: Treatment Ponds

Constituent	Units	30-Day Average	Sample Maximum
Biochemical Oxygen Demand, 5-Day	mg/L ^[1]	80	120
Total Suspended Solids	mg/L	80	120
Total Dissolved Solids	mg/L	Water Supply + 300	850
Settleable Solids	mL/L ^[2]	0.3	0.5
Sodium	mg/L	Water Supply + 70	200
Chloride	mg/L	Water Supply + 50	200
pH	Standard pH Units	Between 6.5 and 8.4	Not Applicable

[1] mg/L denotes milligrams per liter

[2] mL/L denotes milliliters per liter

Table 6. Effluent Limitations: Treatment Ponds (after 24 months)¹

Constituent	Units	30-Day Average	7-Day Average	Sample Maximum
Biochemical Oxygen Demand, 5-Day	mg/L	45	65	Not Applicable
Total Suspended Solids	mg/L	45	65	Not Applicable
Settleable Solids	mL/L	0.3	Not Applicable	0.5
pH	Standard pH Units	Between 6.5 and 8.4	Not Applicable	Not Applicable

1. Effluent limits in Table 6 take effect 24-months from the date of this notice of applicability.

C. Groundwater Limitations:

Based on review of historical effluent water quality (see Table 3), Los Alamos Community Services District is unable to comply with the General Permit effluent limitations for total dissolved solids, chloride, sodium, and total nitrogen, thus the point of compliance for these constituents will be underlying groundwater. Through groundwater monitoring, Los Alamos Community Services District must demonstrate that the discharge does not cause underlying groundwater to exceed the water quality objectives set forth in the Basin Plan.

Currently, Los Alamos Community Services District is not required to monitor groundwater, and has no groundwater wells present. The General Permit allows a Discharger two years to comply with effluent limits at the point of discharge or in groundwater. Thus, within two years, Los Alamos Community Services District must either install wells and monitor groundwater to demonstrate compliance with constituent limits in Table 7 or improve the Water System to comply with Table 7 limits at the point of discharge (i.e., effluent sample location).

Central Coast Water Board staff anticipates Los Alamos Community Services District will need additional time, more than 24-months, to achieve compliance with the final effluent limitations provided in Table 7. Within 12 months from the date of this notice of applicability, Los Alamos Community Services District must notify the Central Coast Water Board and refer to the General Permit to request a compliance time schedule order pursuant to Water Code section 13300 for consideration by the Central Coast Water Board.

**Table 7. Groundwater Limitations
for Designated Groundwater Basin - *San Antonio Creek Valley***

Constituents	Units	25-Month Rolling Median ^[1]
Total Dissolved Solids	mg/L	600
Chloride	mg/L	150
Sodium	mg/L	100
Sulfate	mg/L	100
Boron	mg/L	0.5
Total Nitrogen	mg/L	10

[1] Rolling Median is the median from all data collected over the most recent 25 months

D. Organic Loading Limitations:

Los Alamos Community Services District land applies treated wastewater and thus organic loading limitations specified in Table 8 apply.

Table 8. Organic Loading Limitations

Constituents	Units	30-Day Average	Maximum
Biochemical Oxygen Demand, 5- Day	Pounds/acre/day	100	300

ATTACHMENT 2 FIGURES




Figure 1. Site Vicinity Map




Figure 2. Site Location Map



ATTACHMENT 3
MONITORING AND REPORTING PROGRAM

CENTRAL COAST REGIONAL WATER QUALITY CONTROL BOARD
MONITORING AND REPORTING PROGRAM NO. R3-2022-0049
(AUGUST 24, 2022 MODIFICATION OF MONITORING AND REPORTING PROGRAM
NO. R3-2020-0020)
FOR
LOS ALAMOS WASTEWATER TREATMENT PLANT
LOS ALAMOS, SANTA BARBARA COUNTY

This Monitoring and Reporting Program applies to the monitoring and reporting requirements for Los Alamos Wastewater Treatment Plant (Wastewater System) enrolled in *General Waste Discharge Requirements Order No. R3-2020-0020 for Discharges from Domestic Wastewater Systems with Flows Greater than 100,000 Gallons per Day* (General Permit).

Los Alamos Community Services District owns and operates the Wastewater System that is subject to the General Permit and notice of applicability. Los Alamos Community Services District must not implement any changes to this monitoring and reporting program unless and until a revised monitoring and reporting program is issued by the Central Coast Regional Water Quality Control Board (Central Coast Water Board).

The State Water Resources Control Board (State Water Board) and Regional Water Quality Control Boards are transitioning to the use of the publicly accessible State Water Board's GeoTracker database for the tracking of environmental and regulatory data for sites that operate under waste discharge requirements. The monitoring and reporting program directs Los Alamos Community Services District to submit reports (both technical and monitoring reports) and analytical data electronically to the State Water Board's GeoTracker database (see monitoring and reporting program section VII.C).

I. SAMPLING AND ANALYSIS

Los Alamos Community Services District must collect representative samples in accordance with the most recently approved sampling and analysis plan contained in the Operations and Maintenance Manual and validate analytical results prior to submittal to the Central Coast Water Board. All samples (e.g., wastewater, groundwater, soil, sludge, etc.) must be representative of the volume and nature of the discharge or matrix of materials sampled.

All samples must be collected by a qualified person, trained in proper procedures for collecting the samples. The name of the sampler, sample type (grab or composite), time, date, location, bottle/container type, and any preservative used for each sample must be recorded on the sample chain of custody form. The chain of custody form must also contain all custody information including date, time, and to whom samples were relinquished. If composite samples are collected, the basis for sampling (time or flow

weighted) must be included in the sampling and analysis plan contained in the Operations and Maintenance Manual for Central Coast Water Board review and approval.

- A. Sampling Schedule** – Unless otherwise specified below, sampling must be performed in accordance with Table 1.

Table 1. Sampling Schedule

Monitoring Period	Sample Collection Time
Quarterly	January, April, July, and October
Semiannual	April and October
Annual	October

Field test instruments (such as those used to test pH, dissolved oxygen, and electrical conductivity, etc.) may be used if they are used by a State Water Board Environmental Laboratory Accreditation Program accredited laboratory, or:

1. The user is trained in proper use and maintenance of the instruments;
2. The instruments are field calibrated prior to monitoring events at the frequency recommended by the manufacturer;
3. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency; and
4. Field calibration reports are maintained and available for at least three years.

- B. Monitoring Location Descriptions** – All samples including influent samples (IS), effluent samples (ES), groundwater monitoring well (MW), etc. must be collected at the locations described in Table 2. These locations must be consistent with the Central Coast Water Board approved sampling and analysis plan. **Los Alamos Community Services District must upload the GeoTracker field point information for each sampling location in the GeoTracker database once, prior to uploading laboratory data (see Table 9).**

Table 2. Sample Identification Details

GeoTracker Field Point Class	GeoTracker Field Point Name (Sample ID)	GeoTracker Field Point Description
Influent Sample	IS-1	Raw wastewater sample collected at the headworks
Effluent Sample	ES-1	Treated wastewater sample collected just prior to land application or discharge into percolation basin.

GeoTracker Field Point Class	GeoTracker Field Point Name (Sample ID)	GeoTracker Field Point Description
Water Supply Well	WSW-1	Well #3A - Water Supply well sample collected prior to treatment and distribution.
Water Supply Well	WSW-2	Well #4 - Water Supply well sample collected prior to treatment and distribution.
Water Supply Well	WSW-3	Well #5 - Water Supply well sample collected prior to treatment and distribution.
Water Supply Well	WSW-4	Well #6 - Water Supply well sample collected prior to treatment and distribution.
Pond Sample	ES-2A through ES-2E	Treatment Ponds, Detention Ponds, and Percolation Ponds. Detention pond sample collected 8-inches below surface.
Monitoring Well-1	MW-1	Groundwater Monitoring Well
Monitoring Well-2	MW-2	Groundwater Monitoring Well
Monitoring Well-3	MW-3	Groundwater Monitoring Well

II. WATER SUPPLY MONITORING

Representative samples of Los Alamos Community Services District's raw water supply (sampled before use or treatment) must be collected and analyzed, at a minimum, for constituents specified in Table 3.

In lieu of the required water supply sampling, Los Alamos Community Services District may request Central Coast Water Board approval to submit a Well Identification Number and the reporting year's consumer confidence report (annual water quality report or drinking water quality report), as required by the State Water Board Division of Drinking Water and/or county, provided, at a minimum, all of the required constituents are sampled at the frequency specified in Table 3. Los Alamos Community Services District must report the results of any constituent monitored more frequently than is required by the monitoring program shown in Table 3. Los Alamos Community Services District must also report detectable concentrations (above the reporting limit) for any other constituent that has a published maximum contaminant level (MCL).

Los Alamos Community Services District must evaluate and provide a tabular summary of the water supply data with the annual monitoring report.

Table 3. Water Supply Monitoring

Constituent	Units ^[1]	Sample Type	Sampling Frequency
Nitrate (as N)	mg/L	Grab	Annually
Total Dissolved Solids	mg/L	Grab	Annually
Chloride	mg/L	Grab	Annually
Sodium	mg/L	Grab	Annually
Sulfate	mg/L	Grab	Annually
Boron	mg/L	Grab	Annually
Carbonate	mg/L	Grab	Annually
Bicarbonate	mg/L	Grab	Annually
Calcium	mg/L	Grab	Annually
Potassium	mg/L	Grab	Annually
Magnesium	mg/L	Grab	Annually

[1] mg/L denotes milligrams per liter

III. INFLUENT AND EFFLUENT MONITORING

A. Influent and Effluent Flow Monitoring – Los Alamos Community Services District must monitor and report flow in gallons per day, as described in Table 4, with each monitoring report. See monitoring and reporting program section VII.A.3 for supplemental volumetric annual reporting requirements established by the State Water Board.

Table 4. Influent and Effluent Flow Monitoring

	INFLUENT	INFLUENT	EFFLUENT	EFFLUENT
Parameter	Sample Type	Reporting Frequency	Sample Type	Reporting Frequency
Daily Flow ^[1]	Metered	Daily	Metered	Daily
Maximum Daily Flow	Metered	Monthly	Metered	Monthly
Mean Daily Flow	Calculated	Monthly	Calculated	Monthly

[1] The General Permit notice of applicability specifies the Wastewater System's maximum permitted flow. In the monitoring reports, Los Alamos Community Services District must evaluate and provide a comparison of monitored flow to the permitted flow.

B. Wastewater System Monitoring – Representative samples of Los Alamos Community Services District’s influent (raw wastewater) into the Wastewater System and effluent (treated wastewater) discharged to land must be collected and analyzed in accordance with the treatment technology-based monitoring requirements (including sample type and frequency) summarized in the tables below. See Figure 1 for the location of samples and GeoTracker field points.




Figure 1. Process Flow Diagram and Sample Locations Referenced in Table 2

1. Pond System Monitoring

- i. **Required Pond Monitoring** – All wastewater treatment and treated wastewater storage/disposal ponds (lined and unlined) must be monitored as specified in Table 5.

Table 5. Wastewater Treatment/Storage/Disposal Pond Monitoring IS-1, ES-1, and ES-2A through ES-2E

Parameter/ Constituent	Units	Sample Type	Sampling/Monitoring Frequency
Freeboard	0.1 feet	Measured	Weekly
Dissolved Oxygen (in pond)	mg/L	Grab	Monthly
Odors	Not Applicable	Observation	Weekly

Parameter/ Constituent	Units	Sample Type	Sampling/Monitoring Frequency
Berm condition	Not Applicable	Observation	Monthly
Sludge Depth	0.1 feet	Measured	Annually
Precipitation	inches/day and date	Measured ^[1]	Each precipitation event

[1] Los Alamos Community Services District may use a rain gauge or use a National Oceanic and Atmospheric Administration or the United States Geological Survey rain station, such as <http://scacis.rcc-acis.org/>.

- ii. **Influent and Effluent Monitoring** – At a minimum, influent and effluent constituent monitoring for pond treatment systems must be monitored as specified in Table 6.

Table 6. Influent and Effluent Monitoring for Pond Treatment Systems

		INFLUENT (IS-1)	INFLUENT (IS-1)	EFFLUENT (ES-1)	EFFLUENT (ES-1)
Parameter/ Constituent	Units	Sample Type	Sampling Frequency	Sample Type	Sampling Frequency
pH	units	Grab	Weekly	Grab	Weekly
Biochemical Oxygen Demand, 5-Day	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Total Suspended Solids	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Settleable Solids	mg/L	Not Applicable	Not Applicable	Grab	Weekly
Total Nitrogen ^[2]	mg/L	Calculated	Quarterly	Calculated	Quarterly
Nitrate (as N) + Nitrite (as N) or separate species	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Total Kjeldahl Nitrogen (as N)	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Ammonia (as N)	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Total Dissolved Solids	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Chloride	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Sodium	mg/L	24-hour composite	Quarterly	Grab	Quarterly

		INFLUENT (IS-1)	INFLUENT (IS-1)	EFFLUENT (ES-1)	EFFLUENT (ES-1)
Parameter/ Constituent	Units	Sample Type	Sampling Frequency	Sample Type	Sampling Frequency
Sulfate	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Boron	mg/L	Not Applicable	Not Applicable	Grab	Quarterly
Carbonate	mg/L	Not Applicable	Not Applicable	Grab	Semiannually
Bicarbonate	mg/L	Not Applicable	Not Applicable	Grab	Semiannually
Calcium	mg/L	Not Applicable	Not Applicable	Grab	Semiannually
Potassium	mg/L	Not Applicable	Not Applicable	Grab	Semiannually
Magnesium	mg/L	Not Applicable	Not Applicable	Grab	Semiannually

[1] Total nitrogen is the sum of total inorganic nitrogen (nitrate + nitrite + ammonium + ammonia) and organic nitrogen.

IV. WASTEWATER DISPOSAL MONITORING

Los Alamos Community Services District must monitor all wastewater disposal areas (e.g., land application areas, percolation ponds, etc.) when wastewater and/or supplemental irrigation water is applied. Inspections (observations) must be conducted as described in Table 7. Notations must be made in a bound logbook and problems must be promptly corrected and recorded. A log of these inspections must be maintained onsite and made available to Central Coast Water Board upon inspection. Observations do not need to be reported in the monitoring reports unless a violation of permit conditions is observed. If violations are observed, planned and implemented mitigation measures to address the violations must be reported.

Los Alamos Community Services District must evaluate and summarize wastewater disposal application rates, loading rates (pounds/acre/day), violations found during the inspections, etc. with each monitoring report.

If wastewater and/or supplemental irrigation water is not discharged to land during a reporting period, the monitoring report must still be submitted and indicate that there was no discharge during the reporting period.

Table 7. Wastewater Disposal Monitoring

Parameter/Constituent	Units	Sample Type	Monitoring Frequency
Wastewater/Supplemental Irrigation	Gallons per day	Metered/Estimated ^[1]	Daily

Parameter/Constituent	Units	Sample Type	Monitoring Frequency
Local Precipitation	Inches/day	Weather Station ^[2]	Each precipitation event
Acreage Applied ^[3]	Acres	Measured	Daily
Application Rate	Gallons per day	Metered/Estimated ^[1]	Daily
Average Monthly Biochemical Oxygen Demand, 5-Day (BOD) Applied ^[4] ^[5]	lbs/acre/day	Calculated	Monthly
Maximum Daily BOD ₅ Applied ^[5]	lbs/acre/day	Calculated	Daily
Total Nitrogen Applied ^[4] ^[5]	lbs/acre/day	Calculated	Monthly
Salts Applied ^[4] ^[5] (total dissolved solids, sodium, chloride, sulfate, boron)	lbs/acre/day	Calculated	Monthly
Soil Erosion Evidence	Not Applicable	Observation	Monthly
Containment Berm Condition	Not Applicable	Observation	Monthly
Soil Saturation/Ponding	Not Applicable	Observation	Monthly
Nuisance Odors/Vectors	Not Applicable	Observation	Monthly
Discharge Offsite	Not Applicable	Observation	Monthly

- [1] Requires meter reading, a pump run time meter, or other approved method. If the flow is estimated, Los Alamos Community Services District is required to provide an explanation (e.g., no meter- estimated using pump operations including rate and time) with each monitoring report.
- [2] Los Alamos Community Services District must have a rain gauge or use a NOAA or USGS rain station, such as <http://scacis.rcc-acis.org/>.
- [3] Acreage applied denotes the acreage to which wastewater is applied.
- [4] The total nitrogen, salts, and BOD applied loading rates must be calculated from wastewater flow volumes, applied acreage, and concentrations reported in effluent analytical testing as follows:

Total Nitrogen/Salts/BOD Applied (pounds/acre/ day) =

$$\frac{X \text{ [mg/L]} \times Q \text{ [million gallons per day]} \times 8.34 \text{ [(conversion from mg/L to pounds/million gallons per day)]}}{\text{Acreage Applied [acres]}}$$

Where X = Total nitrogen, salts, or BOD concentration

Where Q = Application Rate (often effluent flow rate)

- [5] Frequencies of analytical testing are defined in the influent and effluent monitoring Table 6.

V. SLUDGE/BIOSOLIDS DISPOSAL MONITORING

Los Alamos Community Services District must report the handling and disposal of all sludge/biosolids generated at the Wastewater System. Records must include the date removed from the Wastewater System, name/contact information for the hauling company, the type and volume of waste transported, the disposal facility name and address, and copies of analytical data required by the entity accepting the waste. These records must be submitted as part of the annual monitoring report.

Los Alamos Community Services District must also monitor sludge/biosolids consistent with a Central Coast Water Board approved sludge management plan and in accordance with the requirements specified by the receiving party, including a regulated landfill and/or regulated composting facility.

If sludge/biosolids are not removed during the year, Los Alamos Community Services District must explain the absence of this monitoring in the annual report.

VI. GROUNDWATER MONITORING

A. Option 1: No Groundwater Monitoring Program – Los Alamos Community Services District has chosen General Permit Option 1 for groundwater monitoring. Under this option, Los Alamos Community Services District must demonstrate the quality of effluent discharged from the Wastewater System meets effluent limitations specified in Table 6 or Table 7 of the General Permit. Los Alamos Community Services District must evaluate and provide a comparison of their effluent to the effluent limitations in the monitoring reports. Los Alamos Community Services District must demonstrate within 24 months of issuance of the notice of applicability that the quality of effluent discharged from the Wastewater System meets effluent limitations specified in Table 6 or Table 7 of the General Permit.

If Los Alamos Community Services District is unable to comply with the effluent limitations within 24 months, Los Alamos Community Services District may be required to implement the groundwater monitoring program as described in Option 2, section VI.B of Attachment D of the General Permit- General Monitoring and Reporting Program R3-2020-0020¹. Los Alamos Community Services District must submit a groundwater monitoring well workplan (as described below) if it chooses the point of compliance as groundwater.

¹ General Monitoring and Reporting Program R3-2020-0020 can be accessed on the Internet via the following link:
https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/r32020_0020mrp.pdf

VII. REPORTING REQUIREMENTS

A. QUARTERLY AND ANNUAL MONITORING REPORTS

Quarterly and annual monitoring reports are due as described in Table 8.

Table 8. Quarterly and Annual Monitoring Reporting

Report	Monitoring Period	Report Due Date
First Quarter Monitoring Report	January 1 to March 31	May 1
Second Quarter Monitoring Report	April 1 to June 30	August 1
Third Quarter Monitoring Report	July 1 to September 30	November 1
Fourth Quarter Monitoring Report	October 1 to December 31	February 1
Annual Report	January 1 to December 31	March 1
State Water Board Volumetric Annual Reporting	January 1 to December 31	April 30

1. **Quarterly Monitoring Reporting** – At a minimum, the quarterly reports must include:
 - i. Results of all required monitoring in tabular format.
 - ii. The results of any pollutant or parameter monitored more frequently than is required by this monitoring program. Values obtained through additional monitoring must be used in calculations as appropriate.
 - iii. A comparison of monitoring data to the discharge specifications, applicable effluent limitations, disclosure of any violations of the notice of applicability and/or General Permit, and an explanation of any violation of those requirements. **Los Alamos Community Services District must calculate 7-day averages, 30-day averages and 25-month rolling medians for select analytes when comparing monitoring data to applicable effluent limitations specified in the General Permit.** Data must be presented in tabular format.
 - iv. Copies of laboratory analytical report(s) and chain of custody form(s).
 - v. An updated hydrogeologic conceptual site model with the groundwater monitoring reporting requirements based on new information generated from the monitoring well boring logs, groundwater elevation data, water quality data, etc.
 - vi. Copies of groundwater monitoring well field sheets with purge methods and data.

2. **Annual Reporting** – Los Alamos Community Services District must submit annual reports in compliance with Standard Provisions 2013², (and any updates to the Standard Provisions) Section C, General Reporting Requirements, Item 16 using the most recent annual report template provided by Central Coast Water Board.

The current annual report template can be found here:

https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/wdr_annual_report_format.pdf

3. **State Water Board Volumetric Annual Reporting** – Los Alamos Community Services District must electronically certify and submit a summary of the monthly influent and effluent flow volume by April 30th of each calendar year via the State Water Board's Internet GeoTracker database³.

The following information is required:

- i. Monthly volume of wastewater collected and treated by the wastewater treatment plant (i.e., total monthly influent volume).
- ii. Monthly volume of wastewater treated, specifying level of treatment, including treated wastewater discharged.
- iii. If applicable, monthly volume of recycled water distributed, and annual volume of treated wastewater distributed for beneficial use in compliance with California Code of Regulations, title 22 use categories.

Additional information about volumetric annual reporting of wastewater and recycled water and the Recycled Water Policy is available at the Recycled Water Policy Volumetric Annual Reporting Website⁴.

B. VERBAL NON-COMPLIANCE REPORTING:

Los Alamos Community Services District must verbally notify and report to Central Coast Water Board noncompliance of limits related to pond freeboard, flow rate, bypass or overflow, and wastewater containment failure, pursuant to General Permit section VI.C.2. The Central Coast Water Board Waste Discharge Requirements email address is RB3-WDR@waterboards.ca.gov and the phone number is (805) 549-3891.

² See Attachment E, Standard Provisions, 2013:

https://www.waterboards.ca.gov/centralcoast/board_decisions/docs/wdr_standard_provisions_2013.pdf

³ See: <https://geotracker.waterboards.ca.gov/>

⁴ See: [Volumetric Annual Reporting | California State Water Resources Control Board](#)

C. ELECTRONIC GEOTRACKER SUBMITTAL

All monitoring reports must be provided electronically in a searchable PDF format, with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permiitting/docs/transmittal_sheet.pdf

Los Alamos Community Services District must submit all reports/documents and laboratory analytical data to the State Water Board's GeoTracker^{5,6} database consistent with applicable Electronic Submittal of Information (ESI) requirements under the Wastewater System-specific global identification number **WDR100030112** at:

<https://geotracker.waterboards.ca.gov/esi/login>

For general questions, please contact the GeoTracker Help Desk at:
Geotracker@waterboards.ca.gov.

Table 9 summarizes all the GeoTracker electronic reporting requirements. Central Coast Water Board may request submittal of some documents on paper, particularly drawings or maps that require a large size to be readable, or in other electronic formats where evaluation of data is required.

Table 9. GeoTracker Electronic Submittal Information Data Requirements

Electronic Submittal	Description of Action	Action	Frequency
Reports and Documents	Complete copy of all documents including monitoring reports (in searchable PDF format) and any other associated documents related to the Wastewater System.	Upload directly to GeoTracker all monitoring reports (in searchable PDF format) and any other associated documents.	On or before the due dates required by this General Permit and for other documents when required by the Central Coast Water Board.

⁵ Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguide2.pdf

⁶ Additional information available at:

<https://geotracker.waterboards.ca.gov/>

Electronic Submittal	Description of Action	Action	Frequency
Laboratory Data	All analytical data (including geochemical data) in electronic deliverable format (EDF). This includes all water, soil, and vapor samples collected when monitoring a discharge.	Upload, or direct your California ELAP-accredited laboratory staff to upload, all EDF laboratory data directly to GeoTracker.	On or before the due date of the required monitoring report.
Depth to Groundwater	Monitoring wells must have the depth-to-water information reported. Report data only for wells defined as permanent sampling points.	Upload depth-to-water information to the GeoTracker GEO_WELL file.	On or before the due date of the required monitoring report.
Boring Logs and Well Screen Intervals	Boring logs must be prepared by a registered professional and submitted in PDF format separately (not only as attachments to reports).	Upload boring logs (in searchable PDF format) to GeoTracker GEO_BORE file whenever a new boring is drilled.	Every time a new boring is drilled.
Field Points, Location Data (Geo XY) ^[1]	Name, classify, and identify the location (latitude and longitude) of all sampling points. Monitoring wells must be surveyed, influent and effluent sample locations must be identified on the GeoTracker mapping tool under "non-surveyed data." These data points are required prior to laboratory data uploads.	Upload the location data (surveyed and non-surveyed) to the GeoTracker Geo_XY file.	Every time a permanent monitoring point is established.
Elevation Data (Geo Z) ^[2]	Survey and mark the elevation at the top of groundwater well casings for all permanent groundwater wells. These points are required prior to depth-to-water data uploads.	Upload the survey data to the GeoTracker GEO_Z file.	One-time, for all groundwater monitoring wells.
Geo Map	Site layout, map of facilities, Wastewater System including treatment and disposal area(s).	Upload the Site layout PDF to the GeoTracker site plan file.	Year one and every five years thereafter and when the facilities are modified.

[1] Geo XY required for all wells. New wells must be surveyed. For existing wells, use original well

installation survey data. Los Alamos Community Services District must also upload sample locations (e.g., influent and effluent samples) that are not defined as a **permanent monitoring well** and have not been surveyed by a licensed professional.

- [2] Geo Z required for all wells. New wells must be surveyed. For existing wells, use original well installation survey data.

VIII. TECHNICAL REPORTS

The technical reports are due as described in Table 10.

Table 10. Technical Report Submittal Due Dates

Report	Report Due Date ^[1]
Operations and Maintenance Manual	12 months (August 24, 2023)
Time Schedule Compliance Plan	12 months (August 24, 2023)
Groundwater Monitoring Well Workplan ^[2]	13 months (September 24, 2023)
Climate Change Adaptation Plan	24 months (August 24, 2024)

- [1] Reports are due within the time specified after issuance of notice of applicability to Los Alamos Community Services District. (August 24, 2022)

- [2] Required if Los Alamos Community Services District chooses the point of compliance as groundwater for salts and nitrate.

1. **Operations and Maintenance Manual** – In addition to the required components specified in Standard Provisions⁷ A.12 and A.28 (and any updates to the Standard Provisions) and General Permit section VI.A.2, the Operations and Maintenance Manual must contain the following components. Each component must contain an implementation schedule and identification of adequate funding to implement the component.
 - i. **Sampling and Analysis Plan** – Los Alamos Community Services District's Operation and Maintenance Manual must contain a sampling and analysis plan that meets the requirements specified herein. Anyone performing sampling on behalf of Los Alamos Community Services District must be familiar with the sampling and analysis plan. At a minimum, the sampling and analysis plan must contain the following:
 - a. A wastewater treatment process flow schematic with the monitoring locations labeled and scaled Wastewater System maps with treatment components, discharge locations (both treated wastewater and non-

⁷ See Attachment E, Standard Provisions, 2013:

https://www.waterboards.ca.gov/centralcoast/board_decisions/docs/wdr_standard_provisions_2013.pdf

- potable recycled water), monitoring locations, groundwater wells, storage locations (e.g., chemical, sludge, emergency overflow ponds, etc.), buildings, etc. (if Los Alamos Community Services District needs to update Figure 1 to comply with this requirement, a copy of the updated process flow schematic will also be included with the annual report).
- b. Sample identification details in tabular format. The table must include the sample titles, GeoTracker field point information, sample description(s), and sampling frequencies.
 - c. Sample chain-of-custody procedures and documentation.
 - d. Sample handling/preservation procedures.
 - e. A description of the analytical methods.
 - f. A description of sample containers, preservatives, and holding times.
 - g. For water supply monitoring, a description of the location and method of data collection (e.g., onsite well sampling, use of consumer confidence report, etc.).
 - h. For groundwater monitoring, a description of the well purging and field methods.
- ii. **Sludge Management Plan** – Los Alamos Community Services District's Operation and Maintenance Manual must contain a sludge management plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. At a minimum, the plan must describe the following:
- a. An estimated volume/amount and quality of sludge and scum that will be generated.
 - b. How sludge, scum, and supernatant will be stored and disposed of to protect groundwater quality.
 - c. If sludge will be subject to further treatment, describe the treatment and storage requirements.
 - d. Procedures for cleaning of digesters or storage vessels and the treatment and disposal of the residuals. If drying of residuals is planned, describe how that will be performed to prevent nuisance odors, prevent vectors, and protect groundwater quality.
- iii. **Wastewater Disposal Management Plan** – Los Alamos Community Services District's Operation and Maintenance Manual must contain a wastewater disposal management plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. At a minimum, the wastewater disposal management plan must include:

- a. A description of the wastewater disposal area and a map denoting acreage.
 - b. Loading calculations based on flow volumes, applied acreage, and biochemical oxygen demand, salts (total dissolved solids, sodium, chloride, sulfate, boron), and nitrogen analytical results.
 - c. A description of wastewater disposal and water quality protection practices.
- iv. **Spill Prevention and Emergency Response Plan –Los Alamos**
Community Services District's Operation and Maintenance Manual must contain a spill prevention and emergency response plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. The spill prevention and emergency response plan must describe operation and maintenance activities to prevent accidental releases of wastewater and to effectively respond to such releases and minimize the environmental impact. At a minimum, the spill prevention and emergency response plan must address the following:
- a. Operation and Control of Wastewater System - A description of the wastewater treatment equipment, operational controls, flow measurement and calibration procedures, and treatment system schematic including valve/gate locations.
 - b. Sludge Handling - A description of the sludge handling equipment, operational controls, and disposal procedures.
 - c. Collection System Maintenance - A description of collection system cleaning and maintenance, equipment tests, and alarm functionality tests to minimize the potential for wastewater spills originating in the collection system or headworks. For collection systems subject to State Water Board Order No. 2006-0003-DWQ, Statewide General Waste Discharge Requirements for Sanitary Sewer Systems (or its replacement), reports prepared to comply with State Water Board Order No. 2006-0003-DWQ satisfy this requirement.
 - d. Emergency Response - A description of emergency response procedures including for emergencies such as power outage, severe weather, flooding, or inadequate freeboard (for systems with wastewater treatment, storage, or disposal ponds or treated non-potable recycled water storage ponds). An equipment and telephone list for contractors/consultants, emergency personnel, and equipment vendors.
 - e. Finance - At a minimum, discuss current fees, projected fees, current budget for spill prevention and emergency response, projected budget for spill prevention and emergency response.

- f. Notification Procedures - Coordination procedures with fire, police, Governor's Office of Emergency Services (CalOES), Central Coast Water Board, and local county health department personnel.
 - v. **Training Records Log** – Los Alamos Community Services District's Operation and Maintenance Manual must contain updated training records logs that demonstrates Los Alamos Community Services District is complying with General Permit section VI.B.3.
- 2. **Time Schedule Compliance Plan** - As set forth in General Permit sections V.A and VI.A.5, if Los Alamos Community Services District anticipates that additional time is needed to achieve compliance with the effluent limitations, Los Alamos Community Services District must prepare and submit for Central Coast Water Board review and approval, a time schedule compliance plan. At a minimum, the time schedule compliance plan must address the following:
 - i. Comparison of the current effluent quality to the effluent and groundwater limitations in General Permit Tables 3-6.
 - ii. A detailed description and chronology of efforts, since issuance of the notice of applicability, to reduce wastes.
 - iii. Justification of the need for additional time to achieve the effluent limitations in General Permit Tables 3-6.
 - iv. A detailed time schedule of specific actions Los Alamos Community Services District will take to achieve the effluent limitations.
 - v. A demonstration that the time schedule requested is as short as possible, considering the technological, operation, and economic factors that affect the design, development, and implementation of the measures that are necessary to comply with the effluent limitation(s).
 - vi. If the requested time schedule exceeds one year, the proposed schedule shall include interim requirements and the date(s) for their achievement. The interim requirements shall include both of the following:
 - a. Effluent limitation(s) for the pollutant(s) of concern.
 - b. Actions, measurable milestones, and tangible products leading to compliance with the effluent limitation(s).
- 3. **Groundwater Monitoring Workplan** – If, in the Time Schedule Compliance Workplan, Los Alamos Community Services District proposes groundwater as the point of compliance, it must submit a Groundwater Monitoring Workplan. **The workplan must be submitted 13 months from the** issuance of notice of applicability to Los Alamos Community Services District.

At a minimum, the workplan must include a preliminary hydrogeologic conceptual site model, and propose the installation of at least three shallow groundwater monitoring wells to establish groundwater gradient, groundwater flow velocity and

direction, and evaluate groundwater quality influenced by the wastewater disposal. The number and location of the proposed groundwater monitoring well network must be on a scale sufficient to determine potential impacts and be sufficiently representative of groundwater conditions upgradient and downgradient of the permitted disposal area. The groundwater monitoring wells should not be installed prior to Central Coast Water Board approval of the groundwater monitoring workplan and preliminary hydrogeologic conceptual site model.

The groundwater monitoring wells must be installed within first encountered groundwater and in accordance with California Department of Water Resources Bulletin No. 74-81 and Supplement No. 74-90, California Water Code sections 13710 through 13755, and any local permitting requirements. The locations and top-of-casing elevations for the newly installed monitoring wells must be surveyed by a licensed land surveyor. Los Alamos Community Services District must install⁸ the Central Coast Water Board approved groundwater monitoring well network within **90 days** of receiving Central Coast Water Board approval.

4. **Climate Change Adaptation** –The Climate Change Adaptation Plan must, at a minimum, include the following components:
 - i. Hazards and Vulnerabilities – Identify climate change hazards, at a minimum accounting for the hazards listed below, applicable to the Wastewater System. Using up-to-date tools, data, and guidance from the State of California (e.g., Cal-Adapt⁹, Sea-Level Rise Guidance from Ocean Protection Council, reports from the Climate-Safe Infrastructure Working Group, the Climate Adaptation Planning Guide, and California Climate Assessment Regional Reports), assess the Wastewater System's vulnerability to identified hazards that could cause reduction, loss, or failure of treatment processes and/or critical structures at the Wastewater System. Identify and justify the resources (e.g., models and tools, design parameters) used to inform identification of these hazards and vulnerabilities.
 - a. Sea Level Rise – Saltwater intrusion, flooding and inundation, and increased coastal erosion.

⁸ Well installation must be supervised by a California licensed Civil Engineer or Professional Geologist.

⁹ Cal-Adapt is an online resource with downscaled climate project data. It provides users with projections and more detailed downloadable data supporting a range of needs and array of climate models and emissions scenarios. Cal-Adapt offers climate projections for the major stressors facing California, including the following: temperature averages and extremes, precipitation averages and extremes, sea-level rise, wildfires, and drought. The Governor's Office of Planning and Research (OPR) recommends agencies use Representative Concentration Pathway (RCP) 8.5 for analyses considering impacts through 2050, because there are minimal differences between emissions scenarios during the first half of the 21st century.

- b. Precipitation Pattern Changes.
 - I. Drought – Decreased influent quantity and quality.
 - II. Peak Events – Flooding and increased influent quantity.
- c. Temperature fluctuations and extremes.
- d. Increased wildfires.
- e. Increased power outages.
- ii. Resiliency Actions – Identify actions to build Wastewater System and operational resilience to identified vulnerabilities, accounting for options that minimize resource impacts.

IX. LEGAL REQUIREMENTS

The Central Coast Water Board's requirements that the Los Alamos Community Services District submit the technical and monitoring reports described in this monitoring and reporting program are made pursuant to [section 13267 of the California Water Code](#). Failure to submit reports in accordance with schedules established by this General Permit and notice of applicability with attachments or failure to submit a report of sufficient technical quality to be acceptable to the Central Coast Water Board may subject Los Alamos Community Services District to enforcement action pursuant to section 13268 of the California Water Code. Pursuant to [section 13268 of the Water Code](#), a violation of a request made pursuant to section 13267 may subject Los Alamos Community Services District to civil liability assessment of up to \$1,000 per day in which the violation occurs.

The Central Coast Water Board needs the required information to ensure compliance with the notice of applicability and the General Permit. Los Alamos Community Services District is required to submit this information because it is subject to the General Permit and is responsible for the discharge.

The burden, including costs, of the reports bears a reasonable relationship to their need and the benefits to be obtained. The requirement for the reports is necessary to ensure compliance with the General Permit, notice of applicability, and monitoring and reporting program to protect water quality.

Los Alamos Community Services District must implement the above monitoring program on October 1, 2022. The Central Coast Water Board may rescind or modify this monitoring and reporting program at any time.

Ordered By:

Jennifer Epp  Digitally signed by Jennifer Epp
Date: 2022.08.23 17:25:58 -07'00'

for Matthew T. Keeling
Executive Officer

MRP No. R3-2022-0049
Los Alamos Wastewater Treatment Plant, Los Alamos

August 24, 2022

\\ca.epa.local\RB\RB3\Shared\WDR\WDR Facilities\Santa Barbara Co\Los Alamos
WWTP\Big Order Enrollment\LosAlamos_MRP R3-2022-0049.docx
Last modified: 04/21/2022