



Central Coast Regional Water Quality Control Board

April 18, 2024

Sent Via Electronic Mail

Dwayne Chisam
General Manager
San Miguelito Mutual Water Company
1561 Sparrow St.
San Luis Obispo, CA, 93405
e-mail: Dchisam@smmwc.com

Dear Dwayne Chisam:

**SAN MIGUELITO MUTUAL WATER COMPANY WILD CHERRY CANYON WWTP,
3560 WILD CHERRY CANYON, SAN LUIS OBISPO - SAN LUIS OBISPO COUNTY:**

- **NOTICE OF APPLICABILITY FOR ENROLLMENT IN ORDER NO. R3-2020-0020, GENERAL WASTE DISCHARGE REQUIREMENTS FOR DISCHARGES FROM DOMESTIC WASTEWATER SYSTEMS WITH FLOWS GREATER THAN 100,000 GALLONS PER DAY;**
- **TRANSMITTAL OF MONITORING AND REPORTING PROGRAM R3-2024-0027; AND**
- **TERMINATION OF INDIVIDUAL PERMIT, WASTE DISCHARGE REQUIREMENTS ORDER NO. 95-057 FOR SAN MIGUELITO MUTUAL WATER COMPANY.**

The Central Coast Regional Water Quality Control Board (Central Coast Water Board) reviewed the February 24, 2022 notice of intent and available documents associated with San Miguelito Mutual Water Company's domestic wastewater treatment facility (Wastewater System) located at 3560 Wild Cherry Canyon in San Luis Obispo, California. The Wastewater System, owned by San Miguelito Mutual Water Company is currently regulated pursuant to *Order 95-057 Waste Discharge Requirements for San Miguelito Mutual Water Company Wild Cherry Canyon Sewage Treatment Plant*.

On September 25, 2020, the Central Coast Water Board adopted *General Waste Discharge Requirements Order No. R3-2020-0020 for Discharges from Domestic Wastewater Systems with Flows Greater than 100,000 Gallons per Day* (General Permit).

JANE GRAY, CHAIR | RYAN E. LODGE, EXECUTIVE OFFICER

This letter serves as a notice of applicability for enrollment in the General Permit. This letter includes: wastewater system operation summary, specific requirements, and limitations (Attachment 1); figures (Attachment 2); and San Miguelito Mutual Water Company's monitoring and reporting program requirements (Attachment 3).

This letter also serves as a notice of termination of San Miguelito Mutual Water Company's coverage in existing individual permit, Order 95-057.

San Miguelito Mutual Water Company must comply with the following:

1. **General Permit** – San Miguelito Mutual Water Company must comply with all conditions and requirements of the General Permit. As described in the General Permit, ongoing operation, maintenance, monitoring, and reporting are required. A copy of the General Permit can be found electronically at the following link:

https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/r32020_0020.pdf

2. **Monitoring and Reporting Program** – San Miguelito Mutual Water Company must comply with the requirements of the monitoring and reporting program enclosed with this letter (monitoring and reporting program no. R3-2024-0027, Attachment 3). San Miguelito Mutual Water Company must start implementing the revised monitoring on **July 1, 2024**. The first semiannual monitoring report is due **March 1, 2025** and the first annual report is due **March 1, 2025**. San Miguelito Mutual Water Company is also required to comply with annual volumetric reporting requirements¹ established by the State Water Resources Control Board (State Water Board), due annually to the GeoTracker database on April 30th.

Until July 1, 2024, San Miguelito Mutual Water Company must continue to monitor and report pursuant to the existing monitoring and reporting program 95-57 issued on June 9, 2023.

Semiannual monitoring reports and annual reports must be provided electronically in searchable PDF with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permitting/docs/transmittal_sheet.pdf

All annual reports must be formatted and completed as specified in the annual report template found at the following link:

¹ See: [Volumetric Annual Reporting | California State Water Resources Control Board](#)

https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/wdr_annual_report_format.pdf

San Miguelito Mutual Water Company must submit all reports/documents and laboratory data (using the transmittal sheet as the cover page) to the publicly accessible State Water Board's GeoTracker^{2,3} database with applicable Electronic Submittal of Information (ESI) requirements under the Wastewater System – specific global identification number **WDR100035521** over the internet at:

<https://geotracker.waterboards.ca.gov/esi/login.asp>

The attached monitoring and reporting program outlines the GeoTracker electronic reporting requirements. The Central Coast Water Board may request submittal of some documents on paper, particularly drawings or maps that require a large size to be readable, or in other electronic formats where evaluation of data is required.

3. **Fees** – San Miguelito Mutual Water Company paid an annual fee of \$8,431 on November 29, 2023, for coverage in existing individual permit, Order No. 95-057. This payment covers San Miguelito Mutual Water Company's enrollment in the General Permit for the 2023-2024 fiscal year.

San Miguelito Mutual Water Company must pay an annual fee to maintain coverage in the General Permit. Annual fees are determined by the State Water Board's fee program and cover the state fiscal year of July 1 through June 30. San Miguelito Mutual Water Company's Wastewater System is currently assigned a threat and complexity rating of 2B. Based on effluent and groundwater quality data submitted by San Miguelito Mutual Water Company as part of the monitoring and reporting program for Order 95-057, the Central Coast Water Board has determined that a threat and complexity of 2B is more appropriate, which has an annual fee of \$26,785. A copy of the current state fee schedule is available electronically at the following link:

https://www.waterboards.ca.gov/resources/fees/water_quality/#wdr

4. **Notification** – The Central Coast Water Board will be notified of San Miguelito Mutual Water Company's enrollment at a regularly scheduled public meeting on June 20-21, 2024. Details about that meeting are available on our website at:

https://www.waterboards.ca.gov/centralcoast/board_info/agendas/

² Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/

³ Additional information available at: <http://geotracker.waterboards.ca.gov/>

- 5. Future Discharge Modifications** – Pursuant to California Water Code section 13260, San Miguelito Mutual Water Company must inform the Central Coast Water Board at least 120 days prior to modifying your discharge. If there are any significant changes in either treatment or disposal methodologies, or the volume or character of the treated wastewater, San Miguelito Mutual Water Company must notify the Central Coast Water Board immediately of such changes.

Attachment 1 contains the Central Coast Water Board's understanding of the Wastewater System located at 3560 Wild Cherry Canyon in San Luis Obispo, California. Please review Attachment 1 to determine if the description is representative of your current system. Pursuant to California Water Code section 13267, San Miguelito Mutual Water Company must notify the Central Coast Water Board if this information is out of date or incorrect. You are required to provide staff with your updated information within **30 days** of issuance of this letter.

- 6. Responsible Party** – San Miguelito Mutual Water Company is responsible for the management and disposal of the domestic wastewater in compliance with the conditions of the General Permit. Any noncompliance with this General Permit constitutes a violation of the California Water Code, and subjects San Miguelito Mutual Water Company to enforcement action, and termination of enrollment under this General Permit.
- 7. Change in Ownership** - In the event of any change in control or ownership of the property, San Miguelito Mutual Water Company must notify the succeeding owner or operator of the existence of this General Permit by letter, a copy of which shall be immediately forwarded to the Central Coast Water Board so that the new owner or operator can be enrolled in the General Permit and San Miguelito Mutual Water Company's enrollment in the General Permit can be terminated.
- 8. Certified Operator** – San Miguelito Mutual Water Company is required to comply with the operator certification requirements⁴ administered by the State Water Board's Office of Operator Certification, which currently requires a Grade I certified operator onsite to maintain and operate the Wastewater System.
- 9. Termination of Permit** – The existing individual permit, Order No. 95-057 is terminated, except for enforcement purposes.⁵ San Miguelito Mutual Water Company is responsible for compliance with Order No. 95-057 prior to the date of

⁴ Title 23 Division 3. Chapter 26 Wastewater Treatment Plant Classification, Operator Certification and Contract Operator Registration.

https://www.waterboards.ca.gov/water_issues/programs/operator_certification/docs/ocr_clean.pdf

⁵ The General Permit states "... where a Wastewater System discharge is currently regulated by an individual permit, that permit is terminated upon the enrollment of the Wastewater System into this General Permit."

this letter.

10. Compliance Schedule – Based on historical effluent and groundwater quality data, discharges from San Miguelito Mutual Water Company's wastewater treatment plant exceed applicable water quality objectives for total dissolved solids. As required in the attached monitoring and reporting program, San Miguelito Mutual Water Company must prepare a time schedule compliance plan 12 months from the date of this notice of applicability pursuant to Water Code section 13300, which must include more details, milestones, and a schedule for complying with water quality objectives.

If you have any questions, please contact **James Bishop at (805) 542-4628 or by email at James.Bishop@waterboards.ca.gov** or Jennifer Epp at (805) 594-6181 or by email at Jennifer.Epp@waterboards.ca.gov.

Sincerely,

Jennifer Epp
Digitally signed by Jennifer Epp
Date: 2024.04.18 09:35:35 -07'00'
Water Boards

for Ryan E. Lodge
Executive Officer

Attachments:

Attachment 1: Wastewater System Operation Summary, Specific Requirements, and Limitations

Attachment 2: Figures

Attachment 3: Monitoring and Reporting Program No. R3-2024-0027

cc:

Ryan Smith, San Miguelito Mutual Water Company, Rsmith@smmwc.com

Office of Operator Certification, wwopcertprogram@waterboards.ca.gov

Jennifer Epp, Central Coast Water Board, Jennifer.Epp@Waterboards.ca.gov

Jesse Woodard, Central Coast Water Board, Jesse.Woodard@waterboards.ca.gov

James Bishop, Central Coast Water Board, James.Bishop@Waterboards.ca.gov

Anna Melvin, Central Coast Water Board, CentralCoastWaterBoard@waterboards.ca.gov

WDR Program, GeoTracker RB3-WDR@Waterboards.ca.gov

ECM/CIWQS = CW-272525

GeoTracker No. = GT- WDR100035521

Rev 6/1/23

ECM Subject Name = San Miguelito Mutual Water Company NOA for R3-2020-0020

San Miguelito Mutual Water Company
Wild Cherry Canyon Wastewater Treatment Plant

April 18, 2024

\\ca.epa.local\RB\RB3\Shared\WDR\WDR Facilities\San Luis Obispo Co\San Miguelito
Mutual Water Co. (Wild Cherry Cyn. WWTP)\1- Permit\Permit 2024 - Big Order\R3-
2020-0020 NOA San Miguelito_final.docx

ATTACHMENT 1
WASTEWATER SYSTEM OPERATION SUMMARY, SPECIFIC REQUIREMENTS,
AND LIMITATIONS

1. Ownership and Wastewater System Information

Ownership and wastewater system information submitted by San Miguelito Mutual Water Company to the Central Coast Water Board is shown in Table 1.

Table 1. Ownership and Wastewater System Information

Name	San Miguelito Mutual Water Company Wild Cherry Canyon WWTP
Physical Address	3560 Wild Cherry Canyon, San Luis Obispo, CA, 93405
Latitude	35.11'40"N
Longitude	120.45'35"W
Mailing Address	1561 Sparrow St. San Luis Obispo, CA, 93405
Owner	San Miguelito Mutual Water Company
Operator	Ryan Smith San Miguelito Mutual Water Company phone: (805) 595-2348 ext. 103 e-mail: rsmith@smmwc.com
Legally Responsible Official	Dwayne Chisam General Manager, San Miguelito Mutual Water Company phone: (805) 595-2348 ext. 101 [office]; (805) 264-5592 [cell] e-mail: Dchisam@smmwc.com
Raw Wastewater Characteristics	Sewer Connections: 649 Population Served: 1400 Domestic (%): 100% Industrial (%): 0%
Permitted Design Flow, Maximum Daily (gallons per day, gpd)	150,000
Baseline Flow (average annual flow) in gpd	75,000
Threat to Water Quality	2
Complexity	B
For Internal Use	
Fee Code	58
Primary Place Type	Wastewater Treatment Facility
Facility Type	Municipal/Domestic

Facility Waste Type	Domestic Wastewater
Regulatory measure Type	Enrollee - WDR
Reclamation Included	No
EPA Approved Pretreatment Program	No

2. Wastewater System Operation Summary

San Miguelito Mutual Water Company wastewater treatment facility (Wastewater System) is a Class I wastewater system. San Miguelito Mutual Water Company must staff a Class I chief plant operator for proper operation of the Wastewater System. The current chief plant operator is Ryan Smith, Grade II, License Number 28414.

The Wastewater System is capable of treating 150,000 gallons per day to a Secondary treatment level. The Wastewater System consists of the treatment technologies and treatment capabilities shown in Table 2.

Table 2. Treatment Technology and Capacity

Headworks/Preliminary Treatment	Hydro-dyne 6mm screen.
	Headworks capacity (gpd): 1,000,000
Primary Treatment	Aerated pond system
	Primary treatment capacity (gpd): 150,000
Secondary Treatment	Solids settling and stabilization/polishing ponds
	Secondary treatment capacity (gpd): 150,000
Tertiary Treatment	None
	Tertiary treatment capacity (gpd): None
Disinfection	None
	Disinfection Capacity (gpd): None
Wastewater Disposal Method	Percolation ponds.
	Total pond capacity (gallons): 1,980,000
Biosolids/Sludge Production and Handling	Ponds are dredged every 10 years, sludge is dewatered, and the biosolids are stored onsite ⁶ .
	Annual production of biosolids: 40-60 tons
	The ultimate destination of biosolids produced is Engel & Grey in Santa Maria, California

A summary of historic and recent average effluent concentrations is included in Table 3, which were reported in San Miguelito Mutual Water Company annual monitoring reports. The Central Coast Water Board used reported effluent water quality data to establish the effluent and groundwater limitations in section 3.

⁶ Title 40 Code of Federal Regulations allows biosolids to be stored onsite for up to two years.

Table 3. Effluent Water Quality for Select Constituents

Constituents	Units	Historical Average ^[2]	Annual Average for 2022 ^[3]
Biochemical Oxygen Demand, 5-Day	mg/L	36	36
Total Suspended Solids	mg/L	44	66
Total Dissolved Solids	mg/L	859	906
Chloride	mg/L	351	138
Sodium	mg/L	128	170
Sulfate	mg/L	389	186
Total Nitrogen	mg/L	45.1	25

[1] mg/L denotes milligrams per liter.

[2] Based on water quality data reported by San Miguelito Mutual Water Company in their 2019 to 2021 monitoring reports.

[3] Based on water quality data reported by San Miguelito Mutual Water Company in the 2022 Annual Monitoring Report.

3. Wastewater System Specific Requirements and Limitations

San Miguelito Mutual Water Company must operate the Wastewater System in accordance with the General Permit and this notice of applicability. San Miguelito Mutual Water Company must comply with the wastewater specific limitations specified in Table 4 through Table 6.

Flow limitations are shown in Table 4.

A. Flow Limitations:

Table 4. Flow Limitations

Flow	Units	Limit	Point of Compliance
Maximum Daily	Gallons per day	150,000	Influent
Maximum Average Monthly ^[1]	Gallons per day	150,000	Influent
Mean Monthly ^[2] (to disposal area)	Gallons per day	150,000	Effluent

[1] Average monthly to be calculated by the total discharge to the headworks by volume during a calendar month divided by the number of days in the month that the wastewater system headworks received flow.

[2] Mean monthly to be calculated by the total discharge to the disposal area by volume during a calendar month divided by the number of days in the month that the discharge to the disposal area occurred.

B. Effluent Limitations:

San Miguelito Mutual Water Company must comply with the wastewater specific effluent limitations specified in Table 5.

Table 5. Effluent Limitations: Treatment Ponds

Constituent	Units	30-Day Average	7-Day Average	Instantaneous Limit
Biochemical Oxygen Demand, 5-Day	mg/L ^{[1][2]}	45	65	Not Applicable
Total Suspended Solids	mg/L	45	65	Not Applicable
Settleable Solids	mL/L ^[3]	0.3	Not Applicable	0.5
pH	Not Applicable	Not Applicable	Not Applicable	Between 6.5 and 8.4

[1] mL/L denotes milliliters per liter.

C. Groundwater Limitations:

Based on review of historical effluent water quality (see Table 3), San Miguelito Mutual Water Company is unable to consistently comply with the General Permit effluent limitations for the constituents listed in table 6, thus the point of compliance for these constituents will be underlying groundwater.

Through groundwater monitoring, San Miguelito Mutual Water Company must demonstrate that the discharge does not cause underlying groundwater to exceed the water quality objectives set forth in the Basin Plan including the limitations listed in Table 6.

Table 6. Groundwater Limitations for Non-Designated Groundwater Basins

Constituents	Units	25-Month Rolling Median	Sample Maximum
Total Dissolved Solids	mg/L ^[1]	500	1000
Chloride	mg/L	250	500
Sodium	mg/L	250	Not Applicable
Sulfate	mg/L	250	500
Boron	mg/L	0.5	Not Applicable
Total Nitrogen	mg/L	10	Not Applicable

[1] mg/L denotes milligrams per liter

**ATTACHMENT 2
FIGURES**




Figure 1. Site Location Map

**ATTACHMENT 3
MONITORING AND REPORTING PROGRAM**

CENTRAL COAST REGIONAL WATER QUALITY CONTROL BOARD

MONITORING AND REPORTING PROGRAM R3-2024-0027

April 18, 2024

FOR

**SAN MIGUELITO MUTUAL WATER COMPANY WILD CHERRY CANYON
WASTEWATER TREATMENT PLANT**

AVILA BEACH, SAN LUIS OBISPO COUNTY

This Monitoring and Reporting Program contains monitoring and reporting requirements for San Miguelito Mutual Water Company's Wild Cherry Canyon Wastewater Treatment Plant (Wastewater System) enrolled in *General Waste Discharge Requirements Order R3-2020-0020 for Discharges from Domestic Wastewater Systems with Flows Greater than 100,000 Gallons per Day* (General Permit).

San Miguelito Mutual Water Company owns and operates the Wastewater System that is subject to the General Permit and notice of applicability.

The State Water Resources Control Board (State Water Board) and Regional Water Quality Control Boards are transitioning to the use of the publicly accessible State Water Board's GeoTracker database for the tracking of environmental and regulatory data for sites that operate under waste discharge requirements. The monitoring and reporting program directs San Miguelito Mutual Water Company to submit reports (both technical and monitoring reports) and analytical data electronically to the State Water Board's GeoTracker database (see monitoring and reporting program section 10).

1. SAMPLING AND ANALYSIS

San Miguelito Mutual Water Company must collect representative samples in accordance with the most recently approved sampling and analysis plan contained in the Operations and Maintenance Manual and validate analytical results prior to submittal to the Central Coast Regional Water Quality Control Board (Central Coast Water Board). All samples (e.g., wastewater, groundwater, soil, sludge) must be representative of the volume and nature of the discharge or matrix of materials sampled.

All samples must be collected by a qualified person, trained in proper procedures for collecting the samples. The name of the sampler, sample type (grab or composite),

time, date, location, bottle/container type, and any preservative used for each sample must be recorded on the sample chain of custody form. The chain of custody form must also contain all custody information including date, time, and to whom samples were relinquished. If composite samples are collected, the basis for sampling (time or flow weighted) must be included in the sampling and analysis plan contained in the Operations and Maintenance Manual for Central Coast Water Board review and approval.

A. Sampling Schedule

Unless otherwise specified below, sampling must be performed in accordance with Table 1.

Table 1. Sampling Schedule

Monitoring Period	Sample Collection Time
Monthly	Each month of the year
Quarterly	January, April, July, and October
Semiannually	April and October
Annually	October

Field test instruments (such as those used to test pH, dissolved oxygen, and electrical conductivity) may be used if they are used by a State Water Board Environmental Laboratory Accreditation Program accredited laboratory, or:

1. The user is trained in proper use and maintenance of the instruments;
2. The instruments are field calibrated prior to monitoring events at the frequency recommended by the manufacturer;
3. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency; and
4. Field calibration reports are maintained and available for at least three years.

B. Monitoring Location Descriptions – All samples including influent samples (IS), effluent samples (ES), and groundwater monitoring wells (MW) must be collected at the locations described in Table 2 and shown in Figure 1. These locations must be consistent with the Central Coast Water Board approved sampling and analysis plan. **San Miguelito Mutual Water Company must upload the GeoTracker field point information for each sampling location in the GeoTracker database once, prior to uploading laboratory data (see Table 12).**

Table 2. Sample Identification Details

GeoTracker Field Point Class	GeoTracker Field Point Name (Sample ID)	GeoTracker Field Point Description
Water Supply Well Sample ^[1]	WSW-1	Sample from the primary water supply well that provides water to the wastewater treatment system collection area.
Influent Sample	IS-1	Influent sample collected from the lined aeration pond
Effluent Sample	ES-2	Effluent sample collected prior to discharge from serpentine settling pond
Monitoring Well	MW-1	Groundwater Sample collected from upgradient monitoring well B1
Monitoring Well	MW-2	Groundwater sample collected from downgradient monitoring well B2
Monitoring Well	MW-3	Groundwater sample collected from downgradient monitoring well B3
Stream Headwater Source Sample	STR-1	Stream sample collected at the first occurrence of water discharging from the ground to the stream near the percolation ponds
Stream Terminus Sample	STR-2	Stream sample collected near the stream terminus at Avila Dog Beach

^[1] Water supply sample data should be included in the annual report but does not need to be uploaded to GeoTracker if the Central Coast Water Board approves submittal of a Well Identification Number pursuant to the Water Supply Monitoring section below.




Figure 1. Process Flow Diagram and Sample Locations Referenced in Table 2.



Figure 2. Map of STR-2 surface water sample location.

2. WATER SUPPLY MONITORING

Representative samples of San Miguelito Mutual Water Company's raw water supply (sampled before use or treatment) must be collected and analyzed, at a minimum, for constituents specified in Table 3.

In lieu of the required water supply sampling, San Miguelito Mutual Water Company may request Central Coast Water Board approval to submit a Well Identification Number and the reporting year's consumer confidence report (annual water quality report or drinking water quality report), as required by the State Water Board Division of Drinking Water and/or county, provided, at a minimum, all of the required constituents are sampled at the frequency specified in Table 3. San Miguelito Mutual Water Company must report the results of any constituent monitored more frequently than is required by the monitoring program shown in Table 3. San Miguelito Mutual Water Company must also report detectable concentrations (above the reporting limit) for any other constituent that has a published maximum contaminant level (MCL).

San Miguelito Mutual Water Company must evaluate and provide a tabular summary of the water supply data with the annual monitoring report.

Table 3. Water Supply Monitoring

Constituent	Units^[1]	Sample Type	Sampling Frequency
Nitrate (as N)	mg/L	Grab	Annually
Total Dissolved Solids	mg/L	Grab	Annually
Chloride	mg/L	Grab	Annually
Sodium	mg/L	Grab	Annually
Sulfate	mg/L	Grab	Annually
Boron	mg/L	Grab	Annually
Carbonate	mg/L	Grab	Annually
Bicarbonate	mg/L	Grab	Annually
Calcium	mg/L	Grab	Annually
Potassium	mg/L	Grab	Annually
Magnesium	mg/L	Grab	Annually

[1] mg/L denotes milligrams per liter.

3. INFLUENT AND EFFLUENT MONITORING

A. Influent and Effluent Flow Monitoring

San Miguelito Mutual Water Company must monitor and report flow in gallons per day, as described in Table 4, with each monitoring report. See monitoring and reporting program section 8 for supplemental volumetric annual reporting requirements established by the State Water Board.

Table 4. Influent and Effluent Flow Monitoring

	INFLUENT (IS-1)	INFLUENT (IS-1)	EFFLUENT (ES-2)	EFFLUENT (ES-2)
Parameter	Sample Type	Sampling Frequency	Sample Type	Sampling Frequency
Daily Flow	Metered	Daily	Estimated	Daily
Monthly Average Flow ^[2]	Calculated	Monthly	Calculated	Monthly
Percent of Permitted Flow ^[2]	Calculated	Quarterly	N/A	N/A

- [1] Monthly Average Flow to be calculated by the total flow by volume during a calendar month divided by the number of days in the month that the wastewater system received flow.
- [2] The General Permit notice of applicability specifies the Wastewater System's maximum permitted flow. In the monitoring reports, San Miguelito Mutual Water Company must evaluate and provide a comparison of monitored flow to the permitted flow.

B. Wastewater System Monitoring

Representative samples of San Miguelito Mutual Water Company's influent (raw wastewater) into the Wastewater System and effluent (treated wastewater) discharged to land must be collected and analyzed in accordance with the treatment technology-based monitoring requirements (including sample type and frequency) summarized in the tables below. See Figures 1 and 2 for the location of samples and GeoTracker field points. **Influent and Effluent Monitoring** – At a minimum, influent and effluent constituent monitoring for pond treatment systems must be monitored as specified in Table 5.

Table 5. Influent and Effluent Monitoring for Pond Treatment Systems

		INFLUENT (IS-1)	INFLUENT (IS-1)	EFFLUENT (ES-2)	EFFLUENT (ES-2)
Parameter/ Constituent	Units	Sample Type	Sampling Frequency	Sample Type	Sampling Frequency
pH	pH units	Grab	Weekly	Grab	Weekly
Dissolved Oxygen	mg/L	Grab	Weekly	Grab	Weekly
Biochemical Oxygen Demand, 5-Day	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Total Suspended Solids	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Settleable Solids	ml/L ^[1]	Not Applicable	Not Applicable	Grab	Weekly
Total Nitrogen ^[2]	mg/L	Calculated	Quarterly	Calculated	Quarterly
Nitrate (as N) + Nitrite (as N) or separate species	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Total Kjeldahl Nitrogen (as N)	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Ammonia (as N)	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Total Dissolved Solids	mg/L	24-hour composite	Quarterly	Grab	Quarterly

		INFLUENT (IS-1)	INFLUENT (IS-1)	EFFLUENT (ES-2)	EFFLUENT (ES-2)
Parameter/ Constituent	Units	Sample Type	Sampling Frequency	Sample Type	Sampling Frequency
Chloride	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Sodium	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Sulfate	mg/L	24-hour composite	Quarterly	Grab	Quarterly
Boron	mg/L	Not Applicable	Not Applicable	Grab	Quarterly
Carbonate	mg/L	Not Applicable	Not Applicable	Grab	Semiannually
Bicarbonate	mg/L	Not Applicable	Not Applicable	Grab	Semiannually
Calcium	mg/L	Not Applicable	Not Applicable	Grab	Semiannually
Potassium	mg/L	Not Applicable	Not Applicable	Grab	Semiannually
Magnesium	mg/L	Not Applicable	Not Applicable	Grab	Semiannually

[1] ml/L denotes milliliters per liter.

[2] Total nitrogen is the sum of total inorganic nitrogen (nitrate + nitrite + ammonium + ammonia) and organic nitrogen.

C. Pond System Monitoring

Required Pond Monitoring – All wastewater treatment and treated wastewater storage/disposal ponds (lined and unlined) must be monitored as specified in Table 6. Sampling for pH and dissolved oxygen must be a grab sample taken from 1 foot below pond surface.

Observations do not need to be reported in the monitoring reports unless a violation, significant change, or treatment issue is observed. Photos of the pond(s) verifying the observations must be collected annually and included in the annual report, with the date and location of the photo clearly marked. Observations must be noted in a logbook or database and made available to the Central Coast Water Board upon request. Any problems must be promptly corrected and recorded.

Table 6. Wastewater Treatment Pond Monitoring

Parameter/ Constituent	Units	Sample Type	Sampling/Monitoring Frequency	Ponds to Monitor
Freeboard	0.1 feet	Measured	Weekly	Ponds 1, 2, 3
Sludge Depth	0.1 feet	Measured	Annually	Ponds 1, 2, 3
Color	Not applicable	Observation	Monthly	Ponds 1, 2, 3
Vegetation in and surrounding ponds	Not Applicable	Observation	Monthly	Ponds 1, 2, 3
Berm condition	Not Applicable	Observation	Monthly	Ponds 1, 2, 3
Precipitation	inches/day and date	Measured ^[1]	Each precipitation event ^[2]	Ponds 1, 2, 3

[1] San Miguelito Mutual Water Company may use a rain gauge or use a National Oceanic and Atmospheric Administration, United States Geological Survey, or California Irrigation Management Information System weather station, such as <http://scacis.rcc-acis.org/>.

[2] A precipitation event is one producing precipitation of ½ inch or more.

D. Serpentine Settling Pond (Pond 3) Berm Monitoring

San Miguelito Mutual Water Company shall monitor the location of the western bank of Wild Cherry Canyon Creek in relation to the berm on the eastern side of the serpentine settling pond (pond 3). Wild Cherry Canyon Creek has the potential to erode the toe of the berm and destabilize the settling pond. San Miguelito Mutual Water Company must take measurements of the location of the western edge of the creek (e.g., coordinates) and of the distance from the western edge of the creek to the toe and crest of the settling pond berm. San Miguelito Mutual Water Company shall inspect the eastern edge of the berm and western bank of the creek for cracks, saturated soil, seepage, or other signs of instability. Signs of instability must immediately be reported to the Central Coast Water Board. Monitoring of the serpentine settling pond berm shall be consistent with Table 7.

Table 7. Serpentine Settling Pond Monitoring Parameters and Frequencies

Parameter	Units	Sample Type	Minimum Sampling Frequency
Coordinates of Western Edge of Creek	WGS 84 – Decimal Degrees	GPS	Monthly During Winter Months ^[1]

Parameter	Units	Sample Type	Minimum Sampling Frequency
Distance From Serpentine Settling Pond Berm Toe to Bank of Creek	Feet	Tape Measure	Monthly During Winter Months
Distance From Serpentine Settling Pond Berm Crest to Bank of Creek	Feet	Tape Measure	Monthly During Winter Months
Signs of Instability in Western Edge of Creek Bank or Eastern Berm of Settling Pond	–	Observation	Monthly
Photographs of the Western Edge of the Creek and Eastern Berm of Settling Pond	–	Photograph	Annually

[1] Winter months are October to April

4. WASTEWATER DISPOSAL MONITORING

San Miguelito Mutual Water Company must monitor all wastewater disposal ponds (ponds 4 through 7) when wastewater and/or supplemental irrigation water is applied. Inspections (observations) must be conducted as described in Table 8. A log of these inspections must be maintained onsite and made available to Central Coast Water Board upon request. Observations do not need to be reported in the monitoring reports unless a violation of permit conditions or issues are observed. If violations are observed, planned and implemented mitigation measures to address the violations must be reported.

San Miguelito Mutual Water Company must evaluate and summarize wastewater disposal application rates, loading rates (pounds/acre/day), violations found during the inspections, with each monitoring report.

If wastewater and/or supplemental irrigation water is not discharged to land during a reporting period, the monitoring report must still be submitted and indicate that there was no discharge during the reporting period.

Table 8. Wastewater Disposal Monitoring

Constituent	Units	Sample Type	Monitoring Frequency
Application Rate	Gallons per day	Metered/Estimated ^[1]	Daily
Freeboard	Feet	Measured	Weekly
Local Precipitation	Inches/day	Weather Station ^[2]	Each precipitation event
Acreage Applied ^[3]	Acres	Measured	Daily
Disposal Pond Number	NA	Recorded	Daily
Average Monthly Biochemical Oxygen Demand, 5-Day (BOD) Applied ^[4] ^[5]	lbs/acre/day	Calculated	Monthly
Maximum BOD ₅ Applied ^[5]	lbs/acre/day	Calculated	Monthly
Total Nitrogen Applied ^[4] ^[5]	lbs/acre/day	Calculated	Monthly
Salts Applied ^[4] ^[5] (total dissolved solids, sodium, chloride)	lbs/acre/day	Calculated	Monthly
Soil Erosion Evidence	Not Applicable	Observation	Monthly
Containment Berm Condition	Not Applicable	Observation	Monthly
Soil Saturation/Ponding	Not Applicable	Observation	Monthly
Nuisance Odors/Vectors	Not Applicable	Observation	Monthly
Discharge Offsite	Not Applicable	Observation	Monthly

[1] Estimate based on influent flow meter reading.

[2] San Miguelito Mutual Water Company must have a rain gauge or use a NOAA or USGS rain station, such as <http://scacis.rcc-acis.org/>.

[3] Acreage applied denotes the acreage to which wastewater is applied.

- [4] The total nitrogen, salts, and BOD applied loading rates must be calculated from wastewater flow volumes, applied acreage, and concentrations reported in effluent analytical testing as follows:

Total Nitrogen/Salts/BOD Applied (pounds/acre/ day) =

$$\frac{X \text{ [mg/L]} \times Q \text{ [million gallons per day]} \times 8.34 \text{ [(conversion from mg/L to pounds/million gallons per day)]}}{\text{Acreage Applied [acres]}}$$

Where X = Total nitrogen, salts, or BOD concentration

Where Q = Application Rate (often effluent flow rate)

- [5] Frequencies of analytical testing are defined in the influent and effluent monitoring tables (Table 5).

5. SLUDGE/BIOSOLIDS DISPOSAL MONITORING

San Miguelito Mutual Water Company must report the handling and disposal of all sludge/biosolids generated at the Wastewater System. Records must include the date removed from the Wastewater System, name/contact information for the hauling company, the type and volume of waste transported, the disposal facility name and address, and copies of analytical data required by the entity accepting the waste. These records must be submitted as part of the annual monitoring report.

San Miguelito Mutual Water Company must also monitor sludge/biosolids consistent with a Central Coast Water Board approved sludge management plan and in accordance with the requirements specified by the receiving party, including a regulated landfill and/or regulated composting facility.

If sludge/biosolids are not removed during the year, San Miguelito Mutual Water Company must explain the absence of this monitoring in the annual report.

6. GROUNDWATER MONITORING

San Miguelito Mutual Water Company must implement a groundwater monitoring program to demonstrate compliance with the groundwater limitations in the notice of applicability and water quality objectives specified in the Basin Plan. Groundwater monitoring reports, workplans, and other technical reports that interpret groundwater data must be prepared and stamped by a California licensed civil engineer or professional geologist.

San Miguelito Mutual Water Company must:

- A. All monitoring wells listed in Table 2 must be, at a minimum, sampled and analyzed as specified in Table 9 and the Central Coast Water Board approved sampling and analysis plan (see section VI.A.2.i of the General Permit).

- B. Prior to sampling, depth to groundwater must be measured and groundwater elevations⁷ must be calculated. The monitoring wells must be purged of at least three well volumes and until measurements of the following parameters have stabilized (i.e., are reproducible within 10 percent): pH, temperature, dissolved oxygen, electrical conductivity, and turbidity. No-purge, low-flow, or other sampling techniques are acceptable only if they are approved in advance by the Central Coast Water Board and described in an approved sampling and analysis plan. Once the groundwater level in each of the wells has recovered sufficiently to ensure the collection of representative groundwater samples, a qualified individual (e.g., consultant, technician) trained in using proper sampling methods must recover samples using approved USEPA methods. Laboratories analyzing groundwater samples must be accredited by the State Water Board Environmental Laboratory Accreditation Program, in accordance with California Water Code section 13176, and must include quality assurance/quality control data with their reports.

San Miguelito Mutual Water Company must provide monitoring well field sheets and report monitoring data, as described in Table 9, with each monitoring report.

Table 9. Groundwater Monitoring

Constituent	Units	Sample Type	Sampling Frequency
Groundwater Elevation ^[1]	0.01 ft msl	Calculated	Semiannually
Depth to Groundwater ^[1]	0.01 ft bgs	Measurement	Semiannually
pH	pH Units	Metered	Semiannually
Dissolved Oxygen	mg/L	Metered	Semiannually
Electrical Conductivity	µS/cm ^[2]	Metered	Semiannually
Oxidation Reduction Potential	mV ^[3]	Metered	Semiannually
Temperature	degrees Celsius	Metered	Semiannually
Gradient ^[4]	feet/foot	Calculated	Semiannually
Groundwater Flow Direction ^[4]	degrees	Calculated	Semiannually
Total Nitrogen ^[5]	mg/L	Calculated	Semiannually
Nitrate (as N)	mg/L	Grab	Semiannually

⁷ The locations and top-of-casing elevations for the existing groundwater monitoring wells must be surveyed by a licensed land surveyor if not already completed at the time of installation.

Constituent	Units	Sample Type	Sampling Frequency
Nitrite (as N)	mg/L	Grab	Semiannually
Total Kjeldahl Nitrogen (as N)	mg/L	Grab	Semiannually
Ammonia (as N)	mg/L	Grab	Semiannually
Total Coliform	mg/L	Grab	Semiannually
Total Dissolved Solids	mg/L	Grab	Semiannually
Chloride	mg/L	Grab	Semiannually
Sodium	mg/L	Grab	Semiannually
Sulfate	mg/L	Grab	Semiannually
Boron	mg/L	Grab	Semiannually
Carbonate	mg/L	Grab	Semiannually
Bicarbonate	mg/L	Grab	Semiannually
Calcium	mg/L	Grab	Semiannually
Potassium	mg/L	Grab	Semiannually
Magnesium	mg/L	Grab	Semiannually

[1] ft.msl denotes feet above mean sea level and ft bgs denotes feet below ground surface.

[2] $\mu\text{S/cm}$ denotes microsiemens per centimeter.

[3] mV denotes millivolts.

[4] Calculations must be prepared by, or under the responsible charge of, a California licensed professional.

[5] Total nitrogen is the sum of total inorganic nitrogen (nitrate + nitrite + ammonium + ammonia) and organic nitrogen.

7. SURFACE WATER MONITORING

Representative samples of surface water shall be consistent with Table 10.

Table 10. Surface Water Monitoring Constituents, Frequencies, and Sample Locations

Constituent	Units	Sample Type	Minimum Sampling Frequency	Sample Location
Sample Location	WGS 84 ^[1] - Decimal Degrees	GPS ^[2]	Semiannually	STR-1, STR-2

Constituent	Units	Sample Type	Minimum Sampling Frequency	Sample Location
Dissolved Oxygen	mg/L	Meter	Semiannually	STR-1, STR-2
pH	std units	Meter	Semiannually	STR-1, STR-2
Total Dissolved Solids	mg/L	Grab	Semiannually	STR-1, STR-2
Total Coliform	MPN/100 mL	Grab	Semiannually	STR-1, STR-2
Nitrate + Nitrate	mg/L	Grab	Semiannually	STR-1, STR-2
Total Kjeldahl Nitrogen	mg/L	Grab	Semiannually	STR-1, STR-2
Total Nitrogen	mg/L	Calculated	Semiannually	STR-1, STR-2

[1] WGS 84 denotes the World Geodetic System of 1984

[2] GPS denotes global positioning system

8. REPORTING REQUIREMENTS

A. Semiannual and Annual Monitoring Reports

Semiannual and annual monitoring reports are due as described in Table 11.

Table 11. Semiannual and Annual Monitoring Reporting

Report	Monitoring Period	Report Due Date
First Semiannual Monitoring Report	January 1 to June 30	May
Second Semiannual Monitoring Report	July 1 to December 31	March 1
Annual Report	January 1 to December 31	March 1
State Water Board Volumetric Annual Reporting	January 1 to December 31	April 30

1. **Semiannual Monitoring Reporting** – At a minimum, the semiannual reports must include:

- i. Results of all required monitoring in tabular format.
- ii. The results of any pollutant or parameter monitored more frequently than is required by this monitoring program. Values obtained through additional monitoring must be used in calculations as appropriate.

- iii. A comparison of monitoring data to the discharge specifications, applicable effluent limitations, disclosure of any violations of the notice of applicability and/or General Permit, and an explanation of any violation of those requirements. **San Miguelito Mutual Water Company must calculate 7-day averages, 30-day averages and 25-month rolling medians for select analytes when comparing monitoring data to applicable effluent limitations specified in the General Permit.** Data must be presented in tabular format.
 - iv. Copies of laboratory analytical report(s) and chain of custody form(s).
 - v. Copies of groundwater monitoring well field sheets with purge methods and data.
2. **Annual Reporting** – San Miguelito Mutual Water Company must submit annual reports in compliance with Standard Provisions 2013⁸, (and any updates to the Standard Provisions) Section C, General Reporting Requirements, Item 16 using the most recent annual report template provided by Central Coast Water Board.
- The current annual report template can be found here:
- https://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/2020/wdr_annual_report_format.pdf
- i. San Miguelito Mutual Water Company must include a discussion of the location of Wild Cherry Creek in relation to the serpentine settling pond berm in the annual report. This should include a description and photos of changes in the creek morphology or scouring.
 - ii. San Miguelito Mutual Water Company must include the following operator information with the annual report:
 - a. The name, grade, and license number for the wastewater operator responsible for operation, maintenance, and system monitoring, and all operator personnel.
 - b. A copy of the current Office of Operator Certification Wastewater Treatment Plant Classification Form.
 - c. A copy of the current Office of Operator Certification Chief Plant Operator Acknowledgement Form.
 - d. If a contract operator is used, a copy of the contract operator certificate from the Office of Operator Certification.
3. **State Water Board Volumetric Annual Reporting** – San Miguelito Mutual Water Company must electronically certify and submit a summary of the monthly

⁸ See Attachment E, Standard Provisions, 2013:
https://www.waterboards.ca.gov/centralcoast/board_decisions/docs/wdr_standard_provisions_2013.pdf

influent and effluent flow volume by April 30th of each calendar year via the State Water Board's Internet GeoTracker database.⁹

The following information is required:

- i. Monthly volume of wastewater collected and treated by the wastewater treatment plant (i.e. total monthly influent volume).
- ii. Monthly volume of wastewater treated, specifying level of treatment, including treated wastewater discharged.
- iii. If applicable, monthly volume of recycled water distributed, and annual volume of treated wastewater distributed for beneficial use in compliance with California Code of Regulations, title 22 use categories.

Additional information about volumetric annual reporting of wastewater and recycled water and the Recycled Water Policy is available at the Recycled Water Policy Volumetric Annual Reporting Website¹⁰.

9. NON-COMPLIANCE REPORTING:

San Miguelito Mutual Water Company must notify and report to Central Coast Water Board noncompliance of limits related to pond freeboard, flow rate, bypass or overflow, and wastewater containment failure, pursuant to General Permit section VI.C.2.

10. ELECTRONIC GEOTRACKER SUBMITTAL

All monitoring reports must be provided electronically in a searchable PDF format, with the Central Coast Water Board's current transmittal sheet found at the link below as the cover page. The transmittal sheet must be signed.

https://www.waterboards.ca.gov/centralcoast/water_issues/programs/wastewater_permiiting/docs/transmittal_sheet.pdf

San Miguelito Mutual Water Company must submit all reports/documents and laboratory analytical data to the State Water Board's GeoTracker^{11,12} database consistent with applicable Electronic Submittal of Information (ESI) requirements under the Wastewater System-specific global identification number **WDR10035521** at:

⁹ See: <https://geotracker.waterboards.ca.gov/>

¹⁰ See: [Volumetric Annual Reporting | California State Water Resources Control Board](#)

¹¹ Information for first-time GeoTracker users is available at:

https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguide2.pdf

¹² Additional information available at:
<https://geotracker.waterboards.ca.gov/>

<https://geotracker.waterboards.ca.gov/esi/login>

For general questions, please contact the GeoTracker Help Desk at:
geotracker@waterboards.ca.gov.

Table 12 summarizes all the GeoTracker electronic reporting requirements. Central Coast Water Board may request submittal of some documents on paper, particularly drawings or maps that require a large size to be readable, or in other electronic formats where evaluation of data is required.

Table 12. GeoTracker Electronic Submittal Information Data Requirements

Electronic Submittal	Description of Action	Action	Frequency
Reports and Documents	Complete copy of all documents including monitoring reports (in searchable PDF format) and any other associated documents related to the Wastewater System.	Upload directly to GeoTracker all monitoring reports (in searchable PDF format) and any other associated documents.	On or before the due dates required by this General Permit and for other documents when required by the Central Coast Water Board.
Laboratory Data	All analytical data (including geochemical data) in electronic deliverable format (EDF). This includes all water, soil, and vapor samples collected when monitoring a discharge.	Upload, or direct your California ELAP-accredited laboratory staff to upload, all EDF laboratory data directly to GeoTracker.	On or before the due date of the required monitoring report.
Depth to Groundwater	Monitoring wells must have the depth-to-water information reported. Report data only for wells defined as permanent sampling points.	Upload depth-to-water information to the GeoTracker GEO_WELL file.	On or before the due date of the required monitoring report.
Boring Logs and Well Screen Intervals	Boring logs must be prepared by a registered professional and submitted in PDF format separately (not only as attachments to reports).	Upload boring logs (in searchable PDF format) to GeoTracker GEO_BORE file whenever a new boring is drilled.	Every time a new boring is drilled.

Electronic Submittal	Description of Action	Action	Frequency
Field Points, Location Data (Geo XY) ^[1]	Name, classify, and identify the location (latitude and longitude) of all sampling points. Monitoring wells must be surveyed, influent and effluent sample locations must be identified on the GeoTracker mapping tool under “non-surveyed data.” These data points are required prior to laboratory data uploads.	Upload the location data (surveyed and non-surveyed) to the GeoTracker Geo_XY file.	Every time a permanent monitoring point is established.
Elevation Data (Geo Z) ^[2]	Survey and mark the elevation at the top of groundwater well casings for all permanent groundwater wells. These points are required prior to depth-to-water data uploads.	Upload the survey data to the GeoTracker GEO_Z file.	One-time, for all groundwater monitoring wells.
Geo Map	Site layout, map of facilities, Wastewater System including treatment and disposal area(s).	Upload the Site layout PDF to the GeoTracker site plan file.	Year one and every five years thereafter and when the facilities are modified.

[1] Geo XY required for all wells. New wells must be surveyed. For existing wells, use original well installation survey data. San Miguelito Mutual Water Company must also upload sample locations (e.g., influent and effluent samples) that are not defined as a **permanent monitoring well** and have not been surveyed by a licensed professional.

[2] Geo Z required for all wells. New wells must be surveyed. For existing wells, use original well installation survey data.

11. TECHNICAL REPORTS

The technical reports are due as described in Table 13.

Table 13. Technical Report Submittal Due Dates

Report	Report Due Date
Operations and Maintenance Manual	April 18, 2025

Report	Report Due Date
Climate Change Adaptation Plan	April 18, 2026
Time Schedule Compliance Plan	April 18, 2025
Capital Improvement Plan	April 18, 2025

A. Operations and Maintenance Manual

In addition to the required components specified in Standard Provisions¹³ A.12 and A.28 (and any updates to the Standard Provisions) and General Permit section VI.A.2, the Operations and Maintenance Manual must contain the following components. Each component must contain an implementation schedule and identification of adequate funding to implement the component.

1. **Sampling and Analysis Plan** – San Miguelito Mutual Water Company's Operation and Maintenance Manual must contain a sampling and analysis plan that meets the requirements specified herein. Anyone performing sampling on behalf of San Miguelito Mutual Water Company must be familiar with the sampling and analysis plan. At a minimum, the sampling and analysis plan must contain the following:
 - i. A wastewater treatment process flow schematic with the monitoring locations labeled and scaled Wastewater System maps with treatment components, discharge locations (both treated wastewater and non-potable recycled water), monitoring locations, groundwater wells, storage locations (e.g., chemical, sludge, emergency overflow ponds), and buildings. (if San Miguelito Mutual Water Company needs to update Figure 1 to comply with this requirement, a copy of the updated process flow schematic will also be included with the annual report).
 - ii. Sample identification details in tabular format. The table must include the sample titles, GeoTracker field point information, sample description(s), and sampling frequencies.
 - iii. Sample chain-of-custody procedures and documentation.
 - iv. Sample handling/preservation procedures.
 - v. A description of the analytical methods.
 - vi. A description of sample containers, preservatives, and holding times.
 - vii. For water supply monitoring, a description of the location and method of data collection (e.g., onsite well sampling, use of consumer confidence report).

¹³ See Attachment E, Standard Provisions, 2013:

https://www.waterboards.ca.gov/centralcoast/board_decisions/do-cs/wdr_standard_provisions_2013.pdf

- viii. For groundwater monitoring, a description of the well purging and field methods.
2. **Sludge Management Plan** – San Miguelito Mutual Water Company’s Operation and Maintenance Manual must contain a sludge management plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. At a minimum, the plan must describe the following:
- i. An estimated volume/amount and quality of sludge and scum that will be generated.
 - ii. How sludge, scum, and supernatant will be stored and disposed of to protect groundwater quality.
 - iii. If sludge will be subject to further treatment, describe the treatment and storage requirements.
 - iv. Procedures for cleaning of digesters or storage vessels and the treatment and disposal of the residuals. If drying of residuals is planned, describe how that will be performed to prevent nuisance odors, prevent vectors, and protect groundwater quality.
3. **Wastewater Disposal Management Plan** – San Miguelito Mutual Water Company’s Operation and Maintenance Manual must contain a wastewater disposal management plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. At a minimum, the wastewater disposal management plan must include:
- i. A description of the wastewater disposal area and a map denoting acreage.
 - ii. Loading calculations based on flow volumes, applied acreage, and biochemical oxygen demand, salts (total dissolved solids, sodium, chloride, sulfate, boron), and nitrogen analytical results.
 - iii. If sleep A description of wastewater disposal and water quality protection practices.
4. **Spill Prevention and Emergency Response Plan** – San Miguelito Mutual Water Company’s Operation and Maintenance Manual must contain a spill prevention and emergency response plan that is sufficient to ensure compliance with the terms of the General Permit and the notice of applicability. The spill prevention and emergency response plan must describe operation and maintenance activities to prevent accidental releases of wastewater and to effectively respond to such releases and minimize the environmental impact. At a minimum, the spill prevention and emergency response plan must address the following:
- a. Operation and Control of Wastewater System - A description of the wastewater treatment equipment, operational controls, flow measurement and calibration procedures, and treatment system schematic including valve/gate locations.

- b. Sludge Handling - A description of the sludge handling equipment, operational controls, and disposal procedures.
- c. Collection System Maintenance - A description of collection system cleaning and maintenance, equipment tests, and alarm functionality tests to minimize the potential for wastewater spills originating in the collection system or headworks. For collection systems subject to State Water Board Order WQ 2022-0103-DWQ, Statewide Waste Discharge Requirements General Order for Sanitary Sewer Systems (or its replacement), reports prepared to comply with State Water Board Order WQ 2022-0103-DWQ satisfy this requirement.
- d. Emergency Response - A description of emergency response procedures including for emergencies such as power outage, severe weather, flooding, or inadequate freeboard (for systems with wastewater treatment, storage, or disposal ponds or treated non-potable recycled water storage ponds). An equipment and telephone list for contractors/consultants, emergency personnel, and equipment vendors.
- e. Finance - At a minimum, discuss current fees, projected fees, current budget for spill prevention and emergency response, projected budget for spill prevention and emergency response.
- f. Notification Procedures - Coordination procedures with fire, police, Governor's Office of Emergency Services (CalOES), Central Coast Water Board, and local county health department personnel.
- g. Training Records Log – San Miguelito Mutual Water Company's Operation and Maintenance Manual must contain updated training records logs that demonstrates San Miguelito Mutual Water Company is complying with General Permit section VI.B.3.

B. Climate Change Adaptation

The Climate Change Adaptation Plan must, at a minimum, include the following components:

- 1. Hazards and Vulnerabilities** – Identify climate change hazards, at a minimum accounting for the hazards listed below, applicable to the Wastewater System. Using up-to-date tools, data, and guidance from the State of California (e.g., Cal-Adapt¹⁴, Sea-Level Rise Guidance from Ocean

¹⁴ Cal-Adapt is an online resource with downscaled climate project data. It provides users with projections and more detailed downloadable data supporting a range of needs and array of climate models and emissions scenarios. Cal-Adapt offers climate projections for the major stressors facing California, including the following: temperature averages and extremes, precipitation averages and extremes, sea-level rise, wildfires, and drought. The Governor's Office of Planning and Research (OPR) recommends agencies use Representative Concentration Pathway (RCP) 8.5 for analyses considering impacts through

Protection Council, reports from the Climate-Safe Infrastructure Working Group, the Climate Adaptation Planning Guide, and California Climate Assessment Regional Reports), assess the Wastewater System's vulnerability to identified hazards that could cause reduction, loss, or failure of treatment processes and/or critical structures at the Wastewater System. Identify and justify the resources (e.g., models and tools, design parameters) used to inform identification of these hazards and vulnerabilities. If

- i. Sea Level Rise – Saltwater intrusion, flooding and inundation, and increased coastal erosion.
- ii. Precipitation Pattern Changes.
 - I. Drought – Decreased influent quantity and quality.
 - II. Peak Events – Flooding and increased influent quantity.
- iii. Temperature fluctuations and extremes.
- iv. Increased wildfires.
- v. Increased power outages.

2. Resiliency Actions – Identify actions to build Wastewater System and operational resilience to identified vulnerabilities, accounting for options that minimize resource impacts.

C. Time Schedule Compliance Plan

As set forth in General Permit sections V.A and VI.A.5, if San Miguelito Mutual Water Company anticipates that they cannot achieve compliance with the effluent limitations, San Miguelito Mutual Water Company must prepare and submit for Central Coast Water Board review and approval, a time schedule compliance plan. At a minimum, the time schedule compliance plan must address the following:

1. Comparison of the current effluent quality to the effluent and groundwater limitations in General Permit Tables 3-6. A detailed description and chronology of efforts, since issuance of the notice of applicability, to reduce wastes.
2. Justification of the need for additional time to achieve the effluent limitations in General Permit Tables 3-6.
3. A detailed time schedule of specific actions San Miguelito Mutual Water Company will take to achieve the effluent limitations.
4. A demonstration that the time schedule requested is as short as possible, considering the technological, operation, and economic factors that affect the

2050, because there are minimal differences between emissions scenarios during the first half of the 21st century.

design, development, and implementation of the measures that are necessary to comply with the effluent limitation(s).

5. If the requested time schedule exceeds one year, the proposed schedule shall include interim requirements and the date(s) for their achievement. The interim requirements shall include both of the following:
 - i. Effluent limitation(s) for the pollutant(s) of concern.
 - ii. Actions, measurable milestones, and tangible products leading to compliance with the effluent limitation(s).

D. Capital Improvements Plan

San Miguelito Mutual Water Company must prepare and submit a Capital Improvement Plan. The Capital Improvement Plan must contain all significant capital projects, equipment purchases, and major studies for operating the San Miguelito Mutual Water Company's Wastewater System. In general, the Capital Improvement Plan will include the following elements:

1. Estimated overall cost of each project
2. Estimated operational and maintenance cost for each project
3. Estimated project timelines
4. Funding sources
5. Project prioritization

12. LEGAL REQUIREMENTS

The Central Coast Water Board requires San Miguelito Mutual Water Company to submit the technical and monitoring reports described in this monitoring and reporting program pursuant to [California Water Code section 13267](#). Failure to submit reports in accordance with the schedules established by the Permit or failure to submit a report of sufficient technical quality to be acceptable to the Central Coast Water Board may subject San Miguelito Mutual Water Company to enforcement action pursuant to [California Water Code section 13268](#).

The burden, including costs, of the reports bears a reasonable relationship to their need and the benefits to be obtained. The requirement for the reports is necessary to ensure compliance with the Permit and to protect water quality. San Miguelito Mutual Water Company is required to submit this information because it is subject to the Permit and is responsible for the discharge.

San Miguelito Mutual Water Company must implement the above monitoring program on July 1, 2024. Until July 1, 2024, San Miguelito Mutual Water Company must continue to implement monitoring and reporting program No. 95-57. The Central Coast Water Board may rescind or modify the monitoring and reporting program at any time. San Miguelito Mutual Water Company must not implement any changes to this monitoring and reporting program unless and until a revised monitoring and reporting program is issued by the Central Coast Water Board.

Ordered By:

 Digitally signed by Jennifer
Epp
Date: 2024.04.18 09:35:12
-07'00'
Water Boards

for Ryan E. Lodge
Executive Officer

\\ca.epa.local\RB\RB3\Shared\WDR\WDR Facilities\San Luis Obispo Co\San Miguelito
Mututal Water Co. (Wild Cherry Cyn. WWTP)\1- Permit\Permit 2024 - Big Order\R3-
2020-0020 NOA San Miguelito_final.docx

rev: 12/5/2023