



EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

Central Valley Regional Water Quality Control Board

23 July 2018

Jesse Hampton
Calaveras County Water District
P.O. Box 846
San Andreas, CA 95249

CERTIFIED MAIL
91 7199 9991 7036 7006 7303

NOTICE OF APPLICABILITY

GENERAL WASTE DISCHARGE REQUIREMENTS FOR SMALL DOMESTIC WASTEWATER TREATMENT SYSTEMS ORDER WQ 2014-0153-DWQ

FOR

CALAVERAS COUNTY WATER DISTRICT WILSEYVILLE WASTEWATER TREATMENT PLANT CALAVERAS COUNTY

The Calaveras County Water District (CCWD, Discharger) submitted a Report of Waste Discharge dated 14 November 2017 describing Wilseyville Wastewater Treatment Plant (WWTP) in Calaveras County. Based on the provided information, the domestic wastewater treatment system and discharge at the WWTP is consistent with the requirements of the State Water Resources Control Board (State Water Board) *General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems*, Order WQ 2014-0153-DWQ (General Order). This Notice of Applicability (NOA) provides notice that the General Order is applicable to the site as described below. You are hereby assigned Order WQ 2014-0153-DWQ-R5279 for the discharge. A copy of the General Order is enclosed and also available at:

http://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wgo2014_0153_dwq.pdf

You should familiarize yourself with the entire General Order and its attachments, which describe mandatory discharge and monitoring requirements. The General Order contains operational and reporting requirements by wastewater system type. Sampling, monitoring, and reporting requirements applicable to your treatment and disposal methods must be completed in accordance with the appropriate treatment system sections of the General Order and the attached Monitoring and Reporting Program (MRP) WQ 2014-0153-DWQ-R5279. The Discharger is responsible for all the applicable requirements that exist in the General Order and this NOA.

KARL E. LONGLEY SCD, P.E., CHAIR | PATRICK PULUPA, ESQ., EXECUTIVE OFFICER

11020 Sun Center Drive #200, Rancho Cordova, CA 95670 | www.waterboards.ca.gov/centralvalley

REGULATORY BACKGROUND

WDRs 98-044, adopted by the Central Valley Regional Water Quality Control Board (Central Valley Water Board) on 27 February 1998, prescribes requirements for the wastewater treatment system and allows a monthly average dry weather discharge flow of 9,000 gallons per day (gpd). WDRs Order 98-044 is proposed to be rescinded at the **4/5 October 2018** meeting of the Central Valley Water Board. Effective upon rescission of Order 98-044, the discharge described in this NOA shall be regulated pursuant to the General Order.

EXISTING FACILITY AND DISCHARGE DESCRIPTION

The WWTP is located at 4027 Railroad Flat Road in Wilseyville, Calaveras County in Sections 14, T6N, and R12E, MDB&M as shown on Attachment A, which is incorporated herein. The Assessor's Parcel Numbers for the WWTP are 10-19-36 (treatment facility) and 10-19-37 (land application area, LAA). The District owns and operates the WWTP, which treats domestic wastewater from 28 Equivalent Dwelling Units including 27 residential connections and a single general store.

Drinking water for the Wilseyville community is supplied by the CCWD's West Point Water Treatment Plant. The source of raw water is Bear Creek, a tributary of the Lower Middle Fork of the Mokelumne River, or from Lower Middle Fork. Drinking water has a TDS concentration of 37 mg/L based on the CCWD's *2016 Annual Water Quality Report*.

The current average dry weather Influent flow (ADWF) ranges from approximately 733 to 2,682 gpd. A summary of the influent flow rates is presented below.

Month	ADWF (gpd)
June, 2013	2,682
September, 2013	No data
June, 2014	2,422
September, 2014	850
June, 2015	856
September, 2015	938
June, 2016	909
September, 2016	1,792
June, 2017	No data
September, 2017	733

The WWTP was constructed in 1985 and designed for a flow of 9,000 gpd. The WWTP consists of an unlined aerated stabilization pond and a LAA. The pond provides both wastewater treatment and storage with an approximate capacity of 12.2 acre-feet based on two feet of free board. The LAA includes five acres of sprayfield and five acres of buffer area. The LAA has not been used in recent years. Low influent flow versus design flow combined with evaporation and percolation rates typically meet disposal requirements. An influent flow meter is located upstream of the stabilization pond and a 15.0-foot long staff

gauge located inside the pond. The RWD indicated that the WWTP has a design loading rate of 20 pounds per day for Biochemical Oxygen Demand (BOD₅); BOD₅ reduction is anticipated to be 80 to 90 percent. However, effluent BOD data have not been collected because effluent has not been applied to the LAA in recent years.

Disposal of wastewater is accomplished by a combination of percolation and evaporation in the pond. Additional disposal can be accomplished with land application at the LAA. Prior to application on the LAA, pond supernatant is first pumped through an automatic self-backwashing strainer before being applied to the LAA. Tailwater from the LAA is collected in the catchment basin which drains into the stabilization pond. The site plan and the process schematic are shown on Attachment B and C, respectively, which are incorporated herein. A summary of wastewater quality in the pond is presented below.

Quarter	pH				Electrical Conductivity (µmhos/cm)			
	2013	2014	2015	2016	2013	2014	2015	2016
1 st	6.1	5.5	6.5	6.8	183	264	318	199
2 nd	6.1	6.4	6.9	6.7	214	232	303	176
3 rd	5.6	6.8	7.5	8.2	251	280	352	180
4 th	5.7	6.6	7.2	8.8	224	587	604	262

Solids management consists of measurement of solids accumulation in stabilization pond utilizing a Sludge Judge®. This generally performed every twelve months. When required these solids are removed from the pond and transported to the La Contenta Wastewater Treatment Facility for additional treatment, dewatering, and disposal.

SITE-SPECIFIC REQUIREMENTS AND EFFLUENT LIMITS

Note that the General Order contains prohibitions and specifications that apply to all wastewater treatment systems as well as those that only apply to specific treatment and/or disposal systems. The specific requirements for the treatment system are summarized below.

The wastewater treatment operator must be certified and familiar with the requirements contained in the General Order, this NOA, and the MRP.

Requirements by Wastewater System Type, Section B of General Order

B.1 All Wastewater Systems

This applies in its entirety to the WWTP with the following site specific requirements.

B.1.a. Flow Limit.

Influent flow to the WWTP shall not exceed **9,000 gpd** as an average dry weather flow defined as the total flow for the months of July through September divided by 92 days.

B.1.I. Wastewater System Setbacks.

Equipment or Activity	Domestic Well	Flowing Stream	Ephemeral Stream Drainage	Property Line	Lake or Reservoir
Aerobic Treatment Unit, Treatment System or Collection System ¹	150 ft.	50 ft.	50 ft.	5 ft.	200 ft.
Impoundment ¹	150 ft.	150 ft.	150 ft.	50 ft.	200 ft.
Land Application Area ¹	150 ft.	100 ft.	100 ft.	100 ft.	200 ft.

¹ Reference setbacks in Table 3 of General Order.

B.5 Pond Systems

The WWTP contains a storage and disposal pond; therefore, this section applies in its entirety.

B.7 Land Application and/or Recycled Water Systems

The WWTP contains a LAA; therefore, this section applies in its entirety.

MONITORING AND REPORTING PROGRAM

The Discharger shall comply with MRP WQ 2014-0153-DWQ-R5279, which is incorporated herein.

ENFORCEMENT

Please review this NOA carefully to ensure that it completely and accurately reflects the discharge. Discharge of wastes other than those described in this NOA is prohibited. Prior to allowing changes to the wastewater strength or generation rate, or to the method of waste disposal, you must contact the Central Valley Water Board to determine if submittal of an RWD is required.

The Discharger generates the waste subject to the terms and conditions of WQ 2014-0153-DWQ-R5279 and maintains exclusive control over the discharge. As such, CCWD is primarily responsible for compliance with this NOA, MRP, and General Order, with all attachments. Failure to comply with the requirements in the General Order or this NOA could result in an enforcement action as authorized by provisions of the California Water Code.

ANNUAL FEES

Staff has determined the discharge is a threat to water quality and complexity rating of 3-B. The annual fee corresponding to a threat to water quality and complexity of 3-B is currently \$4,699; however, because the permitted flow is less than 50,000 gpd, the discharge qualifies for the 50-percent fee discount. Therefore, the annual fee for this discharge is currently \$2,349. The fee is due and payable on an annual basis until coverage under the General Order is formally rescinded. Please note that the annual fees are reviewed each year and may change. If the wastewater discharge ceases, you must provide written notice so that we can terminate coverage under the General Order and no longer bill you.

DOCUMENT SUBMITTAL

All monitoring reports and other correspondence should be converted to searchable Portable Document Format (PDF) and submitted electronically. Documents that are less than 50 MB should be emailed to:

centralvalleysacramento@waterboards.ca.gov.

To ensure that your submittal is routed to the appropriate staff person, the following information should be included in the body of the email or any documentation submitted to the mailing address for this office:

Facility Name: Wilseyville Wastewater Treatment Plant, Calaveras County		
Program: Non-15 Compliance	Order: WQ 2014-0153-DWQ-R5279	CIWQS Place ID: CW-272716

Documents that are 50 MB or larger should be transferred to a CD, DVD, or flash drive and mailed to:

Central Valley Regional Water Quality Control Board
ECM Mailroom
11020 Sun Center Drive, Suite 200
Rancho Cordova, CA 95670

Now that the Notice of Applicability has been issued, the Board's Compliance and Enforcement section will take over management of your case. Kenny Croyle is your new point of contact for any questions about the General Order. If you find it necessary to make a change to your permitted operations, Kenny will direct you to the appropriate Permitting staff. You may contact Kenny at (916) 464-4676 or at kcroyle@waterboards.ca.gov.


For Patrick Pulupa
Executive Officer

enc: Water Quality Order WQ 2014-0153-DWQ
Monitoring and Reporting Program WQ 2014-0153-DWQ-R5279
Attachment A, Site Location Map
Attachment B, Site Plan
Attachment C, Process Schematic
Monitoring Report Transmittal Sheet

cc w/out enc: Timothy O'Brien, State Water Resources Control Board, Sacramento
Brian Moss, Calaveras County Environmental Health Department, San Andreas