

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 96-120

WASTE DISCHARGE REQUIREMENTS
FOR
QUAIL LAKE ESTATES, THE CAMBRIAN GROUP
AND
FRESNO COUNTY SERVICE AREA NO. 47
QUAIL LAKE ESTATES WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. The Cambrian Group (TCG), a California general partnership comprised of general partners CIL Investment Properties, Inc. and BIC Properties, Inc., California corporations, submitted a Report of Waste Discharge on 24 July 1995. TCG was acting on behalf of Quail Lake Estates (QLE), a California limited partnership, in applying for a discharge of domestic waste from a proposed wastewater treatment facility (WWTF) for Quail Lake Estates, a planned residential community in Fresno County approximately 3.5 miles east of the City of Clovis. TCG is the sole general partner of QLE. On 14 November 1995 the Fresno Local Agency Formation Commission formed Fresno County Service Area (FCSA) No. 47 to acquire, operate, and maintain the WWTF and a domestic water treatment plant for the residential community. FCSA No. 47, CG and QLE are hereafter jointly referred to as Discharger. The property (Assessor's Parcel Nos. 308-070-17S, 308-070-18, 308-070-19, 308-070-38S, 308-070-42S, 308-070-55, 308-070-56S, 308-070-57S, 308-070-58S, 308-081-01S, and 308-081-02S) is owned by QLE. A property parcel will be dedicated to the WWTF and deeded to FCSA No. 47.
2. Quail Lake Estates will be constructed on about 375 acres and will include 730 residential units, a community clubhouse, an elementary school, and retail commercial development projected to generate monthly average and maximum daily flows of 0.160 mgd and 0.180 mgd, respectively, of domestic waste.
3. The proposed WWTF will provide tertiary treatment for domestic waste, and the treatment units will be confined below a concrete deck. The proposed plant will be constructed on 1.35 acres and treatment will be provided by fine screening; flow equalization; primary clarification; three stages of trickling filtration with interstage secondary clarification; chemical addition (alum); flocculation; sand filtration; and disinfection. Sludge will be removed from the primary and secondary clarifiers and stored in a sludge holding tank prior to truck removal. The Discharger proposes to use the

WASTE DISCHARGE REQUIREMENTS
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-2-

sludge removed from the plant for disposal in a manner consistent with permitting requirements and technical standards included in 40 CFR 503.

4. Treated effluent will be reclaimed (also referred to as recycled) by irrigating 33 acres of common area landscape. An emergency storage pond of approximately 540,000 gallons (sufficient to contain three days of peak daily design flow) will temporarily contain any wastewater that does not meet effluent specifications. The pond will have a plastic liner with a permeability of less than 10^{-7} cm/sec.
5. A 57-acre lake with a capacity of 350 acre feet will provide seasonal storage of reclaimed water (approximately 15 acre feet/year) when irrigation demand is less than the amount of reclaimed water generated. In this lake, the reclaimed water will be mixed with Fresno Irrigation District canal water and natural precipitation. Reclaimed water will comprise approximately 5% of the annual average lake replenishment. The bottom of the 57-acre lake will be of one-foot-thick compacted clay soil (on-site surface soils recompacted) with a permeability of 1×10^{-7} cm/sec, minimizing seepage from the lake. The lake will accommodate precipitation from a 100-year annual rainfall season and will be used for boating and fishing.
6. The California Department of Health Services (DHS) has established water reuse criteria in Title 22, California Code of Regulations, Section 60301 through 60355, (hereafter 'Title 22'), and has developed guidelines for specific uses. Further, DHS is revising Title 22 and recommends using the proposed revisions to criteria as guidelines.
7. On 28 September 1995, the Discharger submitted an engineering report pursuant to Title 22, Section 60323, which contains a description of the design of the proposed recycling system and the means for compliance with flexibility of design and reliability requirements for producing adequately disinfected, oxidized, coagulated, clarified, and filtered wastewater for the intended reclamation use.
8. Quail Lake Estates is in Sections 16 and 17, T13S, R22E, MDB&M, with surface water drainage to Redbank Creek and Greys Creek, as shown in Attachment A, which is attached hereto and part of this Order by reference. The site lies within the Fresno Hydrologic Area (No. 551.30), as depicted on interagency hydrologic maps prepared by the Department of Water Resources in August 1986.
9. Soils on the 375-acre property consist of sands, silts, and clays with permeabilities ranging from 1.4×10^{-8} to 5×10^{-5} cm/sec.

WASTE DISCHARGE REQUIREMENTS
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-3-

10. The Board adopted the *Water Quality Control Plan for the Tulare Lake Basin, Second Edition*, (hereafter Basin Plan), which designates beneficial uses and contains water quality objectives for all waters of the Basin. These requirements implement the Basin Plan.
11. Information from on-site borings indicates first encountered ground water ranges from 9.5 feet below ground surface (bgs) near the southwest portion of the 375-acre property to up to 32 feet bgs at other locations. The ground water encountered at 9.5 feet bgs is in a perched zone adjacent to a wetland area. Local domestic wells are in an unconfined aquifer at 90 to 125 feet bgs that is of excellent mineral quality, with a Conductivity (Specific 'Electrical Conductance at 25° C, also referred to as 'EC') of 300 μ mhos/cm and total dissolved solids concentration of 210 mg/l. Water supply wells for Quail Lake Estates will be in a semi-confined aquifer at 235 to 390 feet bgs.
12. The beneficial uses of underlying ground water are domestic, industrial, and agricultural supply.
13. On 22 March 1994, Fresno County certified a final environmental impact report (EIR) in accordance with the California Environmental Quality Act (CEQA) (Public Resources Code Section 21000, et seq.) and the State CEQA Guidelines. The project as approved will not have a significant effect on water quality.
14. The permitted discharge is consistent with the antidegradation provisions of State Water Resources Control Board Resolution No. 68-16. The WWTF will produce a high quality effluent, and impacts on water quality will be insignificant. The discharge allows wastewater utility service necessary to accommodate housing and economic expansion in the area, and is considered to be a benefit to the people of the state.
15. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge and has provided them with an opportunity for a public hearing and an opportunity to submit their written views and recommendations.
16. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Quail Lake Estates, The Cambrian Group, and Fresno County Service Area No. 47, their agents, successors, and assigns, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

WASTE DISCHARGE REQUIREMENTS
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-4-

A. Discharge Prohibitions

1. Discharge of recycled water to surface waters or surface water drainage courses other than the 57-acre lake described in Finding No. 5 is prohibited.
2. Discharge of untreated or partially treated wastewater to the reuse areas is prohibited.
3. The by-pass or overflow of wastewater from the WWTF is prohibited (extenuating circumstances described in Standard Provision E.2 do not apply to this WWTF).
4. The discharge of waste classified as 'hazardous' or 'designated', as defined in Sections 2521(a) and 2522(a) of Title 23, California Code of Regulations, Sections 2510, et seq. (hereafter Chapter 15) is prohibited.
5. Application or impoundment of recycled water within 50 feet of any well used for domestic purposes is prohibited.

B. Discharge Specifications

1. The monthly average discharge shall not exceed 0.160 mgd.
2. Objectionable odors originating at this facility shall not be perceivable beyond the limits of the wastewater treatment and emergency storage areas.
3. The WWTF shall be designed, constructed, operated, and maintained to prevent inundation or washout due to floods with a 100-year return frequency.
4. The discharge shall be at all times an adequately disinfected, oxidized, coagulated, and filtered wastewater as specified by Section 60313(b) of Title 22 and shall not exceed the following limits:

<u>Constituent</u>	<u>Units</u>	<u>Monthly Average</u>	<u>Daily Maximum</u>
BOD ₅ ¹	mg/l	10	20
Total Suspended Solids	mg/l	10	20

WASTE DISCHARGE REQUIREMENTS
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-5-

<u>Constituent</u>	<u>Units</u>	<u>Monthly Average</u>	<u>Daily Maximum</u>
Settleable Solids	ml/l	0.1	0.2

5-day, 20 °C Biochemical Oxygen Demand.

5. The median number of total coliform organisms shall be less than 2.2 MPN (most probable number) per 100 ml, as determined from the bacteriological results of the last seven days for which analyses have been completed, and the daily maximum number of coliform organisms shall not exceed 23 MPN/100 ml.
6. The CT value (the product of the chlorine residual, in mg/l, times the modal contact time, in minutes) shall equal or exceed 300. The modal chlorine contact time at peak daily design flow shall equal or exceed 90 minutes.
7. The turbidity of the discharge shall not exceed the following

<u>Units</u>	<u>Daily Average</u>	<u>95% Percentile</u>	<u>Instantaneous Maximum</u>
NTU	2	5	10

8. The discharge shall not have a pH less than 6.0 or greater than 9.0.
9. The Conductivity of the discharge shall not exceed the average Conductivity of the source water plus 300 μ mhos/cm.
10. Public contact with untreated wastewater at the WWTF shall be precluded through such means as fences, signs, and other acceptable alternatives.
11. The emergency storage pond shall not contain wastewater for more than 72 hours after emergency use.
12. Freeboard in the emergency storage pond shall never be less than two feet.
13. The dissolved oxygen content in the upper zone (1 foot) of wastewater in the emergency holding pond shall not be less than 1.0 mg/l.

WASTE DISCHARGE REQUIREMENTS
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-6-

C. Recycled Water Specifications

1. Use of recycled water shall be limited to landscape and the above described lake at Quail Lake Estates, and to construction use.
2. The landscaped area irrigated with recycled water and the 57-acre lake shall be managed to prevent breeding of mosquitos.
3. Recycled water used for irrigation shall be managed to minimize erosion, runoff, and movement of aerosols from the irrigation area.
4. Direct or windblown spray shall be confined to the landscape area and prevented from contacting drinking water facilities, food handling facilities, and private dwellings.
5. Workers involved in water reuse activities shall be informed of the potential health hazards involved with contact or ingestion of recycled water, and should be educated regarding proper hygienic procedures to protect themselves and their families.
6. An adequate number of conspicuous signs shall be posted at the landscape irrigation area in a size no less than 4 inches by 8 inches, that include the following wording; "Reclaimed Water - Do Not Drink" or "Recycled Water - Do Not Drink". Each sign shall display the international symbol shown on Attachment B.
7. An adequate number of signs as described in Recycled Water Specification C.6., above, but including the words "No Swimming", shall be posted at the 57-acre lake.
8. Application of recycled water to the landscape area shall not exceed what is reasonably necessary for the grass, soil, climate and management system.
9. Recycled water controllers, valves, etc., shall be affixed with recycled water warning signs, and these and quick couplers and sprinkler heads shall be of a type, or secured in a manner, that permits operation by authorized personnel only. The recycled water piping system shall not include any hose bibs.
10. No physical connection shall exist between recycled water piping and domestic water supply piping.

WASTE DISCHARGE REQUIREMENTS
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-7-

11. Recycled water use shall cease during any period that the prohibitions and discharge specifications of this order cannot be met, and at other times if the public health, welfare, or safety may be at risk.
12. The WWTF shall be designed, constructed, and maintained with effective alarms, power reliability features, and treatment reliability features pursuant to and defined by Title 22, Sections 60333 through 60355.

D. Sludge Disposal Specifications

1. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner that is consistent with Chapter 15 and approved by the Executive Officer.
2. Any proposed change in sludge use or disposal practice shall be reported to the Executive Officer **at least 90 days in advance** of the change.
3. Use and disposal of sewage sludge shall comply with existing Federal and State laws and regulations.

E. Ground Water Limitations

The discharge, in combination with other sources, shall not cause underlying ground water to contain waste constituents in concentrations statistically greater than background water quality, excepting EC. The incremental increase of EC over a five-year period shall not exceed 15 $\mu\text{mhos/cm}$.

F. Provisions

1. The Discharger shall comply with Monitoring and Reporting Program No. 96-120, which is part of this Order, and any revisions thereto as ordered by the Executive Officer.
2. The Discharger shall comply with all items of the "Standard Provisions and Reporting Requirements for Waste Discharge Requirements," dated 1 March 1991, which are part of this Order. This attachment and its individual paragraphs are commonly referenced as "Standard Provision (s)."
3. In the event of any change in control or ownership of land or waste discharge facilities described herein, the Discharger shall notify the succeeding owner or

WASTE DISCHARGE REQUIREMENTS
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-8-

operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to this office.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the State of incorporation if a corporation, the name and address and telephone number of the persons responsible for contact with the Board, and a statement. The statement shall comply with the signatory paragraph of Standard Provision B.3 and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the California Water Code. Transfer shall be approved or disapproved by the Executive Officer.

4. At least **30 days prior** to actual start-up, the Discharger shall submit a technical report that certifies that the WWTF was constructed, designed, and ready to operate in full compliance of the terms of this Order. The report shall be prepared and signed by a California registered civil engineer experienced in wastewater treatment and disposal.
5. A copy of the operation and maintenance manual for the facility shall be submitted by **15 July 1996**. The Operation and Maintenance Manual shall be prepared under the supervision of a California registered civil engineer and include descriptions of complete operational procedures for the WWTF, reuse areas, and storage ponds that assure compliance with Title 22 and this Order. Further, the Operation and Maintenance Manual must address the items in Standard Provision B.2.
6. Within **30 days** following WWTF start-up, the Discharger shall submit a technical report demonstrating how it proposes to comply with Sludge Disposal Specifications D.1 and D.3. The report shall be prepared and signed by a California registered civil engineer experienced in wastewater treatment and disposal.
7. The Discharger shall use the best practicable control technique currently available to comply with this Order.
8. If recycled water is used for construction purposes, it shall comply with the most current edition of "Guidelines for Use of Reclaimed Water for Construction Purposes". Other uses of reclaimed water not specifically authorized herein shall

WASTE DISCHARGE REQUIREMENTS
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-9-

be subject to the approval of the Executive Officer and shall comply with 22 CCR, Division 4.

9. The Discharger must comply with all conditions of this Order, including timely submittal of technical and monitoring reports as directed by the Executive Officer. Violations may result in enforcement action, including Regional Board or court orders requiring corrective action or imposing civil monetary liability, or in revision or rescission of this Order.
10. A copy of this Order shall be kept at the WWTF for reference by operating personnel. Key operating personnel shall be familiar with its contents.
11. The Board will review this Order periodically and will revise requirements when necessary.
12. The WWTF shall be staffed with a sufficient number of qualified personnel to operate the WWTF effectively, where qualified personnel shall be determined by Standard Provision E.1.
13. In addition to Standard Provision A.3, this Order may be modified (after notice and opportunity for hearing) to reflect future revisions to Title 22 that differ significantly from those implemented in this Order.
14. The Discharger shall not allow pollutant-free wastewater to be discharged into the collection system and WWTF in amounts that significantly diminish the system's capability to comply with this Order. Pollutant-free wastewater means rainfall, ground water, cooling waters, and condensates that are essentially free of pollutants.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 3 May 1996.



WILLIAM H. CROOKS, Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 96-120
FOR
QUAIL LAKE ESTATES, THE CAMBRIAN GROUP
AND
FRESNO COUNTY SERVICE AREA NO. 47
QUAIL LAKES ESTATES WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

Specific sample stations locations shall be established with concurrence of the Board's staff, and a description of the stations shall be submitted to the Board and attached to this Program.

INFLUENT MONITORING

Influent samples shall be collected at the inlet of the headworks and at approximately the same time as effluent samples. Influent monitoring shall include at least the following:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
BOD ₅ ¹	mg/l	Grab	A, B
Total Suspended Solids	mg/l	Grab	A, B
Settleable Solids	ml/l	Grab	A, B

^{1, A, B} (See footnotes next page)

EFFLUENT MONITORING

Except for flow, which may be measured either at the headworks or the outlet from the treatment system, effluent samples shall be collected just prior to discharge for reclamation. Effluent samples should be representative of the volume and nature of the discharge. Time of collection of a grab sample shall be recorded.

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Flow ^{1,2}	mgd	metered	Continuous
BOD ₅	mg/l	Grab	A, B
Total Suspended Solids	mg/l	Grab	A, B
Settleable Solids	ml/l	Grab	A, B
Conductivity	µmhos/cm	Grab	A, B

^{1,2, A, B} (See footnotes next page)

MONITORING AND REPORTING PROGRAM
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-2-

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Total Coliform Organisms ²	MPN ³ /100 ml	Grab	Daily
Turbidity	NTU	Metered	Continuous ⁴
Chlorine	mg/l	Metered	Continuous
pH	PH Units	Grab	Daily
CT Value	mg - minutes/l	Calculated	Daily ⁵

¹ Five-day, 20° Celsius biochemical oxygen demand.

² BOD⁵ and total coliform organisms samples shall be dechlorinated immediately following sample collection as part of sample collection procedures.

³ Most Probable Number.

⁴ Sampled for turbidity using a continuous turbidity meter and recorder at a point prior to filtration and again following filtration. Turbidity measurements shall be based on a reading and recording of the turbidity charts or computer records at four-hour intervals. Compliance with the daily average operating turbidity shall be determined by averaging the results of all six four-hour turbidity samples read during the day.

⁵ The CT value shall be calculated and recorded based on conditions at the time of peak daily flow.

^A 2/month for flows ≤ 0.050 mgd.

^B Weekly for flows ≤ 0.050 mgd.

RECYCLED WATER MONITORING

The amounts (acre-feet) of water and/or recycled water applied to the landscape areas and to the 57-acre lake shall be measured and reported to the Board quarterly in accordance with the following schedule:

<u>Monitoring Period</u>	<u>Report Due</u>
January - March	15 April
April - June	15 July

MONITORING AND REPORTING PROGRAM
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-3-

<u>Monitoring Period</u>	<u>Report Due</u>
July - September	15 October
October - December	15 January

EMERGENCY STORAGE POND MONITORING

The amounts (million gallons) of any untreated wastewater diverted to the emergency storage pond shall be reported to the Board monthly.

SLUDGE MONITORING

A composite sample of sludge shall be collected annually and tested, on a dry weight basis, for Total Solids (%), Nitrogen (total, NH₄-N, and NO₃-N), Total Phosphorous, Total Potassium, and totals of specific metals (Pb, Zn, Cu, Ni, Cd, and Ag). Analytical results shall be submitted to the Executive Officer. Analysis of soluble concentrations of these specific metals shall also be included as needed. Sampling records shall be retained for a minimum of five years. A log shall be kept of sludge quantities generated and of handling and disposal activities. The frequency of entries is discretionary; however, the log should be complete enough to serve as a basis for part of the annual report. Additional sludge sampling may be requested at subsequent intervals, depending upon review of analytical results.

WATER SUPPLY MONITORING

A sampling station shall be established where a representative sample of the water supply can be obtained. Water supply monitoring shall include at least the following:

<u>Constituents</u>	<u>Unit</u>	<u>Sample Frequency</u>
Conductivity	µmhos/cm	Quarterly

If the source water is from more than one well, the Conductivity shall be reported as a weighted average and include copies of supporting calculations.

REPORTING

Monthly monitoring reports shall be submitted to the Board by the 20th day of the month following sample collection. Quarterly and annual monitoring results shall be submitted by the 20th day of the month following each calendar quarter and year, respectively.

MONITORING AND REPORTING PROGRAM
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY

-4-

In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly whether the discharge complies with waste discharge requirements.

If the Discharger monitors any pollutant at the locations designated herein more frequently than is required by this Order, the results of such monitoring shall be included in the calculation and reporting of the values required in the discharge monitoring report form. Such increased frequency shall be indicated on the discharge monitoring report form.

The Discharger may also be requested to submit an annual report to the Board with tabular and graphical summaries of the monitoring data obtained during the previous year. Any such request shall be made in writing. The report shall discuss the corrective actions taken and planned to bring the discharge into full compliance with the waste discharge requirements.

By 31 January of each year, the Discharge shall submit a written report to the Executive Officer containing the following:

- a. The names, titles, certificate grades, and general responsibilities of persons operating and maintaining the wastewater treatment plant.
- b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.
- c. A certified statement of when the flow meter and other monitoring instruments and devices were last calibrated, including identification of who did the calibration (Standard Provision C.4.).
- d. A statement whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last reviewed for adequacy.
- e. The total quantity of sludge disposed of during the previous year and ultimate disposal site(s).

All reports submitted in response to this Order shall comply with the signatory requirements in Standard Provisions B.3.

**MONITORING AND REPORTING PROGRAM
QUAIL LAKE ESTATES WWTF
FRESNO COUNTY**

-5-

The Discharger shall implement the above monitoring program prior to any discharge and not later than the first day of the month following start-up of the WWTF.

Ordered by: William H. Crooks
WILLIAM H. CROOKS, Executive Officer

3 May 1996

(Date)

LML:lml/rac

INFORMATION SHEET

QUAIL LAKE ESTATES, CAMBRIAN GROUP, AND FRESNO COUNTY SERVICE AREA NO. 47 WASTEWATER TREATMENT FACILITY FRESNO COUNTY

Fresno County Service Area No. 47 will be the operator for a wastewater treatment facility (WWTF) that services Quail Lakes Estates, a planned residential community in Fresno County. Quail Lake Estates will be constructed on about 375 acres and will include 730 residential units, a community clubhouse, an elementary school, and retail commercial development generating monthly average and maximum daily flows of 0.160 mgd and 0.180 mgd, respectively, of domestic waste. The WWTF will provide tertiary treatment of domestic waste by fine screening; flow equalization; primary clarification; three stages of trickling filtration with interstage secondary clarification; chemical addition (alum); flocculation; sand filtration; and disinfection.

Treated effluent will be reused to irrigate 33 acres of common area landscape in accordance with Title 22, California Code of Regulations. An emergency storage pond of approximately 540,000 gallons (sufficient to contain three days of peak daily design flow) will temporarily contain any wastewater that does not meet effluent specifications. The pond will have a plastic liner with permeability rating of less than 10^{-7} cm/sec.

A 57-acre lake with a capacity of 350 acre feet will provide seasonal storage of reclaimed water (approximately 15 acre feet/year) when irrigation demand is less than the amount of recycled water generated. In this lake, the recycled water will be mixed with Fresno Irrigation District canal water and natural precipitation. Recycled water will comprise approximately 5% of the annual average lake replenishment. The bottom of the 57-acre lake will be of one-foot of compacted clay soil with a permeability of 1×10^{-7} cm/sec, minimizing seepage from the lake. The lake will accommodate precipitation from a 100-year annual rainfall season. The lake will be used for boating and fishing.

Because of planned use of the lake for contact recreation (fishing) and use of effluent for landscape irrigation, these requirements include discharge specifications that limit the 7-day median number of total coliform organisms in the WWTF effluent to <2.2 MPN/100 ml to protect public health.

The Federal Clean Water Act and implementing regulations require that discharges of stormwater from certain industrial activities be subject to permit regulation under the National Pollutant Discharge Elimination System. Wastewater treatment facilities are one of the industrial categories subject to such regulation, but only if greater than one mgd. Since this WWTF is less than 1 mgd, it is not required to obtain such a permit.

INFORMATION SHEET - Continued

QUAIL LAKE ESTATES WWTF FRESNO COUNTY

Information from on-site borings indicates first encountered ground water ranges from 9.5 feet below ground surface (bgs) near the southwest portion of the 375-acre property to 22 feet to 32 feet bgs at most other locations. The ground water encountered at 9.5 feet bgs is in a perched zone adjacent to a wetland area. Local domestic wells are in an unconfined aquifer at 90 to 125 feet bgs that is of excellent mineral quality with total dissolved solids of 210 mg/l. Water supply wells for Quail Lake Estates will be in a semi-confined aquifer 235 to 390 feet bgs.

The beneficial uses of underlying ground water are domestic, industrial, and agricultural supply.

Soils on the 375-acre property consist of sands, silts, and clays with permeabilities ranging from 1.4×10^{-8} to 5×10^{-5} cm/sec.

Surface water drainage is to Redbank Creek and Greys Creek, valley floor waters, by sheet flow. The beneficial uses of Greys Creek are industrial and agricultural supply; water contact and non-contact water recreation; warm fresh water habitat; wildlife habitat; preservation of rare and endangered species; and ground water recharge.

Average annual precipitation in the area is approximately 10 inches and average annual evaporation is roughly 60 inches.

Fresno County certified a final environmental impact report (EIR) in accordance with the California Environmental Quality Act (CEQA) (Public Resources Code Section 21000, et seq.) And the State CEQA Guidelines. The project as approved will not have a significant effect on water quality.

LML:lml/rac:5/3/96