

California Regional Water Quality Control Board
Santa Ana Region

October 7, 1999

ITEM: 5

SUBJECT: Waste Discharge Requirements for West Hills Golf Associates Limited dba Western Hills Golf & Country Club, Order No. 99-54, Chino, San Bernardino County

DISCUSSION:

West Hills Golf Associates Limited dba Western Hills Golf & Country Club operates a packaged wastewater treatment plant in the Carbon Canyon area of San Bernardino County. The facility is located in the SW¹/₄ of Section 30, T2S, R8W, SBB&M, as shown in Attachment "A".

The discharges from the facility are currently regulated under Order No. 87-62. These waste discharge requirements need to be updated to reflect changes in state laws, regulations, plans, and policies.

An average of approximately 20,000 gallons per day of reclaimed water are currently discharged to a landscape impoundment. The water is then used to irrigate the adjoining golf course. The design capacity of the treatment facility is 50,000 gallons per day. The wastewater treatment facility is an activated sludge plant with extended aeration. The digested sludge is hauled away for disposal/use every 4-6 weeks.

Water quality objectives and beneficial uses of the groundwaters underlying this facility have not yet been established. However, small capacity local wells do supply water for domestic purposes. The water supply for this development has an average total dissolved solids concentration of 500 mg/l. This area is tributary to Santa Ana Forebay Groundwater Subbasin, the beneficial uses of which include municipal and domestic supply, agricultural supply, industrial service supply, and industrial process supply.

The discharge limitations of the proposed order are based on the Water Quality Control Plan (Basin Plan) for the Santa Ana Region and best professional judgement. These limitations are intended to meet the water quality objectives established in the Basin Plan to protect both surface water and groundwater and to ensure that the discharge will not create conditions of pollution or nuisance.

RECOMMENDATION:

Adopt Order No. 99-54 as presented.

COMMENTS SOLICITATION:

Comments were solicited from the discharger and from the following agencies:

State Water Resources Control Board, Office of the Chief Counsel - Ted Cobb
State Water Resources Control Board, Division of Water Quality – James Kassel
State Department of Water Resources - Glendale
State Department of Health Services - San Bernardino
San Bernardino County Department of Environmental Health Services – Scott Maass
San Bernardino County Department of Building and Safety – Leon Reed
San Bernardino County Flood Control and Water Conservation District - Jason Christie
Water Quality Specialists – Bill Jaroncyk
Orange County Water District – Nira Yamachika

California Regional Water Quality Control Board
Santa Ana Region

ORDER NO. 99-54

Waste Discharge Requirements
for
Western Hills Golf & Country Club
San Bernardino County

The California Regional Water Quality Control Board, Santa Ana Region (hereinafter Regional Board), finds that:

1. On June 12, 1987, the Regional Board adopted Order No. 87-62 for the discharge of treated wastewater from West Hills Golf Associates Limited dba Western Hills Golf and Country Club (hereinafter discharger) packaged wastewater treatment plant to a landscape impoundment in the Carbon Canyon area of San Bernardino County. The treated wastewater is then used for landscape irrigation of the adjoining golf course.
2. The current waste discharge requirements need to be updated to reflect changes in state laws, regulations, plans, and policies.
3. An average of approximately 20,000 gallons per day of reclaimed water are currently discharged to a landscape impoundment. The design capacity of the treatment facility is 50,000 gallons per day.
4. The wastewater treatment facility is an activated sludge plant with extended aeration. The facility and the point of discharge are located in the SW $\frac{1}{4}$ of Section 30, T2S, R8W, SBB&M.
5. A revised Water Quality Control Plan for the Santa Ana River Basin (Basin Plan) became effective on January 24, 1995. The Basin Plan contains beneficial uses and water quality objectives for waters in the Santa Ana Region.
6. Water quality objectives and beneficial uses of the groundwaters underlying this facility have not yet been established. However, small capacity local wells do supply water for domestic purposes.
7. The area of the discharge/use is tributary to Carbon Canyon Creek and the Santa Ana Forebay Groundwater Subbasin. The Basin Plan establishes numeric water quality objectives for this groundwater subbasin.
8. The beneficial uses of Carbon Canyon Creek Include:
 - a. Municipal and domestic supply,
 - b. Groundwater recharge,
 - c. Water contact recreation,

- d. Non-contact water recreation,
 - e. Warm freshwater habitat,
 - f. Wildlife habitat, and
 - g. Rare, threatened or endangered species
9. The beneficial uses of the Santa Ana Forebay Groundwater Subbasin include:
- a. Municipal and domestic supply,
 - b. Agricultural supply,
 - c. Industrial service supply, and
 - d. Industrial process supply.
10. The requirements contained in this order are necessary to meet the water quality objectives and protect the beneficial uses specified in the Basin Plan.
11. The project involves the continued operation of an existing facility and, as such, is exempt from the California Environmental Quality Act (Public Resources Code, Section 21100 et. seq) in accordance with Section 15301, Chapter 3, Title 14, California Code of Regulations.
12. The Regional Board has notified the discharger and other interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written views and recommendations.
13. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that the discharger, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder and the provisions of the Clean Water Act and regulations and guidelines adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

- 1. The discharge of wastes to property not owned or controlled by the discharger is prohibited.
- 2. Odors, vectors, and other nuisances of sewage origin are prohibited outside of the treatment plant site or landscape impoundment.
- 3. The discharge of any substances in concentrations toxic to human, animal, plant or aquatic life is prohibited
- 4. Any discharge to the impoundment with less than 18 inches of freeboard is prohibited.

B. Discharge Specifications:

- 1.a. The discharge of wastes containing constituent concentrations in excess of the following limits is prohibited:

Constituents	Unit	Average Concentration Limit
Total Dissolved Solids	mg/l	750
Biochemical Oxygen Demand	"	30
Suspended Solids	"	30

- 1.b. The discharge of wastes containing an annual average TDS concentration which exceeds the annual average TDS concentration in the water supply by more than 250 mg/l is prohibited.

For Discharge Specifications 1.a. and 1.b., whichever limitation results in the lower average TDS concentration shall be controlling.

2. The pH of the discharge shall at all times be within the range of 6 and 8 pH units.
3. Reclaimed water used for landscape irrigation of the golf course shall at all times be an adequately disinfected, oxidized wastewater. The wastewater shall be considered adequately disinfected if the median number of coliform organisms does not exceed 23 per 100 milliliters, as determined from the bacteriological results of all analyses completed during the last 7 days, and the number of coliform organisms does not exceed 240 per 100 milliliters in any two consecutive samples.

C. Provisions:

1. The discharger shall comply with Monitoring and Reporting Program No. 99-54 as ordered by the Executive Officer of the Regional Board. This monitoring and reporting program may be modified by the Executive Officer at any time during the term of this order, and may include a reduction or an increase in the number of parameters to be monitored, the frequency of the monitoring, or the number and size of samples collected.
2. Neither the treatment nor the discharge of wastes shall cause or threaten to cause a nuisance or pollution as defined in Section 13050 of the California Water Code.
3. The wastewater treatment and storage facilities shall be protected from a 100-year frequency flood.
4. The discharger shall file with the Board a report of waste discharge at least 120 days before making any material change or proposed change in the character, location, or volume of the discharge or in the operator or property ownership of any portions of the facility identified in this order.

5. The discharger shall maintain a copy of this order at the site so that it is available at all times to site operating personnel. Key operating personnel shall be familiar with its contents.
6. Collected screenings, sludge, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.
7. The discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the discharger to achieve compliance with the conditions of this order. Proper operation and maintenance also includes adequate laboratory controls, appropriate quality assurance procedures, effective performance, adequate funding, adequate staffing and training and adequate process controls. This provision requires the operation of back up or auxiliary facilities or similar systems which are installed by a discharger only when the operation is necessary to achieve compliance with the conditions of the order.
8. Whenever the discharger monitors any pollutant more frequently than is required by this order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the discharge monitoring report specified by the Executive Officer.
9. The requirements prescribed herein do not authorize the commission of any act causing injury to the property of another, nor protect the discharger from his liabilities under federal, state, or local laws.
10. This order does not convey any property rights of any sort, or any exclusive privilege.
11. The Regional Board, and other authorized representatives shall be allowed:
 - a. Entry upon premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this order;
 - b. Access to copy any records that are kept under the conditions of the order;
 - c. To inspect any facility, equipment (including monitoring and control equipment), practices, or operations regulated or required under this order; and
 - d. To photograph, sample and monitor for the purpose of assuring compliance with this order.
12. The discharger shall take all reasonable steps to minimize or prevent any discharge that has a reasonable likelihood of adversely affecting human health or the environment.
13. The discharger shall take all reasonable steps to minimize any adverse impact to receiving waters resulting from noncompliance with any requirement specified in this order, including such accelerated or additional monitoring as necessary to determine the nature and impact of the

noncomplying discharge.

14. Order No. 87-62 is hereby rescinded.

I, Gerard J. Thibeault, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an order adopted by the California Regional Water Quality Control Board, Santa Ana Region, on October 7, 1999.

Gerard J. Thibeault
Executive Officer

California Regional Water Quality Control Board
Santa Ana Region

Monitoring and Reporting Program No. 99-54

for
Western Hills Golf & Country Club
San Bernardino County

This M&RP
Revised
See Amended
M&RP dated 6/28/01

A. General Monitoring Provisions:

1. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. The analytical techniques or methods used; and
 - e. The results of such analyses.
2. All monitoring instruments and devices used by the discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy.
3. The flow measurement system shall be calibrated at least once per year or more frequently, to ensure continued accuracy.
4. All analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services or at a laboratory approved by the Executive Officer of the Regional Board.

B. Definition:

1. A "composite" sample is defined as a combination of no fewer than eight individual grab samples obtained over the specified sampling period. The volume of each individual grab sample shall be proportional to the discharge flow rate at the time of sampling. The compositing period shall equal the specified sampling period, or 24 hour, if no period is specified.

C. Effluent Monitoring:

1. A sampling station shall be established at the point of discharge and shall be located where representative samples of the effluent can be obtained.
2. On the 15th working day of February, April, June, August, October, and December, a composite sample of the effluent shall be taken and analyzed for total dissolved solids, biochemical oxygen demand, suspended solids, chloride, and boron.
3. On a daily basis, grab samples shall be taken and analyzed for total coliform organisms.
4. On a weekly basis, grab samples shall be taken and analyzed for pH and residual chlorine.
5. The total daily effluent flow from the treatment plant shall be recorded and the average daily flow for each month determined.
6. Every Monday, the freeboard in the impoundment shall be measured and entered in a permanent log book.

D. Water Supply Monitoring:

At least once annually, in July, a sample of the water supply to the plant shall be collected and shall be analyzed for total dissolved solids, chloride, and boron.

E. Reporting:

1. Daily flow and bacteriological analyses and weekly residual chlorine concentration, and pH data shall be compiled and submitted once every month; bimonthly chemical analyses shall also be submitted with the monthly reports, where applicable. All monitoring reports shall be submitted by the 30th day of the month following sampling and shall include:
 - a. A copy of the chemical and/or bacteriological analyses, and
 - b. Flow data
2. For every item where the requirements are not met, the discharger shall submit a statement of the actions undertaken or proposed which will bring the discharge into full compliance with the requirements at the earliest time and submit a timetable for correction.

3. All reports shall be signed by a responsible officer of Western Hills Golf & Country Club and shall be submitted under penalty of perjury.

Gerard J. Thibeault
Executive Officer

October 7, 1999

California Regional Water Quality Control Board
Santa Ana Region

Revised Monitoring and Reporting Program No. 99-54

for
Western Hills Golf & Country Club
San Bernardino County

A. General Monitoring Provisions:

1. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. The analytical techniques or methods used; and
 - e. The results of such analyses.
2. All monitoring instruments and devices used by the discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy.
3. The flow measurement system shall be calibrated at least once per year or more frequently, to ensure continued accuracy.
4. All analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services or at a laboratory approved by the Executive Officer of the Regional Board.

B. Definition:

1. A "composite" sample is defined as a combination of no fewer than eight individual grab samples obtained over the specified sampling period. The volume of each individual grab sample shall be proportional to the discharge flow rate at the time of sampling. The compositing period shall equal the specified sampling period, or 24 hour, if no period is specified.

C. Effluent Monitoring:

1. A sampling station shall be established at the point of discharge and shall be located where representative samples of the effluent can be obtained.
2. On the 15th working day of February, April, June, August, October, and December, a composite sample of the effluent shall be taken and analyzed for total dissolved solids, biochemical oxygen demand, suspended solids, chloride, and boron.
3. Grab samples shall be taken and analyzed for total coliform organisms daily, Monday through Friday. Grab samples for coliform organisms do not need to be collected on weekends and national holidays¹.
4. On a weekly basis, grab samples shall be taken and analyzed for pH and residual chlorine.
5. The total daily effluent flow from the treatment plant shall be recorded and the average daily flow for each month determined.
6. Every Monday, the freeboard in the impoundment shall be measured and entered in a permanent log book.

D. Water Supply Monitoring:

At least once annually, in July, a sample of the water supply to the plant shall be collected and shall be analyzed for total dissolved solids, chloride, and boron.

E. Reporting:

1. Daily flow and bacteriological analyses and weekly residual chlorine concentration, and pH data shall be compiled and submitted once every month; bimonthly chemical analyses shall also be submitted with the monthly reports, where applicable. All monitoring reports shall be submitted by the 30th day of the month following sampling and shall include:
 - a. A copy of the chemical and/or bacteriological analyses, and
 - b. Flow data
2. For every item where the requirements are not met, the discharger shall submit a statement of the actions undertaken or proposed which will bring the discharge into

¹ National holidays: Independence Day, Labor Day, Veterans Day, Thanksgiving Day, Christmas Day, New Year's Day, President's Day, and Memorial Day.

full compliance with the requirements at the earliest time and submit a timetable for correction.

3. All reports shall be signed by a responsible officer of Western Hills Golf & Country Club and shall be submitted under penalty of perjury.

Gerard J. Thibeault
Executive Officer
June 28, 2001