

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 94-151

WASTE DISCHARGE REQUIREMENTS
FOR
STATE DEPARTMENT OF PARKS AND RECREATION
AMERICAN RIVER DISTRICT
GRANITE BAY STATE PARK
PLACER COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. State Department of Parks and Recreation (hereafter Discharger) submitted a Report of Waste Discharge, dated 18 January 1990.
2. Waste Discharge Requirements Order No. 69-205, adopted by the Board on 14 March 1969, prescribes requirements for a discharge from Granite Bay State Park to a sewage lagoon.
3. Order No. 69-205 is neither adequate nor consistent with current plans and policies of the Board.
4. The Discharger discharges approximately 5,000 gallons per day during spring and summer and approximately 500 gallons per day during fall and winter to two leachfields which were replaced in 1983 (field No. 1) and 1987 (field No. 2).
5. The disposal area where both leachfields are on State Park property, in Section 36, T11N, R7E, MDB&M, with surface water drainage to Miners Ravine, as shown in Attachment A, which is attached hereto and part of the Order by reference.
6. The Board adopted a Water Quality Control Plan, Second Edition, for the Sacramento River Basin (hereafter Basin Plan), which contains water quality objectives for all waters of the Basin. These requirements implement the Basin Plan.
7. The beneficial uses of Miners Ravine which is tributary to the Sacramento River are municipal, industrial, and agricultural supply; recreation; esthetic enjoyment; navigation; ground water recharge; fresh water replenishment; and preservation and enhancement of fish, wildlife, and other aquatic resources.
8. The beneficial uses of underlying ground water are domestic, industrial, and agricultural supply.
9. The action to update waste discharge requirements for this facility is exempt from the provisions of the California Environmental Quality Act (CEQA), in accordance with Title 14, California Code of Regulations (CCR), Section 15301.

STATE DEPARTMENT OF PARKS AND RECREATION
AMERICAN RIVER DISTRICT
GRANITE BAY STATE PARK
PLACER COUNTY

-2-

10. This discharge is exempt from the requirements of Title 23, CCR, Section 2510, et seq. (hereafter Chapter 15). The exemption, pursuant to Section 2511(b), is based on the following:
 - a. The Board is issuing waste discharge requirements, and
 - b. The discharge complies with the Basin Plan, and
 - c. The wastewater does not need to be managed according to 22 CCR, Division 4, Chapter 30, as a hazardous waste.
11. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge and has provided them with an opportunity for a public hearing and an opportunity to submit their written views and recommendations.
12. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Order No. 69-205 is rescinded and State Department of Parks and Recreation, American River District, its agents, successors, and assigns, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

1. Discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. Bypass or overflow of untreated or partially treated waste is prohibited.
3. Discharge of waste classified as 'hazardous' or 'designated', as defined in Sections 2521(a) and 2522(a) of Chapter 15, is prohibited.

B. Discharge Specifications:

1. The monthly average dry weather discharge flow shall not exceed 0.005 million gallons/day.
2. Objectionable odors originating at this facility shall not be perceivable beyond the limits of the wastewater treatment and disposal areas.
3. The treatment and disposal facilities shall be designed, constructed, operated, and maintained to prevent inundation or washout due to floods with a 100-year return frequency.
4. Public contact with wastewater shall be precluded through such means as fences, signs, and other acceptable alternatives.

C. Sludge Disposal:

1. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner that is consistent with Chapter 15, Division 3, Title 23, of the California Code of Regulations and approved by the Executive Officer.
2. Any proposed change in sludge use or disposal practice from a previously approved practice shall be reported to the Executive Officer and U.S. Environmental Protection Agency (EPA) Regional Administrator at least 90 days in advance of the change.
3. Use and Disposal of sewage shall comply with existing Federal and State laws and regulations, including permitting requirements and technical standards included in 40 CFR 503.

If the State Water Resources Control Board and the Regional Water Quality Control Boards are given the authority to implement regulations contained in 40 CFR 503, this Order may be reopened to incorporate appropriate time schedules and technical standards. The Discharger must comply with the standards and time schedules contained in 40 CFR 503 whether or not they have been incorporated into this Order.

4. The Discharger is encouraged to comply with the State Guidance Manual issued by the Department of Health Services titled *Manual of Good Practice for Landspreading of Sewage Sludge*.

D. Provisions:

1. The Discharger shall comply with the Monitoring and Reporting Program No. 94-151, which is part of this Order, and any revisions thereto as ordered by the Executive Officer.
2. The Discharger shall comply with the "Standard Provisions and Reporting Requirements for Waste Discharge Requirements", dated 1 March 1991, which are attached hereto and by reference a part of this Order. This attachment and its individual paragraphs are commonly referenced as "Standard Provisions."
3. In the event of any change in control or ownership of land or waste discharge facilities described herein, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to this office.
4. At least **90 days** prior to termination or expiration of any lease, contract, or agreement involving disposal or reclamation areas or off-site reuse of effluent, used to justify the capacity authorized herein and assure compliance with this Order, the Discharger shall notify


STATE DEPARTMENT OF PARKS AND RECREATION
AMERICAN RIVER DISTRICT
GRANITE BAY STATE PARK
PLACER COUNTY

-4-

the Board in writing of the situation and of what measures have been taken or are being taken to assure full compliance with this Order.

5. The Discharger shall use the best practicable cost-effective control technique currently available to comply with salinity limits specified in this order.
6. The Discharger must comply with all conditions of this Order, including timely submittal of technical and monitoring reports as directed by the Executive Officer. Violations may result in enforcement action, including Regional Board or court orders requiring corrective action or imposing civil monetary liability, or in revision or rescission of this Order.
7. A copy of this Order shall be kept at the discharge facility for reference by operating personnel. Key operating personnel shall be familiar with its contents.
8. If reclaimed water is used for construction purposes, it shall comply with the most current edition of "Guidelines for Use of Reclaimed Water for Construction Purposes". Other uses of reclaimed water not specifically authorized herein shall be subject to the approval of the Executive Officer and shall comply with 22 CCR, Division 4.
9. The Board will review this Order periodically and will revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 20 May 1994.


WILLIAM H. CROOKS, Executive Officer

24 May 1994/MRB:dlk



California Regional Water Quality Control Board

Central Valley Region



Alan C. Lloyd, Ph.D.
Agency Secretary

Robert Schneider, Chair

Arnold Schwarzenegger
Governor

Sacramento Main Office
11020 Sun Center Drive #200, Rancho Cordova, CA 95670
Phone (916) 464-3291 • FAX (916) 464-4780
Internet Address: <http://www.waterboards.ca.gov>

9 September 2005

Keenen Sederquist
California Department of Parks and Recreation
7806 Folsom-Auburn Road
Folsom, CA 95630


REVISED MONITORING AND REPORTING PROGRAM, GRANITE BAY STATE PARK, PLACER COUNTY

Based on a review of Monitoring and Reporting Program (MRP) No. 94-151, staff determined that the MRP was outdated and insufficient to show compliance with the WDRs, and thus needed to be revised. On 19 May 2005, a draft MRP was sent to California Department of Parks and Recreation; any comments were to be submitted to the Regional Board by 30 June 2005. Staff did not receive any comments, and therefore has finalized the draft revised MRP.

Enclosed is the final Revised MRP No. 94-151. Please note that this revised MRP is effective starting **1 October 2005**; therefore, your October monitoring report is to conform to the requirements of this Revised MRP. Quarterly groundwater monitoring shall begin with the fourth quarter of 2007.

Staff looks forward to receiving the Groundwater Monitoring Well Installation Workplan by **1 May 2007**, and the Well Installation Report and Groundwater Sampling Plan by **1 September 2007**.

If you have any questions or comments with regards to this letter, please do not hesitate to call Guy Childs at (916) 464-4648.


MARK R. LIST, P.G., Chief
Waste Discharge to Land Unit

Enclosure: Revised Monitoring and Reporting Program No. 94-151
Standard Provisions and Reporting Requirements

cc: Brad Banner, Placer County Environmental Health Department, Auburn

California Environmental Protection Agency

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

REVISED MONITORING AND REPORTING PROGRAM NO. 94-151

FOR

STATE DEPARTMENT OF PARKS AND RECREATION
AMERICAN RIVER DISTRICT
GRANITE BAY STATE PARK
PLACER COUNTY

This Monitoring and Reporting Program (MRP) describes requirements for domestic wastewater effluent and leachfield monitoring. This MRP is issued pursuant to Water Code Section 13267. The Discharger shall not implement any changes to this MRP unless and until a revised MRP is issued by the Executive Officer. Regional Board staff shall approve specific sample station locations prior to implementation of sampling activities.

All samples should be representative of the volume and nature of the discharge or matrix of material sampled. The time, date, and location of each grab sample shall be recorded on the sample chain of custody form.

Field test instruments (such as those used to test pH and dissolved oxygen) may be used provided that:

1. The operator is trained in proper use and maintenance of the instruments;
2. The instruments are field calibrated prior to each monitoring event;
3. Instruments are serviced and/or calibrated per the manufacturer's recommended frequency; and
4. Field calibration reports are submitted as described in the "Reporting" section of this MRP.

SEPTIC TANK MONITORING

The Discharger shall monitor the septic tank(s) and report this information in the annual reports. The septic tank(s) shall be inspected annually and pumped as described below.

<u>Parameter</u>	<u>Units</u>	<u>Type of Measurement</u>	<u>Minimum Inspection</u>	<u>Reporting Frequency</u>
Sludge depth and scum thickness in the first compartment of each septic tank	Feet	Staff Gauge	Annually	Annually
Distance between bottom of the scum layer and bottom of outlet device	Inches	Staff Gauge	Annually	Annually
Distance between top of sludge layer and bottom of outlet device	Inches	Staff Gauge	Annually	Annually

The septic tank(s) shall be pumped when any one of the following conditions exist or may occur before the next inspection:

1. The combined thickness of sludge and scum extends one-third of the tank depth of the first compartment; or,
2. The scum layer is within three inches of the outlet device; or,
3. The sludge layer is within eight inches of the outlet device.

The Discharger shall retain records of each inspection, noting the date and measured readings and calculations. The Discharger will also record when cleaning is required, the condition of the tank, and the date that cleaning or repair occurred and by whom. Copies of the Liquid Waste Hauler manifests shall be retained for review as with any other record concerning documentation of compliance with the Order.

EFFLUENT MONITORING

The Discharger shall conduct effluent monitoring of the wastewater entering the leachfields; samples shall be collected at a point prior to discharge into the leachfield dosing tanks. Effluent monitoring shall include, at a minimum, the following:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>	<u>Reporting Frequency</u>
Flow ¹	gpd	Continuous Meter	Daily ²	Monthly
Total Dissolved Solids	mg/L	Grab	Monthly	Monthly
Nitrates as Nitrogen	mg/L	Grab	Monthly	Monthly
Total Kjeldahl Nitrogen	mg/L	Grab	Monthly	Monthly
Standard Minerals ³	mg/L	Grab	Annually	Annually

¹ A flow meter shall be installed and operational by 1 December 2005.

² Beginning 1 December 2005

³ Standard Minerals shall include, at a minimum, the following elements and compounds: Boron, Calcium, Iron, Magnesium, Manganese, Sodium, Potassium, Chloride, Sulfate, Total Alkalinity (including alkalinity series), and Hardness.

LEACHFIELD AREA MONITORING

The Discharger shall conduct a visual inspection of the leachfield on a **weekly basis**. Results shall be recorded and submitted with the monthly monitoring report. Photocopies of entries into an operator's log are acceptable. Evidence of surfacing wastewater, erosion, field saturation, runoff, or the presence of nuisance conditions shall be noted in the report. If surfacing water is found, then a sample shall be collected and tested for total coliform organisms and total dissolved solids. In addition to the visual inspections, monitoring of the leachfields shall include the following:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>	<u>Reporting Frequency</u>
Application Rate ¹	gal/acre•day	Calculated	Monthly	Monthly
Leachline Riser Inspection ²	Inches	Measurement	Monthly	Monthly

¹ The application rate for each of the leachfields

² The Discharger shall measure and record the distance from the surface of the liquid in the observation port to the surface of the ground in the active lateral(s).

GROUNDWATER MONITORING

The groundwater monitoring program shall begin in the **fourth quarter of 2007**. Samples shall be collected from all groundwater monitoring wells at the facility. Prior to construction and/or sampling of any additional groundwater monitoring wells, the Discharger shall submit plans and specifications to the Board for review and approval. Once installed, all new wells shall be added to the MRP and shall be sampled and analyzed according to the schedule below.

Prior to sampling, the groundwater elevations shall be measured and the wells shall be purged of at least three well volumes until temperature, pH and electrical conductivity have stabilized. Depth to groundwater shall be measured to the nearest 0.01 feet. Samples shall be collected using standard EPA methods. Groundwater monitoring shall include, at a minimum, the following:

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>	<u>Reporting Frequency⁶</u>
Depth to Groundwater	0.01 Feet	Measurement	Quarterly	Quarterly
Groundwater Elevation ¹	0.01 Feet	Calculated	Quarterly	Quarterly
Gradient	Feet/Feet	Calculated	Quarterly	Quarterly
Gradient Direction	Degrees	Calculated	Quarterly	Quarterly
pH ²	pH Units	Grab	Quarterly	Quarterly
Specific Conductivity @ 25° C	µmhos/cm	Grab	Quarterly	Quarterly
Total Coliform Organisms ³	MPN/100ml ⁴	Grab	Quarterly	Quarterly
Total Dissolved Solids	mg/L	Grab	Quarterly	Quarterly
Nitrate as Nitrogen	mg/L	Grab	Quarterly	Quarterly
Total Kjeldahl nitrogen	mg/L	Grab	Quarterly	Quarterly
Standard Minerals ⁵	mg/L	Grab	Annually	Annually

¹ Groundwater elevation shall be based on depth-to-water using a surveyed measuring point elevation on the well and a surveyed reference elevation.

² Hand held field meter may be used.

³ Using a minimum of 15 tubes or three dilutions

⁴ Most probable number per 100 ml.

⁵ Standard Minerals shall include, at a minimum, the following elements and compounds: Boron, Calcium, Iron, Magnesium, Manganese, Sodium, Potassium, Chloride, Sulfate, Total Alkalinity (including alkalinity series), and Hardness.

⁶ Beginning with the fourth quarter 2007.

REPORTING

In reporting monitoring data, the Discharger shall arrange the data in tabular form so that the date, sample type (e.g., process wastewater effluent, groundwater well, etc.), and reported analytical result for each sample are readily discernible. The data shall be summarized in such a manner to clearly illustrate compliance with waste discharge requirements and spatial or temporal trends, as applicable. The results of any monitoring done more frequently than required at the locations specified in the Monitoring and Reporting Program shall be reported in the next scheduled monitoring report.

As required by the California Business and Professions Code Sections 6735, 7835, and 7835.1, all Groundwater Monitoring Reports shall be prepared under the direct supervision of a Registered Engineer or Professional Geologist and signed/stamped by the registered professional.

A. Monthly Monitoring Reports

Monthly reports shall be submitted to the Regional Board on the **1st day of the second month following sampling** (i.e. the January Report is due by 1 March). At a minimum, the reports shall include:

1. Results of effluent and leachfield area monitoring;
2. A comparison of monitoring data to the discharge specifications and an explanation of any violation of those requirements. Data shall be presented in tabular format;
3. If requested by staff, copies of laboratory analytical report(s); and
4. A calibration log verifying calibration of all hand held monitoring instruments and devices used to comply with the prescribed monitoring program.

B. Quarterly Monitoring Reports

Beginning with the **fourth quarter of 2007**, the Discharger shall establish a quarterly sampling schedule for groundwater monitoring such that samples are obtained approximately every three months. Quarterly monitoring reports shall be submitted to the Regional Board by the **1st day of the second month after the quarter** (i.e. the January-March quarterly report is due by May 1st) and may be combined with the monthly report. The Quarterly Report shall include the following:

1. Results of the groundwater monitoring;
2. A narrative description of all preparatory, monitoring, sampling, and analytical testing activities for the groundwater monitoring. The narrative shall be sufficiently detailed to verify compliance with the WDR, this MRP, and the Standard Provisions and Reporting Requirements. The narrative shall be supported by field logs for each well documenting depth to groundwater; parameters measured before, during, and after purging; method of purging; calculation of casing volume; and total volume of water purged;

3. Calculation of groundwater elevations and discussion of seasonal trends if any;
4. A narrative discussion of the analytical results for all groundwater locations monitored including spatial and temporal trends, with reference to summary data tables, graphs, and appended analytical reports (as applicable);
5. A comparison of the monitoring data to the groundwater limitations and an explanation of any violation of those requirements;
6. Summary data tables of historical and current water table elevations and analytical results;
7. A scaled map showing relevant structures and features of the facility, the locations of monitoring wells and any other sampling stations, and groundwater elevation contours referenced to mean sea level datum; and
8. Copies of laboratory analytical report(s) for groundwater monitoring.

B. Annual Report

An Annual Report shall be prepared as the December monthly monitoring report. The Annual Report will include all monitoring data required in the monthly schedule. The Annual Report shall be submitted to the Regional Board by **1 February** each year. In addition to the data normally presented, the Annual Report shall include the following:

1. The contents of the regular groundwater monitoring report for the last sampling event of the year;
2. If requested by staff, tabular and graphical summaries of all data collected during the year;
3. Results of the annual effluent monitoring;
4. A description of any activity to control vegetation in the leachfield area;
5. Annual summary of the septic tank inspections for the year, including whether the tank was pumped and that waste was removed by a licensed hauler;
6. A description of the annual evaluation of effluent distribution and adjustments made, if any;
7. A summary of maintenance and repair activities which were performed on the effluent collection system;
8. A statement regarding whether the flow meter was calibrated during the year; and
9. A discussion of any compliance issues and the corrective actions taken, as well as any planned or proposed actions needed to bring the discharge into full compliance with the waste discharge requirements.

A letter transmitting the self-monitoring reports shall accompany each report. Such a letter shall include a discussion of requirement violations found during the reporting period, and actions taken or planned for correcting noted violations, such as operation or facility modifications. If the discharger has previously submitted a report describing corrective actions and/or a time schedule for implementing the corrective actions, reference to the previous correspondence will be satisfactory. The transmittal letter shall contain a statement by the discharger, or the discharger's authorized agent, under penalty of perjury, that to the best of the signer's knowledge the report is true, accurate and complete.

The Discharger shall implement the above monitoring program as of the date of this Order.

Ordered by:

Thomas R. Pinkos

THOMAS R. PINKOS, Executive Officer

9 Sept 05

(Date)