

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 95-103

WASTE DISCHARGE REQUIREMENTS
FOR
CITY OF PARLIER
WEST WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

- 1.The City of Parlier (hereafter Discharger) submitted a Report of Waste Discharge (RWD) and a technical report prepared by its consultant on 17 August 1993 for a project to increase the design flow capacity of its West Wastewater Treatment Facility (WWTF), from 1.0 to 2.0 mgd, abandon its East WWTF, redirect flow from the East WWTF to the West WWTF, and acquire additional acreage for reclamation disposal.
- 2.The Discharger has essentially completed its project at the West WWTF but a formal Notice of Completion has not been submitted. The Discharger will abandon the East WWTF and redirect its flow to the West WWTF sometime prior to summer 1995.
- 3.The West WWTF project, funded by the U.S Department of Agriculture, Rural Economic and Community Development Services, will increase the size of the West WWTF. The completed West WWTF will consist of four aerated lagoons, an oxidation lagoon, six evaporation/percolation lagoons, two sludge beds, a sludge storage area, and a 46.7-acre reclamation area. The wastewater is not disinfected.
- 4.Order No. 90-234 is neither adequate to describe the modified WWTF nor consistent with current plans and policies of the Board.
- 5.The Discharger presently leases the reclamation area to Mr. Albert Fujisawa and Mr. Fred Banuelos who irrigate grape vineyards and plum orchards.
- 6.On 10 August 1994, the Board adopted Cease and Desist (C&D) Order No. 90-235 because the Discharger violated past requirements, and threatened to violate Waste Discharge Requirements Order No. 90-234 due to a lack of adequate disposal capacity, frequent freeboard violations, over-irrigation of the reclamation area, and threatened nuisance conditions.
- 7.The Discharger dries sludge on drying beds and stockpiles it in its sludge storage area until it is hauled off-site by a land application company or taken to a landfill for final disposal.
- 8.The Discharger plans to irrigate the reclamation area with about 6.3 ft of reclaimed water per year. The typical water demand for vineyards and orchards in the San Joaquin Valley is approximately 3.4 feet/year and 3.3 feet/year, respectively. The City's engineering consultant indicates that the land is moderate to highly permeable and no ponding of reclaimed will occur. Assuming that the numbers

WASTE DISCHARGE REQUIREMENTS
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-2-

determined by the consultant are correct, approximately 2/3 of the reclaimed water discharged to the reclamation area will be used by the vineyards and orchards and approximately 1/3 of the water will percolate. Based on the typical water demand for vineyards and orchards, the Discharger will reclaim approximately 7 percent of the treated wastewater and the rest will be disposed by percolation/evaporation.

9. Soils on the site consist of Hanford Fine Sandy Loam. The permeability of the soil is moderately rapid and the water holding capacity of the soil is high. According to the technical report, the water holding capacity is 7.5 inches or more over a depth of 5 feet and the permeability is 1.0 to 0.30 feet/day.
10. The West WWTF site is in Section 27, T15S, R22E, MDB&M, within the Consolidated Hydrologic Area (No. 551.70), as depicted on interagency hydrologic maps prepared by the Department of Water Resources in August 1986 and shown in Attachment A, attached and part of this Order by reference. Surface water drainage is to the Kings River, between the Friant-Kern Canal and Peoples Weir (not shown on Attachment A).
11. The Board adopted a Water Quality Control Plan, for the Tulare Lake Basin (5D, hereafter Basin Plan), which contains water quality objectives for all waters of the Basin. These requirements implement the Basin Plan.
12. The West WWTF is situated about 1/2 mile west of the Kingsburg Branch Canal and less than a mile away east of the Selma Branch Canal. Both canals, along with several ditches south of the West WWTF, drain into the Kings River. The beneficial uses of the Kings River from the Friant-Kern Canal to Peoples Weir are municipal, agricultural, and industrial supply; noncontact water recreation; ground water recharge; and preservation and enhancement of fish, wildlife, and other aquatic resources.
13. The quality of background ground water is good (electrical conductivity is about 450 μ mhos/cm). The beneficial uses of the ground water underlying this area are municipal, agricultural, and industrial supply. The City of Parlier obtains its water supply from ground water wells. The average electrical conductivity and total dissolved solids concentrations from the combined water supply are approximately 200 μ mhos/cm and 150 mg/l, respectively.
14. Ground water at the site is at an approximate depth of 55 feet below ground surface and flows in a southwesterly direction. The ground water monitoring network consists of 10 monitoring wells sited as shown in Attachment B, part of this Order by reference. Three wells, situated in the southeast corner of the West WWTF property and adjacent to the now closed Southeast Regional Landfill, are dry. Four wells, Nos. 7, 8, 9, and 10 were installed in the fall of 1994, and there is no data available from them at this time.
15. Data from monitoring wells Nos. 4 and 6 indicate that ground water in the area around the West WWTF has been degraded either by the West WWTF, the Southeast Regional Landfill owned by

WASTE DISCHARGE REQUIREMENTS
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-3-

Fresno County, or by some other source. From February 1987 to August 1994, downgradient well no. 6 exhibited an average electrical conductivity of 276 μ mhos/cm and an average chloride concentration of 41 mg/l greater than the concentration of these parameters upgradient well no. 4, but concentrations of both constituents remain below the Secondary Maximum Contaminant Levels (MCLs) established by DHS. Nitrate-nitrogen concentrations are in excess of the primary MCLs of 10 mg/l established by DHS in monitoring wells Nos. 9 and 6 from February 1987 to August 1994, the average nitrate-nitrogen concentrations for monitoring wells nos. 4 and 6 were 14.9 and 14.6 mg/l, respectively. However, based on a

8 June 1994 investigative report by the Discharger's consultant, the disposal of wastewater by percolation has improved the quality of the ground water aquifer. The consultant indicates that the mean value of the nitrate-nitrogen concentrations in the lagoons is 2.64 mg/l and in monitoring well no. 5, situated on-site and adjacent to Lagoon No.3, is 1.87 mg/l. The monitoring reports indicate that the nitrate-nitrogen concentration of monitoring well No.5 is historically below both the upgradient and downgradient wells. The consultant attributes the high nitrate-nitrogen concentrations to the Southeast Regional Landfill and farming practices in the immediate area.

16.State Water Resources Control Board Resolution No. 68-16 requires the continued maintenance of existing high quality waters, but provides conditions under which a change in water quality is allowable. The conditions are as follows: the discharge be a maximum benefit to the people of the state, the beneficial uses of the ground water are not affected by the discharge, and that the discharge not result in water quality less than that prescribed in the water quality control plan or policies. Ground water quality downgradient of the West WWTF exhibits increases in electrical conductivity and chloride concentrations; however, the increases are well below MCLs established by DHS. Ground water quality around the West WWTF exhibits high nitrogen concentrations that exceed water quality objectives. The Discharger's consultant indicates that the quality of the ground water is being improved by percolated wastewater effluent, which is low in nitrate-nitrogen concentrations. The increase in the discharge allows wastewater utility service necessary for the protection of the public and economic expansion in the area, and is considered to be a benefit to the people of the State.

17.The Basin Plan specifies the minimum treatment level for wastewater facilities which discharge or are projected to discharge in excess of 1.0 mgd prior to the year 2000 is secondary treatment. Secondary treatment should provide 80 percent removal of 5-day BOD and suspended solids or reduction to 40 mg/l, whichever is more restrictive.

18.The California Department of Health Services (DHS) has established statewide reclamation criteria in Title 22, California Code of Regulation (CCR), Section 60301, et seq., (hereafter Title 22), for the use of reclaimed water, and has developed guidelines for specific uses.

The Board consulted with the Department of Health Services, County Health Department, and Mosquito Abatement District and considered their recommendations regarding public health aspects for use of reclaimed water.

WASTE DISCHARGE REQUIREMENTS
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-4-

19. On 26 August 1994, staff inspected the West WWTF due to a complaint that the Discharger was drying grapes on ground irrigated with reclaimed water. The inspection validated the complaint. The DHS advised that the practice of drying raisins on paper on ground irrigated with reclaimed water is in violation of Title 22, which states that "Orchards and vineyards may be surface irrigated with reclaimed water that has the quality of at least equivalent to that of primary effluent provided that no fruit is harvested that has come in contact with the irrigation water or ground." We were advised by DHS that paper does not provide a sufficient barrier between the drying raisins and pathogens that may be present in the ground from reclaimed water.
20. Federal Regulations for storm water discharges were promulgated by the USEPA on 16 November 1990 (40 CFR Parts 122, 123, and 124). The State Water Resources Control Board adopted Order No. 91-13-DWQ, NPDES General Permit No. CAS000001 (General Permit) specifying requirements for discharges of storm water associated with industrial activities. All WWTFs with design flows greater than 1.0 mgd must submit a Notice of Intent (NOI) to be covered by the General Permit. On 24 February 1994, the Discharger submitted a Notice of Termination from the General Permit because all storm water is retained on-site by a safety berm surrounding the boundary of the site. On 20 July 1994, we accepted the Notice of Termination from the Discharger.
21. On 27 May 1992, the City of Parlier certified a negative declaration for the proposed project, in accordance with the California Environmental Quality Act (CEQA) (Public Resources Code Section 21000, et seq.) and the State CEQA Guidelines. The project as approved will not have a significant effect on water quality.
22. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge and has provided them with an opportunity for a public hearing and an opportunity to submit their written views and recommendations.
23. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Order No. 90-234 is rescinded and the City of Parlier, its agents, successors, and assigns, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

B. Discharge Prohibitions:

1. Discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. Bypass or overflow of untreated or partially treated waste is prohibited.

WASTE DISCHARGE REQUIREMENTS
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-5-

3. Discharge of waste classified as 'hazardous' or 'designated', as defined in Sections 2521(a) and 2522(a) of Chapter 15, Division 3, Title 23, California Code of Regulations, Section 2510, et seq., (hereafter Chapter 15) is prohibited.

C. Discharge Specifications:

1. The monthly average dry weather (May through October) discharge shall not exceed 2.0 mgd.
2. Objectionable odors originating at this facility shall not be perceivable beyond the limits of the wastewater treatment and disposal areas.
3. As a means of discerning compliance with Discharge Specification No. B.3, the dissolved oxygen content in the upper zone (1 foot) of wastewater in ponds shall not be less than 1.0 mg/l.
4. The effluent from the treatment facility shall not exceed the following limits:

<u>Constituent</u>		<u>Units</u>		<u>Average</u>	<u>Maximum</u>
				Daily	Daily
BOD ₅ ¹	mg/l	140	80		
Total Suspended Solids	mg/l			40	80
Settleable Solids	ml/l			0.2	0.5

¹ 5-day, 20° Celsius biochemical oxygen demand.

5. Ponds shall not have a pH less than 6.5 or greater than 9.5.
6. The maximum specific electrical conductivity (EC) of the discharge shall not exceed the average EC of the source water plus 500 µmhos/cm.
7. Ponds shall have sufficient capacity to accommodate allowable wastewater flow and design seasonal precipitation and ancillary inflow and infiltration during the non-irrigation season. Design seasonal precipitation shall be based on total annual precipitation using a return period of 100 years, distributed monthly in accordance with historical rainfall patterns. Freeboard shall never be less than two feet (measured vertically).
8. On or about 1 October of each year, available pond storage capacity shall at least equal the volume necessary to comply with Discharge Specification B.7.

D. Reclamation Specifications:

WASTE DISCHARGE REQUIREMENTS
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-6-

- 1.Reclaimed water shall remain within the designated reclamation site at all times.
- 2.The use of reclaimed water shall be limited to flood irrigation of fodder, fiber, seed crops for nonhuman consumption, wine or table grapes, and orchards where no fruit is harvested that has come in contact with the reclaimed water or the irrigated ground. The practice of drying raisins on paper on the ground in the reclamation area is not acceptable unless approved in writing by the DHS.
- 3.The Discharger shall maintain the following setback distances from areas irrigated with reclaimed water:

<u>Setback Distance (feet)</u>	<u>To</u>
25	Property Line
30	Public Roads
50	Drainage courses
150	Irrigation and Domestic wells

- 4.The perimeter of the reclamation area shall be graded to prevent ponding along public roads or other public areas.
- 5.Areas irrigated with reclaimed water shall be managed to prevent breeding of mosquitos. More specifically:
 - a.All applied irrigation water must infiltrate completely within a 48-hour period.
 - b.Weeds shall be minimized through control of water depth, harvesting, or herbicides.
 - c.Low-pressure and unpressurized pipelines and ditches accessible to mosquitos shall not be used to store reclaimed water.
- 6.Reclaimed water shall be managed to minimize runoff onto adjacent properties not owned or controlled by the User.
- 7.Public contact with wastewater shall be precluded through such means as fences, signs, and other acceptable alternatives.
- 8.No physical connection shall exist between reclaimed water piping and any domestic water supply or domestic well, or between reclaimed water piping and any irrigation well that does not have an air gap or reduced pressure principle device.
- 9.The User shall not irrigate with reclaimed water during periods of heavy rainfall or when the ground is saturated.

E.Sludge Disposal Specifications:

1. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner that is consistent with Chapter 15 and approved by the Executive Officer.
2. Any proposed change in sludge use or disposal practice shall be reported to the Executive Officer **at least 90 days in advance** of the change.
3. Use and disposal of sewage sludge shall comply with existing federal and state laws and regulations, including permitting requirements and technical standards included in 40 CFR 503.

If the State Water Resources Control Board and the Regional Water Quality Control Boards are given the authority to implement regulations contained in 40 CFR 503, this Order may be reopened to incorporate appropriate time schedules and technical standards. The Discharger must comply with the standard and time schedules contained in 40 CFR 503 whether or not they have been incorporated into this Order.

F.Ground Water Limitations:

The discharge, in combination with other sources, shall not cause underlying ground water to:

1. Contain waste constituents in concentrations statistically greater than receiving water limits, where specified below, or background water quality where not specified. (For purposes of comparison, background water quality shall be determined when background monitoring provides sufficient data. Quality determined in this manner establishes "water quality protection standards.")
2. Exceed an annual average incremental increase in specific electrical conductivity greater than 4 μ mhos/cm, based on the most recent five-year period, or a maximum of 900 μ mhos/cm., whichever is less.
3. Contain chemicals, heavy metals, or trace elements in concentrations that adversely affect beneficial uses or exceed maximum contaminant levels specified in the California Code of Regulations, Title 22, Division 4, Chapter 15.
4. Exceed a most probable number of total coliform organisms of 2.2/100 ml over any seven-day period.
5. Exceed concentrations of radionuclides specified in the California Code of Regulations, Title 22, Division 4, Chapter 15.
6. Contain taste or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses.

7. Contain concentrations of chemical constituents in amounts that adversely affect agricultural use.

G. Provisions:

1. The Discharger shall comply with Monitoring and Reporting Program No. 95-103, which is part of this Order, and any revisions thereto as ordered by the Executive Officer.
2. The Discharger shall comply with the "Standard Provisions and Reporting Requirements for Waste Discharge Requirements," dated 1 March 1991, which are attached hereto and by reference a part of this Order. This attachment and its individual paragraphs are commonly referenced as "Standard Provision(s)."
3. In the event of any change in control or ownership of land or waste discharge facilities described herein, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to this office.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the State of incorporation if a corporation, the name and address and telephone number of the persons responsible for contact with the Board, and a statement. The statement shall comply with the signatory paragraph of Standard Provision B.3 and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the California Water Code. Transfer shall be approved or disapproved by the Executive Officer.

4. At least **90 days** prior to termination or expiration of any lease, contract, or agreement involving disposal or reclamation areas or off-site reuse of effluent, used to justify the capacity authorized herein and assure compliance with this Order, the Discharger shall notify the Board in writing of the situation and of what measures have been taken or are being taken to assure full compliance with this Order.
5. The Discharger shall use the best practicable cost-effective control technique currently available to comply with salinity limits specified in this order.
6. The Discharger must comply with all conditions of this Order, including timely submittal of technical and monitoring reports as directed by the Executive Officer. Violations may result in enforcement action, including Regional Board or court orders requiring corrective action or imposing civil monetary liability, or in revision or rescission of this Order.
7. The Discharger shall notify the Board in writing 30 days prior to abandoning the East Plant and discharging the waste discharge from the East Plant to the West Plant.

WASTE DISCHARGE REQUIREMENTS
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-9-

8. **By 1 August 1995**, the Discharger shall submit a technical report for sludge disposal, prepared by a California registered civil engineer experienced in wastewater treatment and disposal that addresses compliance with Sludge Disposal Specification Nos. D.1 to D.3 and includes a time schedule for implementation.
9. A copy of this Order shall be kept at the discharge facility for reference by operating personnel. Key operating personnel shall be familiar with its contents.
10. The Board will review this Order periodically and will revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 28 April 1995.

WILLIAM H. CROOKS, Executive Officer

MHS:cjs: 4/28/95

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 95-103

FOR
CITY OF PARLIER
WEST WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

Specific sample station locations shall be established with concurrence of the Board's staff, and a description of the stations shall be submitted to Board and attached to this Program.

INFLUENT MONITORING

Influent samples shall be collected at the inlet of the headworks and shall include at least the following:

<u>Sampling</u>			
<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Frequency</u>
Flow	mgd	Measured	Continuous
Settleable Solids	ml/l	Grab	2/Month
Total Suspended Solids	mg/l	8-hr. Composite	2/Month
BOD ₅ ¹	mg/l	8-hr. Composite	2/Month

¹ Five-day, 20° Celsius biochemical oxygen demand.

EFFLUENT MONITORING

Effluent samples shall be collected just prior to discharge to the disposal ponds. Effluent samples shall be representative of the volume and nature of the discharge. Samples collected from the outlet structure of ponds will be considered adequately composited. Time of collection of a grab sample shall be recorded. Effluent monitoring shall include at least the following:

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling</u> <u>Frequency</u> ¹
Dissolved Oxygen ²	mg/l	Grab	Daily
BOD ₅ ³	mg/l	Grab	Weekly
Total Suspended Solids	mg/l	Grab	Weekly
Settleable Solids	ml/l	Grab	Weekly
Specific Conductivity	µmhos/cm	Grab	Monthly
<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling</u> <u>Frequency</u> ¹

MONITORING AND REPORTING PROGRAM
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-2-

pH	pH Units	Grab	Monthly
Standard Minerals ⁴	mg/l	Grab	Quarterly
Nitrates as N	mg/l	Grab	Quarterly

¹If results of monitoring a pollutant appear to violate effluent limitations, but monitoring frequency is not sufficient to validate violation (e.g., the monthly average for BOD), or indicate a potential upset of the treatment process (e.g., less than minimum D.O.), the frequency of sampling shall be increased to confirm the magnitude and duration of violation, if any, and aid in identification and resolution of the problem.

²Samples shall be collected at a depth of one foot from each pond, opposite the inlet, and analyzed for dissolved oxygen. Samples shall be collected between 0800 and 0900 hours.

³Five-day, 20° Celsius biochemical oxygen demand.

⁴Standard minerals analyses shall include bicarbonate, calcium, carbonate, chloride, fluoride, iron, manganese, magnesium, nitrate, potassium, sodium, sulfate, total phosphorus, total cations, and total anions.

SLUDGE MONITORING

On-site sludge disposal shall be at agronomic rates. Prior to on-site disposal, a composite sludge sample shall be analyzed for the following metals:

Cadmium	Lead
Chromium	Nickel
Copper	Zinc

Analytical results shall be submitted to the Executive Officer. Sampling records shall be retained for a minimum of five years. A log shall be kept of sludge quantities generated and of handling and disposal activities. The frequency of entries is discretionary; however, the log should be complete enough to serve as a basis for part of the annual report. **By 28 February of each year (commencing in 1996)**, the Discharger shall submit a description of present and proposed disposal methods. If more than one method is used, include the percentage of annual sludge production disposed by each method:

1. For **landfill disposal**, include (a) the Regional Board's WDR numbers that regulate the landfill(s) used, (b) the present classifications of the landfill(s) used, (c) the names and locations of the facilities receiving sludge.
2. For **land application**, include (a) the location of the site(s), (b) the Regional Board's WDR numbers that regulate the site(s), (c) a technical report analyzing application rates and procedures relative to Department of Health Services' Manual of Good Practices for landspreading of Sewage Sludge and

MONITORING AND REPORTING PROGRAM
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-3-

EPA's *Process Design Manual for land application of Municipal Sludges* and Title 23, California Code of Regulations, Section 2511 (f), and (d) subsequent uses of the land.

3. For **composting**, include (a) the location of the site(s), and (b) the Regional Board's WDR numbers that regulate the site(s).

POND MONITORING

The freeboard shall be monitored on the evaporation/percolation ponds in use to the nearest tenth foot. Pond water monitoring shall include the following:

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Frequency</u>
Freeboard	feet	Observation	Weekly

Permanent markers shall be placed in the pond with calibration indicating the water level at design capacity and available operational freeboard.

In addition, the Discharger shall inspect the condition of the ponds once per week and write visual observation in a bound log book. Notations shall include observations of whether weeds are developing in the water or along the bank, and their location; whether dead algae, vegetation, scum, or debris are accumulating on the pond surface and their location; whether burrowing animals or insects are present; and the color of the pond (e.g., dark sparkling green, dull green, yellow, grey, tan, brown, etc.). A copy of the entries made in the log during each month shall be submitted along with the monitoring report the following month. Where the O&M manual indicates remedial action is necessary, the Discharger shall briefly explain in the transmittal what action has been taken or is scheduled to be taken.

WATER SUPPLY MONITORING

A sampling station shall be established where a representative sample of the water supply can be obtained. Water supply monitoring shall include at least the following:

<u>Constituents</u> ¹	<u>Units</u>	<u>Sampling Frequency</u>
Standard Minerals	mg/l	Annually
Electrical Conductivity @ 25°C	µmhos/cm	Annually
Total Dissolved Solids	mg/l	Annually

MONITORING AND REPORTING PROGRAM
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-4-

¹If the source water is from more than one well, the EC shall be reported as a weighted average and include copies of supporting calculations.

GROUND WATER MONITORING

Ground water samples shall be representative of the underlying ground water. Ground water monitoring shall include at least the following:

<u>Constituents¹</u>	<u>Units</u>	<u>Sampling Frequency</u>
Electrical Conductivity @ 25°C	µmhos/cm	Quarterly
pH	pH units	Quarterly
Nitrates (as N)	mg/l	Quarterly
Chloride	mg/l	Quarterly
Total Coliform	MPN/100 ml	Quarterly
Standard Minerals	mg/l	Quarterly

¹If the source water is from more than one well, the EC shall be reported as a weighted average and include copies of supporting calculations.

ANNUAL LAND MANAGEMENT REPORTS

The Discharger shall submit a summary report on the land management operation after conclusion of each season. The report shall discuss total water application over the season; the total wastewater applied; the total nutrient loading from wastewater, sludges and chemical fertilizers; and amount of nutrients removed through harvest of the crop. In short, the report shall present a mass balance relative to pollutants of concern and hydraulic loading. The report is due **by 31 January** of the following year.

REPORTING

Monthly monitoring reports shall be submitted to the Board by the **28th day of the following month**.

In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner that illustrates clearly whether the Discharger complies with waste discharge requirements, including calculation of all averages, etc.

MONITORING AND REPORTING PROGRAM
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-5-

If the Discharger monitors any pollutant at the locations designated herein more frequently than is required by this Order, the results of such monitoring shall be included in the discharge monitoring report.

The Discharger may also be requested to submit an annual report to the Board with tabular and graphical summaries of the monitoring data obtained during the previous year. Any such request shall be made in writing. The report shall discuss the corrective actions taken and planned to bring the discharge into full compliance with the waste discharge requirements.

By **31 January of each year**, the Discharger shall submit a written report to the Executive Officer containing the following:

- a. The names, titles, certificate grade (if any) and general responsibilities of persons operating and maintaining the wastewater treatment plant.
- b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.
- c. A certified statement of when the flow meter and other monitoring instruments and devices were last calibrated, including identification of who did the calibration (Standard Provision C.4).
- d. A statement whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last reviewed for adequacy.
- e. The total quantity of sludge disposed of during the previous year and ultimate disposal site(s).

All reports submitted in response to this Order shall comply with the signatory requirements in Standard Provision B.3.

The Discharger shall implement the above monitoring program on the first day of the month following adoption of this Order.

Ordered by: _____
WILLIAM H. CROOKS, Executive Officer

MONITORING AND REPORTING PROGRAM
CITY OF PARLIER WEST WWTF
FRESNO COUNTY

-6-

(Date) _____

MHS:cjs: 4/28/95

INFORMATION SHEET

CITY OF PARLIER WEST WASTEWATER TREATMENT FACILITY FRESNO COUNTY

The City of Parlier (hereafter Discharger) has nearly completed an expansion that increases the maximum monthly capacity of its wastewater treatment facility (West WWTF) from 1.0 mgd to 2.0 mgd. However, the Discharger has not submitted a formal Notice of Completion. The Discharger plans to abandon the East WWTF and redirect that flow to the expanded West WWTF sometime prior to summer 1995.

The expanded West WWTF consist of four aeration lagoons, an oxidation lagoon, six evaporation/percolation lagoons, two sludge drying beds, a sludge storage area, and a 46.7-acre reclamation area. The Discharger will lease the reclamation area to farmers. The reclaimed water will be used to irrigate vineyards and orchards.

On 10 August 1994, the Board adopted Cease and Desist (C&D) Order No. 90-235 for the West WWTF due to a lack of adequate disposal capacity, frequent freeboard violations, over-irrigation of the reclamation area, and threatened nuisance conditions.

The Discharger dries sludge in its drying beds and stockpiles it in a storage area until it is hauled off-site by a land application company or taken to a landfill for final disposal.

The Discharger plans to irrigate the reclamation area with about 6.3 ft of reclaimed water per year. The typical water demand for vineyards and orchards in the San Joaquin Valley is approximately 3.4 feet/year and 3.3 feet/year, respectively. The City's engineering consultant indicates that the land is moderate to highly permeable and no ponding of reclaimed will occur. Soils on the site consist of Hanford Fine Sandy Loam. The permeability of the soil is moderately rapid and the water holding capacity of the soil is high. Assuming that the numbers determined by the consultant are correct, approximately 2/3 of the reclaimed water discharged to the reclamation area will be used by the vineyards and orchards and approximately 1/3 of the water will percolate. Based on the typical water demand for vineyards, the Discharger will reclaim approximately 7 percent of the treated wastewater and the rest will be disposed by percolation/evaporation.

The West WWTF is in Section 27, T15S, R22E, MDB&M. Surface water drainage from the topography is to the Kings River, between the Friant-Kern Canal and Peoples Weir.

The quality of background ground water is good (electrical conductivity is about 450 $\mu\text{mhos/cm}$). The beneficial uses of the ground water underlying this area are municipal, agricultural, and industrial supply.

The City of Parlier obtains its water supply from ground water wells. The average electrical conductivity and total dissolved solids concentrations from the combined water supply are approximately 200 $\mu\text{mhos/cm}$ and 150 mg/l, respectively.

The Basin Plan specifies that minimum treatment level for facilities which discharge in excess of 1.0 mgd prior to the year 2000 is secondary treatment. Secondary treatment should provide

INFORMATION SHEET - Continued

CITY OF PARLIER WEST WASTEWATER TREATMENT FACILITY FRESNO COUNTY

-2-

80 percent removal of 5-day BOD and suspended solids or reduction to 40 mg/l, whichever is more restrictive. A potential for increased nuisances from odors and vectors is associated with higher flows.

Federal Regulations for storm water discharges were promulgated by the USEPA on 16 November 1990 (40 CFR Parts 122, 123, and 124). The State Water Resources Control Board adopted Order No. 91-13-DWQ, NPDES General Permit No. CAS000001, specifying requirements for discharges of storm water associated with industrial activities. As a WWTF with design flow greater than 1.0 mgd, the Discharger submitted a Notice of Intent to be covered by the General Permit. Later, the Board accepted from the Discharger a Notice of Termination from the General Permit because all stormwater is retained on-site by a safety berm surrounding the boundary of the site.

On 27 May 1992, the City of Parlier certified a negative declaration for the proposed project, in accordance with the California Environmental Quality Act (CEQA) (Public Resources Code Section 21000, et seq.) and the State CEQA Guidelines. The project as approved will not have a significant effect on water quality.