

California Regional Water Quality Control Board
North Coast Region

ORDER NO. 84-118

WASTE DISCHARGE REQUIREMENTS

FOR

KLAMATH COMMUNITY SERVICES DISTRICT

Del Norte County

The California Regional Water Quality Control Board, North Coast Region, finds that:

1. The Klamath Community Services District (hereafter the discharger) proposes to construct a municipal wastewater treatment facility to serve the community of Klamath as shown on Attachment "A" incorporated herein and made part of this Order.
2. A community septic tank and leachfield will be constructed on property owned by the discharger. Design flow will be 20,000 gpd. Current wastewater flows are estimated to be 6,500 gpd. Construction should be completed in November, 1984.
3. Soil and groundwater investigations were conducted during January 1983 to evaluate suitability for on-site wastewater treatment and disposal. The investigations revealed that conditions on the 25 acre parcel are in conformance with the Regional Board's Septic Tank Policy. Groundwater is in excess of 12 feet below ground surface, and soils consist of a large river deposit of silty sand.
4. Wastewater from the community currently is discharged into sludge drying beds at an inoperable activated sludge treatment plant. The 15 year old facility is deteriorating and is not cost effective to repair.
5. The Regional Board adopted Waste Discharge Requirements Order No. 74-171 on September 25, 1974, for the activated treatment plant. Cease and Desist Order No. 83-41 was adopted on March 24, 1983, and amended by Order No. 83-61 on May 26, 1983. These Orders will remain in effect until the new wastewater treatment facility demonstrates compliance with this Order.
6. The Regional Board adopted the Water Quality Control Plan for the Klamath River Basin on March 20, 1975. The Plan contains water quality objectives and the Regional Board's Septic Tank Policy.
7. As enumerated in the Water Quality Control Plan, beneficial uses of the lower Klamath River include:
 - a. municipal and agricultural water supply
 - b. groundwater recharge
 - c. navigation
 - d. water contact and non-water contact recreation
 - e. commercial and sport fishing

- f. warm and cold freshwater habitat
 - g. wildlife habitat
 - h. fish migration and spawning
8. On August 1, 1984, the Del Norte County Planning Department issued a negative declaration for the project pursuant to provisions of the California Environmental Quality Act. The Regional Board finds that this project will not have adverse water quality related effects if conducted in conformance with the terms of this Order.
 9. The Board has notified the discharger and interested persons and agencies of its intent to prescribe waste discharge requirements for the discharge.
 10. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

THEREFORE, IT IS HEREBY ORDERED that the discharger shall comply with the following:

A. DISCHARGE SPECIFICATIONS

1. There shall be no discharge of waste to the Klamath River or its tributaries.
2. The discharge of waste shall be kept underground at all times.
3. An adequate replacement area equivalent to the initial disposal area shall be reserved at the time of the design of the initial installation. Incompatible uses of the initial disposal area or the replacement area is prohibited.
4. There shall be no discharge of waste to land not controlled by the discharger.
5. Leachfield trenches shall not extend greater than five feet below existing ground surface.
6. The mean daily waste flow shall not exceed 20,000 gallons averaged over a period of thirty days.

B. PROVISIONS

1. All waste treatment and disposal facilities shall be installed according to applicable ordinances of the Del Norte County Health Department.
2. The discharger shall comply with the Monitoring and Reporting Program No. 84-118 and Contingency Planning and Notification Requirements No. 74-151 and any modifications to this document as specified by the Executive Officer. Such document is attached to this Order and incorporated herein.

3. Neither the treatment nor disposal of wastes shall cause a pollution or nuisance as defined in Section 13050 of the California Water Code.
4. This Board requires the discharger to file a report of waste discharge at least 120 days before making any material change or proposed change in the character, location, or volume of the discharge.
5. The discharger shall file a written report with the Board within 90 days after the average dry-weather waste flow for any month equals or exceeds 75 percent of the design capacity of his waste treatment and/or disposal facilities. The discharger's senior administrative officer shall sign a letter which transmits that report and certifies that the policy making body is adequately informed about it. The report shall include:

Average daily flow for the month, the date on which the instantaneous peak flow occurred, the rate of that peak flow, and the total flow for that day.

The discharger's best estimate of when the average daily dry-weather flow rate will equal or exceed the design capacity of his facilities.

The discharger's intended schedule for studies, design, and other steps needed to provide additional capacity for his waste treatment and/or disposal facilities before the waste flow rate equals the capacity of present units. (Reference: Sections 13260, 13267(b), and 13268, California Water Code.)

6. In the event the discharger is unable to comply with any of the conditions of this Order due to:
 - a. breakdown of waste treatment equipment;
 - b. accidents caused by human error or negligence; or
 - c. other causes, such as acts of nature;

the discharger shall notify the Executive Officer by telephone as soon as he or his agents have knowledge of the incident and confirm this notification in writing within two weeks of the telephone notification. The written notification shall include pertinent information explaining reasons for the noncompliance and shall indicate what steps were taken to correct the problem and the dates thereof, and what steps are being taken to prevent the problem from recurring.

7. The discharger shall permit the Regional Board:
 - a. Entry upon premises in which an effluent source is located or in which any required records are kept;
 - b. Access to copy any records required to be kept under terms and conditions of this Order;
 - c. Inspection of monitoring equipment or records; and
 - d. Sampling of any discharge.

8. The discharger shall maintain in good working order and operate as efficiently as possible any facility or control system installed by the discharger to achieve compliance with the waste discharge requirements.
9. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the discharger, the discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this Board.
10. The discharger shall notify Regional Board staff at least two weeks prior to anticipated backfilling date of leachfield trenches.

Certification

I, David C. Joseph, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, North Coast Region, on September 27, 1984.

ORIGINAL SIGNED BY

David C. Joseph
Executive Officer

California Regional Water Quality Control Board
North Coast Region

Monitoring and Reporting Program No. 84-118
(Revised August 11, 2005)

for the

Klamath Community Services District

Del Norte County

Monitoring

The purpose of this monitoring program is to assure proper maintenance and long-term operation of the collection system, pumps, septic tank, and leach field system.

1. **Wastewater Volume:** The discharger shall record the monthly wastewater volume discharged to the septic tank and leach field system. Flow measurement should be made of flow into or out of the septic tank. Domestic water use may be used as an estimate until septic tank flow measuring equipment is operational; but each monthly report should include an updated status report of progress until septic tank flow measurement is operational. Peak wet-weather flows and the ratio of wet-weather flows to dry-weather flows (as measured at the septic tank) shall be evaluated annually and reported in April as part of an infiltration/inflow study. An operations and maintenance manual bearing the stamp of a professional engineer shall specify a collection system inspection protocol to be implemented if infiltration or inflow is approaching the design flows of either the septic tank or the leach fields.
2. **Groundwater Levels:** The discharger shall report which leach fields have been used for disposal of septic tank effluent during each calendar month. The discharger shall monitor the performance of the leach field by observing groundwater elevations monthly under each leach field. At least one well shall be located between or adjacent to the leach field trenches in each of the three leach fields. Monitoring and observation wells shall be constructed of three or four-inch plastic pipe (or equivalent) equipped with a locking removable cap and sealed at the ground surface to prevent infiltration of surface water. A screw cap that requires a tool to remove will suffice as a locking cap. All wells shall be perforated beginning at a depth of 18 inches below the ground surface and extending to the bottom of the well. Previously constructed wells may be used for this purpose if they can be located.

A new well shall be constructed to a depth of at least ten feet below the ground surface in each leach field wherein previously constructed wells cannot be located. Each monthly report shall include an updated status report of well construction progress until monitoring wells are operational in all three leach fields.

3. Vegetation control: Vegetation should be kept low enough to keep distribution boxes and monitoring wells visible for easy access. The maximum vegetation height in each leach field shall be measured and reported monthly.
4. Septic Tank: Sludge and scum levels shall be measured monthly in each of the four septic tank chambers to estimate seasonal rates of accumulation. When rates of accumulation are known, a reduced observation schedule may be specified in an operations and maintenance manual bearing the stamp of a professional engineer. Sludge and scum level observation frequency shall thereafter comply with that operations and maintenance manual.

Reporting

Monitoring reports shall be submitted to the Regional Water Board monthly by the last day of the following month. The discharger shall report the data on a form similar to the attached example, with status reports and annual reports included as attachments.

Ordered by Original Signed By:

Catherine Kuhlman
Executive Officer

August 11, 2005

KLAMATH COMMUNITY SERVICES DISTRICT (1A84118ODN)

MONITORING REPORT FOR THE MONTH OF _____ 200__

WASTEWATER VOLUME

(append effluent meter status report if water use is being reported)

Starting Pump Value _____

Ending Pump Value _____

Net Volume Discharged _____

LEACH FIELD MONITORING

(append well construction status report if no groundwater elevations)

Leach field	In Use?	Vegetation height (Inches)	Groundwater level (feet below ground surface)
South	Y N	_____	_____
East	Y N	_____	_____
North	Y N	_____	_____

SEPTIC TANK MONITORING

	Sludge Level inches below outlet	Scum Level inches above outlet
1 st chamber left side	_____	_____
2 nd chamber left side	_____	_____
1 st chamber right side	_____	_____
2 nd chamber right side	_____	_____

Signed: _____

Title _____