

California Regional Water Quality Control Board
Santa Ana Region

ORDER NO. 86-121

Waste Discharge Requirements
for
Forest Home Christian Conference Center
Forest Falls
San Bernardino County

The California Regional Water Quality Control Board, Santa Ana Region (hereinafter Board), finds that:

1. Forest Home Christian Conference Center (hereinafter discharger) currently discharges up to 75,000 gallons (284 cubic meters) per day to underground leaching systems in the NE1/4 of Section 13 and the SW1/4 of Section 12, T1S, R1W, SBB&M, consisting of:
 - a. 50,000 gallons (189 cubic meters) per day of treated domestic effluent, and
 - b. 25,000 gallons (95 cubic meters) per day of domestic septic tank effluent.
2. The discharge of wastes from this facility is presently regulated under waste discharge requirements contained in Order No. 79-181.
3. A Water Quality Control Plan was adopted by the Regional Board on May 13, 1983. The Plan contains water quality objectives and beneficial uses of water in the Santa Ana Region.
4. Order No. 79-181 must be updated to conform with the new Water Quality Control Plan.
5. The discharge lies within the Mill Creek Waste Discharge Prohibition area. On June 29, 1979, the Board granted an exemption for the continued discharge of wastes to subsurface disposal systems.
6. The Mill Creek area does not contain a major recognized ground water subbasin, and water quality objectives and beneficial uses for the ground water that is present have not, at this time, been established due to lack of information available.

7. Ground water in the Mill Creek area is tributary to the Bunker Hill II Ground Water Subbasin, which is beneficially used for:
 - a. Municipal and domestic supply,
 - b. Agricultural supply,
 - c. Industrial service supply, and
 - d. Industrial process supply.
8. Surface drainage in the area is tributary to Mill Creek, which is beneficially used for:
 - a. Municipal and domestic supply,
 - b. Agricultural supply,
 - c. Ground water recharge,
 - d. Hydropower generation,
 - e. Non-contact water recreation,
 - f. Cold freshwater habitat, and
 - g. Wildlife habitat.
9. The project involves the discharge of wastes from an existing facility and, as such, is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000 et seq.) in accordance with Section 15301, Chapter 3, Title 14 of the California Administrative Code.
10. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements.
11. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that the discharger shall comply with the following:

A. Discharge Specifications

1. a. The discharge of wastes to subsurface disposal systems in excess of the following limits is prohibited:

<u>Constituent</u>	<u>3-Sample Average Concentration Limit</u>	
Filtrable Residue	450	mg/l
Chloride	60	"
Boron	0.5	"

- b. The discharge of wastes with an average filtrable residue concentration based on 3 consecutive samples which exceeds the filtrable residue concentration in the water supply by more than 250 mg/l is prohibited.
- c. The discharge of treatment plant effluent in excess of the following limits is prohibited:

<u>Constituent</u>	<u>30-Day Average Concentration Limit</u>
Suspended Solids	30 mg/l

- 2. Neither the treatment nor the disposal of wastes shall cause a nuisance and/or pollution, as defined in the California Water Code.
- 3. All wastes discharged to subsurface disposal systems shall be maintained below the surface of the ground at all times.
- 4. The discharge of wastes to property not owned or controlled by the discharger is prohibited.

B. Provisions

- 1. The discharger shall comply with Monitoring and Reporting Program No. 86-121.
- 2. The discharger shall promptly report to the Board any proposed change in the character, location, or method of disposal of the discharge or any change in ownership of the facility.
- 3. The discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided to the Executive Officer (714-782-4130), the City of Redlands Water Department (714-798-7551), and the Office of Emergency Services (1-800-852-7550), if appropriate, as soon as the discharger becomes aware of the circumstances. A written report shall be submitted within five days and shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times and, if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

4. The discharger shall permit the Regional Board:
 - a. Entry upon the premises in which an effluent source is located or in which any required records are kept;
 - b. Access to copy any records required to be kept under the terms and conditions of this order;
 - c. Inspection of monitoring equipment or records; and
 - d. Sampling of any discharge.
5. This order also rescinds Order No. 79-181, the present waste discharge requirements for this facility.

I, James R. Bennett, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an order adopted by the California Regional Water Quality Control Board, Santa Ana Region, on August 8, 1986.

JAMES R. BENNETT
Executive Officer

California Regional Water Quality Control Board
Santa Ana Region

Revised Monitoring And Reporting Program (M&RP) No. 86-121

for
Forest Home Christian Conference Center
Forest Falls
San Bernardino County

Effluent Monitoring

1. Unless otherwise noted, all sampling, sample preservation, and analyses shall be performed in accordance with the latest edition of "Guidelines Established Test Procedures for Analysis of Pollutants" promulgated by the United States Environmental Protection Agency.
2. All analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services.
3. All samples shall be representative of the waste discharge under the conditions of peak load.
4. The following shall constitute the effluent monitoring program for the treatment plant effluent:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>			<u>Frequency of</u> <u>Sampling</u>
Suspended Solids	mg/l	Composite	(Treated Effluent)		Weekly
Filtrable Residue	"	"	"	"	Bi-Monthly
Chloride	"	"	"	"	"
Boron	"	"	"	"	"

Weekly sample shall be taken on random working days of the week. Bi-monthly samples shall be taken on the fifth working day of January, March, May, July, September, and November.

5. A composite sample is defined as a combination of no fewer than eight individual samples obtained over the specified sampling period. The volume of each individual sample shall be proportional to the discharge flow rate at the time of sampling. The compositing period shall equal the specific sampling period, or 24 hours, if no period is specified.
6. Bi-monthly samples of the septic tank effluent, made up of individual grab samples from the camp areas not connected to the treatment plant and weighted according to flow, shall be taken and analyzed for filtrable residue, chloride, and boron.
7. Daily flow data from both the septic tank-subsurface disposal

systems and the treatment plant shall be recorded and provided on a monthly basis.

Water Supply Monitoring

Annually, in July, the water supply shall be analyzed for the following constituents: filtrable residue, chloride, and boron.

Reporting

All reports shall be submitted by the 20th day of February, April, June, August, October, and December, and shall include:

1. Results of mineral analyses;
2. The maximum daily flow to each disposal area during each month in the monitoring period and the date on which it occurred;
3. The maximum daily occupancy of center facilities during each month in the monitoring period and the date(s) on which it occurred;
4. Flow data; and
5. A statement regarding maintenance the wastes below the ground surface.

For every item where the requirements are not met, the discharger shall submit a statement of the actions undertaken or proposed which will bring the discharge into full compliance with the requirements at the earliest time and submit a timetable for correction.

All reports shall be signed by a responsible officer or duly authorized representative of the discharger and shall be submitted under penalty of perjury.



Gerard J. Thibeault
Executive Officer

January 13, 1997

California Regional Water Quality Control Board
Santa Ana Region

Monitoring and Reporting Program No. 86-121
for
Forest Home Christian Conference Center
Forest Falls
San Bernardino County

Effluent Monitoring

1. Unless otherwise noted, all sampling, sample preservation, and analyses shall be performed in accordance with the latest edition of "Guidelines Establishing Test Procedures for Analysis of Pollutants" promulgated by the United States Environmental Protection Agency.
2. All analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services.
3. All samples shall be representative of the waste discharge under the conditions of peak load.
4. The following shall constitute the effluent monitoring program for the treatment plant effluent:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Frequency of Sampling</u>
Suspended Solids	mg/l	Composite (Treated Effluent)	Weekly
Filtrable Residue	"	"	Bi-Monthly
Chloride	"	"	"
Boron	"	"	"

Weekly samples shall be taken on random working days of the week. Bi-monthly samples shall be taken on the fifth working day of January, March, May, July, September, and November.

5. A composite sample is defined as a combination of no fewer than eight individual samples obtained over the specified sampling period. The volume of each individual sample shall be proportional to the discharge flow rate at the time of sampling. The compositing period shall equal the specific sampling period, or 24 hours, if no period is specified.
6. Bi-monthly samples of the septic tank effluent, made up of individual grab samples from the camp areas not connected to the treatment plant and weighted according to flow, shall be taken and analyzed for filtrable residue, chloride, and boron.

7. Daily flow data from both the septic tank-subsurface disposal systems and the treatment plant shall be recorded and provided on a monthly basis.

Water Supply Monitoring

Annually, in July, the water supply shall be analyzed for the following constituents: filtrable residue, chloride, and boron.

Reporting

All reports shall be submitted by the fifth day of February, April, June, August, October, and December, and shall include:

1. Results of mineral analyses;
2. The maximum daily flow to each disposal area during each month in the monitoring period and the date on which it occurred;
3. The maximum daily occupancy of center facilities during each month in the monitoring period and the date(s) on which it occurred;
4. Flow data; and
5. A statement regarding maintenance of the wastes below the ground surface.

For every item where the requirements are not met, the discharger shall submit a statement of the actions undertaken or proposed which will bring the discharge into full compliance with requirements at the earliest time and submit a timetable for correction.

All reports shall be signed by a responsible officer or duly authorized representative of the discharger and shall be submitted under penalty of perjury.

Ordered by _____

JAMES R. BENNETT
Executive Officer

August 8, 1986