

California Regional Water Quality Control Board
North Coast Region

ORDER NO. 87-121
ID NO. IA761620S15

WASTE DISCHARGE REQUIREMENTS

FOR

GRENADA SANITARY DISTRICT

Siskiyou County

The California Regional Water Quality Control Board, North Coast Region, finds that:

1. The Grenada Sanitary District (hereafter the discharger) owns and operates sewage collection, treatment, and disposal facilities which are located in the SE 1/4 of Section 22, T44N, R6W, MDB&M, as shown in Attachment "A", incorporated herein and made a part of this Order.
2. In May 1987, the discharger completed construction of wastewater system improvements in accordance with an Enforcement Time Schedule in Order No. 83-97, which will enable it to properly operate and maintain the treatment works in compliance with existing requirements in Order No. 76-162. Wastewater treatment facilities consist of a gravity sewer followed by septic tank and evaporation/percolation ponds. There are no provisions for surface discharge. Ponds have a surface area of 0.7 acre and receive an estimated waste flow of 21,000 gallons per day. The original septic tank and collection line were constructed in 1917.
3. In 1976, the Board adopted Order No. 76-162, Waste Discharge Requirements for the Grenada Sanitary District.
4. The Regional Board adopted the Water Quality Control Plan for the Klamath River Basin on March 20, 1975. The Plan has been amended on subsequent dates. The Plan prohibits the discharge of waste to all surface freshwater impoundments and the Klamath River and its tributaries, including the Shasta River.
5. Beneficial uses of the Shasta River and its tributaries include:
 - a. municipal, industrial, and agricultural water supply
 - b. groundwater recharge
 - c. freshwater replenishment of lakes and streams
 - d. water contact and nonwater contact recreation
 - e. warm freshwater habitat
 - f. cold freshwater habitat

- g. wildlife habitat
 - h. migration route for anadromous fish
 - i. fish spawning
6. Disposal of treated waste by percolation may have an impact on groundwaters of the Shasta River and Shasta Valley area. Beneficial uses of these groundwaters include domestic and agricultural water supply.
 7. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.
 8. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.
 9. This facility is exempt from the provisions of the California Environmental Quality Act because of its status as an existing facility. The Regional Board finds that this facility will not cause adverse water quality related effects if conducted in conformance with this Order.

THEREFORE, IT IS HEREBY ORDERED that Waste Discharge Requirements Order No. 76-162 and Order No. 83-97 be rescinded and the Grenada Sanitary District shall comply with the following:

A. DISCHARGE PROHIBITIONS

1. There shall be no discharge of waste to the Shasta River or its tributaries.
2. There shall be no discharge of waste to land which is not controlled by the discharger.
3. The dissolved oxygen content of the wastewater in the evaporation/percolation ponds shall not be less than 1.0 mg/l.
4. The discharge shall not cause taste, odor, or color in the groundwaters of the area.

B. PROVISIONS

1. There shall be no discharge of untreated waste at any time.
2. Neither the treatment nor discharge of wastes shall create a nuisance or pollution as defined in the California Water Code.
3. The discharger shall maintain in good working order and operate as efficiently as possible any facility or control system installed by the discharger to achieve compliance with the waste discharge requirements.

4. The discharger shall permit the Regional Board:
 - a. entry upon premises in which an effluent source is located or in which any required records are kept;
 - b. access to copy any records required to be kept under terms and conditions of this Order.
 - c. inspection of monitoring equipment or records; and
 - d. sampling of any discharge.
5. In the event the discharger is unable to comply with any of the conditions of this Order due to:
 - a. breakdown of waste treatment equipment;
 - b. accidents caused by human error or negligence; or
 - c. other causes, such acts of nature;

the discharger shall notify the Executive Officer by telephone as soon as he or his agents have knowledge of the incident and confirm this notification in writing within two weeks of the telephone notification. The written notification shall include pertinent information explaining reasons for the noncompliance and shall indicate what steps were taken to correct the problem and the dates thereof, and what steps are being taken to prevent the problem from recurring.

6. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the discharger, the discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this Board.
7. The discharger shall file with the Board a Report of Waste Discharge at least 120 days before making any material change or proposed change in the character, location or volume of the discharge.
8. The discharger shall comply with the Contingency Planning and Notification Requirements for Accidental Spills and Discharges, Order No. 74-151, attached to and made part of this Order within 90 days of the adoption of this Order.

Certification

I, Benjamin D. Kor, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, North Coast Region, on September 24, 1987.

ORIGINAL SIGNED BY

Benjamin D. Kor
Executive Officer

California Regional Water Quality Control Board
North Coast Region

MONITORING AND REPORTING PROGRAM NO. 87-121

FOR

GRENADA SANITARY DISTRICT

Siskiyou County

Disposal Area Monitoring

The wastewater flow shall be recorded continuously.

At times when waste is ponded, a representative sample shall be collected monthly during the early morning hours and analyzed for dissolved oxygen content.

The discharger shall install suitable staff gauges in disposal ponds. Monthly measurements of pond levels shall be taken and reported to the Regional Board.

Operation and Maintenance Schedule

Septic Tank

- a. Records shall be kept of pumping frequency.
- b. Scum and sludge buildup shall be measured annually.

Ponds

- a. Weeds in or near the pond shall be removed monthly or as necessary.
- b. Breakup of surface scum shall be performed on a monthly basis.
- c. Monthly observations shall be made of dike conditions.

Reporting

Monthly monitoring reports shall be submitted to the Regional Board by the fifteenth day of the month following the sampling period. In reporting the monitoring data, the discharger shall arrange the data in tabular form so that the dates and measurements are readily discernible.

Ordered by _____

Benjamin D. Kor
Executive Officer

September 24, 1987