



California Regional Water Quality Control Board

Santa Ana Region



Winston H. Hickox
Secretary for
Environmental
Protection

Internet Address: <http://www.swrcb.ca.gov/rwqcb8>
3737 Main Street, Suite 500, Riverside, California 92501-3348
Phone (909) 782-4130 - FAX (909) 781-6288

Gray Davis
Governor

*The energy challenge facing California is real. Every Californian needs to take immediate action to reduce energy consumption.
For a list of simple ways you can reduce demand and cut your energy costs, see our website at www.swrcb.ca.gov/rwqcb8.*

March 12, 2003

Ken Caldwell
Water Quality Specialists of San Diego, Inc.
917 Seph Way
Escondido, CA 92027

REVISED MONITORING AND REPORTING PROGRAM NO. 99-54, WEST HILLS GOLF AND COUNTRY CLUB

Dear Mr. Caldwell,

Attached is a copy of the Revised Monitoring and Reporting Program for Order No. 99-54. As discussed, sampling requirements for biochemical oxygen demand and suspended solids have been revised. Sampling requirements for chloride, boron and chlorine residual have been removed.

Should you have any questions or concerns regarding this change, please contact Nikki Outwin of my staff at (909) 782-4963.

Sincerely,

Gerard J. Thibeault
Executive Officer

Enclosure

noutwin/West Hills Revised M&R - coverletter

California Environmental Protection Agency



Recycled Paper

California Regional Water Quality Control Board
Santa Ana Region

Revised Monitoring and Reporting Program No. 99-54

for
Western Hills Golf & Country Club
San Bernardino County

A. General Monitoring Provisions:

1. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. The analytical techniques or methods used; and
 - e. The results of such analyses.
2. All monitoring instruments and devices used by the discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy.
3. The flow measurement system shall be calibrated at least once per year or more frequently, to ensure continued accuracy.
4. All analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services or at a laboratory approved by the Executive Officer of the Regional Board.

B. Definition:

1. A "composite" sample is defined as a combination of no fewer than eight individual grab samples obtained over the specified sampling period. The volume of each individual grab sample shall be proportional to the discharge flow rate at the time of sampling. The compositing period shall equal the specified sampling period, or 24 hour, if no period is specified.

C. Effluent Monitoring:

1. A sampling station shall be established at the point of discharge and shall be located where representative samples of the effluent can be obtained.
2. On the 15th working day of February, April, June, August, October, and December, a composite sample of the effluent shall be taken and analyzed for total dissolved solids.
3. Grab samples shall be taken and analyzed for total coliform organisms daily, Monday through Friday. Grab samples for coliform organisms do not need to be collected on weekends and national holidays¹.
4. On a weekly basis, grab samples shall be taken and analyzed for pH.
5. On a weekly basis, a composite sample of effluent shall be taken and analyzed for biochemical oxygen demand and suspended solids.
6. The total daily effluent flow from the treatment plant shall be recorded and the average daily flow for each month determined
7. Every Monday, the freeboard in the impoundment shall be measured and entered in a permanent log.

D. Water Supply Monitoring:

At least once annually, in July, a sample of the water supply to the plant shall be collected and shall be analyzed for total dissolved solids.

E. Reporting:

1. Daily flow and bacteriological analyses and weekly biochemical oxygen demand, suspended solids, and pH data shall be compiled and submitted once every month; bimonthly chemical analyses shall also be submitted with the monthly reports, where applicable. All monitoring reports shall be submitted by the 30th day of the month following sampling and shall include:
 - a. A copy of the chemical, physical, and/or bacteriological analyses, and
 - b. Flow data

¹ National holidays: Independence Day, Labor Day, Veterans Day, Thanksgiving Day, Christmas Day, New Year's Day, President's Day, and Memorial Day.