

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 5-00-086
FOR
EL DORADO IRRIGATION DISTRICT
EL DORADO LIFT STATION EQUALIZATION POND
EL DORADO COUNTY

This monitoring and reporting program (MRP) incorporates requirements for monitoring of temporarily stored effluent and is issued pursuant to Water Code Section 13267. The Discharger shall not implement any changes to this MRP unless and until a revised MRP is issued by the Executive Officer. Regional Board staff prior to implementation of sampling activities shall approve specific sample station locations. Sample collection stations shall be established such that the samples collected are representative of the nature and volume of the material(s) sampled.

NORTH POND MONITORING

The El Dorado Lift Station Equalization Pond shall be measured for the following constituents according to the schedule below. Note that the constituents may be monitored with field equipment.

<u>Constituents</u>	<u>Units</u>	<u>Sample Type</u>	<u>Sampling Frequency</u>
Flow	gpd	Continuous	Daily, during use
Freeboard	Feet, ± 0.1	Measurement	Daily, during use
Dissolved Oxygen	mg/l	Grab	Daily, during use
pH	pH units	Grab	Daily, during use
Electrical Conductivity	μ mhos/cm	Grab	Daily, during use

SLUDGE MONITORING

A representative composite sample of sludge shall be collected annually in accordance with EPA's *POTW Sludge Sampling and Analysis Guidance Document, August 1989*, and tested for the following metals:

Cadmium	Lead
Chromium	Nickel
Copper	Zinc

Sampling records shall be retained for a minimum of five years. A log shall be kept of sludge quantities generated and of handling and disposal activities. The frequency of entries is discretionary; however, the log shall be complete enough to serve as a basis for part of the annual report.

REPORTING

In reporting monitoring data, the Discharger shall arrange the data in tabular form so that the date, sample type (e.g., influent, effluent, etc.), and reported analytical result for each sample are readily discernible. The data shall be summarized in such a manner to clearly illustrate compliance with waste discharge requirements and spatial or temporal trends, as applicable. The results of any monitoring done more frequently than required at the locations specified in the Monitoring and Reporting Program shall be reported to the Regional Board.

Annual Monitoring Report

The Annual Report is **due by 30 June of each year**. At a minimum, the Annual Monitoring Report shall include the following:

1. The contents of the Daily Monitoring described above;
2. If requested by staff, tabular and graphical summaries of all monitoring data obtained during the previous year;
3. Information on the disposal of biosolids if any;
4. Sludge monitoring;
5. A scaled map showing relevant structures and features of the facility and the locations of sampling stations;
6. Copies of laboratory analytical report(s) if any;
7. A comparison of monitoring data to the discharge specifications and explanation of any violation of those requirements; and
8. A discussion of compliance and the corrective action taken, as well as any planned or proposed actions needed to bring the discharge into full compliance with the waste discharge requirements.

The Discharger shall implement the above monitoring program as of the date of this Order.

GARY M. CARLTON, Executive Officer