

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION

MONITORING AND REPORTING PROGRAM NO. 89-76

FOR
SAN LUCAS COUNTY WATER DISTRICT
COMMUNITY WASTEWATER FACILITIES
MONTEREY COUNTY

Influent Monitoring

Volume of the influent to the wastewater treatment facility shall be measured and reported as follows:

	<u>Units</u>	<u>Type of Sample</u>	<u>Minimum Sampling and Analyzing Frequency</u>
Flow Volume	mgd	Metered	Daily
Flow Volume	mgd	Calculated Mean	Monthly

Effluent Monitoring

Representative samples of the wastewater discharged to the designated wastewater disposal area shall be collected and analyzed for the following constituents:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Minimum Sampling and Analyzing Frequency</u>
Total Nitrogen(as N) mg/l (Total Kjeldahl + Nitrate + Nitrite)		Grab	April and October
Total Dissolved Solids	mg/l	Grab	" "
Sodium	mg/l	Grab	" "
pH	--	Grab	" "

Water Supply Monitoring

Samples typical of the municipal water supply shall be collected and analyzed twice annually for the following constituents:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Total Dissolved Solids	mg/l	Grab	October
Sodium	mg/l	Grab	"
Nitrate Nitrogen (as N)	mg/l	Grab	"

Disposal Area Inspections

The Discharger shall make daily inspections of the treatment and disposal area. A log of these inspections shall be maintained. A summary of observations made during the inspections shall be submitted with each monthly monitoring report.

Reporting

Monitoring reports shall be submitted by the 20th Day of May and November.

ORDERED BY

William P. Leonard
Executive Officer

June 9, 1989

Date

sm5:89-76.MRP