

California Regional Water Quality Control Board
North Coast Region

ORDER NO. 81-131

WASTE DISCHARGE REQUIREMENTS

for

MONTAIR SUBDIVISION HOMEOWNERS ASSOCIATION, INC.
HOLIDAY DEVELOPMENT COMPANY, INC.

AND

JOHN M. HOWE

Siskiyou County

The California Regional Water Quality Control Board, North Coast Region, finds that:

1. On February 9, 1981, Mr. John M. Howe, President and owner of Holiday Development Company, Inc., a California Corporation, submitted a report of waste discharge describing the Montair Subdivision.
2. Mr. John M. Howe proposes to construct a 44 unit subdivision located in Shasta Valley approximately one mile west of the City of Montague and adjacent to and south of State Route 3 in Sections 20 and 29, T45N, R6W, MDB & M (Attachment A).
3. Up to 13,200 gallons of wastewater will be generated daily. Collection and sewage transport will be accomplished by a low pressure collection system. Each home will be served by a septic tank for solids removal with the effluent pumped to a facultative lagoon. Following treatment in the lagoon and after disinfection, final disposal will occur by percolation and evapotranspiration on lands upgradient from a reservoir with a capacity of 46 acre feet. Any runoff from the irrigated area will discharge to the reservoir. Winter storage of wastewater will also occur in the reservoir. Pumping facilities will permit irrigation and disposal of wastewater stored in the reservoir.

The average annual rainfall in the area is 12.5 inches. All storage and disposal facilities are designed for the recorded maximum of 24.19 inches of rain which occurred in the years 1889-1890.

Surface drainage is tributary to the Shasta River which is in turn tributary to the Klamath River.

4. The Regional Board adopted a Water Quality Control Plan for the Klamath River Basin on March 20, 1975. The Plan has been amended on March 25, 1976 and June 21, 1979.
5. Beneficial uses of the Shasta River and its tributaries include:

- a. agricultural water supply
 - b. groundwater recharge
 - c. freshwater replenishment of lakes and streams
 - d. contact and water contact recreation
 - e. warm freshwater habitat
 - f. cold freshwater habitat
 - g. wildlife habitat
 - h. migration route for anadromous fish
 - i. fish spawning area
6. The Basin Plan specifically prohibits the discharge of wastewater to the Klamath River and its tributaries.
 7. The Board has notified the discharger and interested persons and agencies of its intent to prescribe waste discharge requirements for the proposed discharge.
 8. The Board, in a public meeting, heard and considered all comments pertaining to the proposed discharge.
 9. A negative declaration was adopted for this project. The Regional Board finds that this facility will not cause adverse environmental impacts if conducted in accordance with the prohibitions, specifications and provisions contained in this Order.

THEREFORE IT IS HEREBY ORDERED that the Montair Homeowners Association, Inc., Holiday Development Company, Inc., and Mr. John M. Howe shall comply with the following:

A. DISCHARGE PROHIBITIONS:

1. The discharge of waste to the Shasta River or its tributaries is prohibited.
2. The discharge of waste to land which is not owned or controlled by the discharger is prohibited.

B. DISCHARGE SPECIFICATIONS:

1. Wastewater discharged to the irrigation disposal facility shall be applied at a rate which will allow maximum percolation and evaporation and minimize runoff.
2. The mean daily dry weather flow of waste shall not exceed 13,200 gallons per day.
3. Neither the treatment nor the discharge of waste shall cause a pollution or nuisance as defined in Section 13050 of the California Water Code.
4. Surface drainage from the surrounding upgradient areas (other than the disposal area) shall be excluded from the disposal area.
5. All surface runoff from the disposal area shall be intercepted and disposed of in a manner consistent with this Order.

6. Wastewater discharged to the irrigated disposal field and the storage reservoir shall not contain constituents in excess of the following limits:

<u>Constituent</u>	<u>Units</u>	<u>Mean</u>	<u>Maximum</u>
BOD (20°C, 5-day)	mg/l	50	80
NFR	mg/l	50	80
Settleable Matter	ml/l	1.0	2.0
Coliform Organisms	MPN/100 ml	23*	230
Hydrogen Ion	pH not less than 6.5 nor more than 8.5		

*Median

7. The dissolved oxygen content of the wastewater in the treatment pond and the storage reservoir shall not be less than 1.0 mg/l.

C. PROVISIONS:

1. The discharger shall submit to the Regional Board a comprehensive operations and maintenance manual and designate and train an operator prior to the use of the treatment and disposal facilities.
2. Each septic tank effluent pumping station shall be equipped with alarm indicating both visually and by sound a "high water" condition. The minimum working capacity shall be 300 gallons, including a 100 gallon minimum dose and 200 gallons additional storage above the high water alarm level.
3. Adequate capacity in the storage reservoir shall be provided by October 1, of each year for storage of winter wastewater flows. This available capacity shall include storage of rainfall and runoff from the irrigation-disposal field as calculated from the recorded maximum rainfall.
4. In the event the discharger is unable to comply with any of the conditions of this Order due to:
 - a. breakdown of waste treatment equipment;
 - b. accidents caused by human error or negligence; or
 - c. other causes, such as acts of nature;

the discharger shall notify the Executive Officer by telephone as soon as he or his agents have knowledge of the incident and confirm this notification in writing within two weeks of the telephone notification. The written notification shall include pertinent information explaining reasons for the noncompliance and shall indicate what steps were taken to correct the problem and the dates thereof, and what steps are being taken to prevent the problem from recurring.

5. The discharger shall comply with the Monitoring and Reporting Program No. 81-131 and the General Provisions for Monitoring and Reporting and any modifications to these documents as specified by the Executive Officer. Such documents are attached to this Order and incorporated herein.
6. The discharger shall file a report of waste discharge at least 120 days before making any material change or proposed change in the character, location, or volume of the discharge.
7. The discharger shall permit the Regional Board:
 - a. entry upon premises in which an effluent source is located or in which any required records are kept;
 - b. access to copy any records required to be kept under terms and conditions of this Order;
 - c. inspection of monitoring equipment or records; and
 - d. sampling of any discharge.
8. The discharger shall maintain in good working order and operate as efficiently as possible any facility or control system installed to achieve compliance with waste discharge requirements.
9. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of at a legal point of disposal, and in accordance with the provisions of Division 7.5 of the California Water Code. For the purpose of this requirement, a legal point of disposal is defined as one for which waste discharge requirements have been prescribed by a Regional Water Quality Control Board and which is in full compliance therewith.

Certification

I, David C. Joseph, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, North Coast Region, on May 28, 1981.

ORIGINAL SIGNED BY

David C. Joseph
Executive Officer

California Regional Water Quality Control Board
North Coast Region

MONITORING & REPORTING PROGRAM NO. 81-131

for

MONTAIR SUBDIVISION HOMEOWNERS ASSOCIATION, INC.
HOLIDAY DEVELOPMENT COMPANY, INC.

AND

JOHN M. HOWE

Siskiyou County

MONITORING PROGRAM

The purpose of this Monitoring Program is to assure compliance with Waste Discharge Requirements by careful, thorough, conscientious maintenance and operating of wastewater treatment and disposal facilities. The following shall constitute the Monitoring Program:

EFFLUENT MONITORING

<u>Constituent</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
BOD	Grab	Monthly*
NFR	Grab	Monthly*
Suspended Solids	Grab	Monthly
Coliform Organisms	Grab	Monthly
Hydrogen Ion	Grab	Monthly
Flow	--	Continuous

*This frequency shall be modified to "Quarterly" following the first year of operation.

RESERVOIR MONITORING

A staff gage shall be installed at a convenient location within the reservoir. The elevation of the reservoir spillway shall be referenced as zero. Distances from the spillway (reference zero) to water levels shall be calibrated in feet and tenths of feet. The level necessary to provide winter storage shall be marked with a red line. All other marks shall be black on white.

The water level shall be measured as follows:

<u>Period</u>	<u>Frequency</u>
October 1 to May 31	Once Weekly
June 1 to September 30	Once Monthly

Effluent Pumping Facilities

All septic tanks and pumping facilities shall be inspected at least once each year for sludge accumulations. When the sludge level in the septic tank is within 10 inches of the outlet device, the tank and pump station should be pumped.

During the annual inspection, all wiring, piping, etc., shall be visually inspected for any damage. The alarm shall be tested and the homeowner reminded of its purpose. The annual inspection shall be completed by October 1st of each year.

REPORTING

Monthly monitoring reports shall be submitted to the Regional Board by the 15th day of the following month. In reporting the monitoring data, the discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data will be summarized in such a manner to illustrate clearly the compliance with waste discharge requirements. A brief narrative report shall be prepared describing the findings of the annual inspection.

The monitoring and any necessary narrative reports shall be transmitted in accordance with specifications of Resolution No. 71-5 adopted by this Board on February 3, 1971.

IMPLEMENTATION

The monitoring program shall commence immediately upon start-up of the disposal operation.

Ordered by ORIGINAL SIGNED BY
David C. Joseph
Executive Officer
May 28, 1981

