

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION**

**MONITORING AND REPORTING PROGRAM NO. R3-2003-081
FOR**

**CITY OF SAN LUIS OBISPO
PRIMARY USER OF RECLAIMED WATER,
SAN LUIS OBISPO COUNTY**

RECLAIMED WATER MONITORING

The quantity of reclaimed water distributed to reuse sites shall be metered daily.

The User shall:

- ° Continuously monitor and record chlorine residual concentration at a point after the final chlorine contact basin. The lowest CT value shall be recorded daily.
- ° Provide user guidelines, including the User Manual, the Order and other guidance as may be needed, to each Site Supervisor and instructions for implementing the guidelines.
- ° Instruct all District employees who are routinely in the field, such as water meter readers, to report incidents of unauthorized daytime irrigation activity and area runoff to the District's water reclamation inspector. If it is determined that the irrigation is unauthorized, the inspector shall notify the Site Supervisor and the Regional Water Quality Control Board by telephone within 24 hours, followed by a written report within 15 days describing the corrective action taken.
- ° Cooperate with San Luis Obispo County Environmental Health Services and California Department of Health Services, Public Water Supply Branch, to ensure that backflow devices are present, tested on a regular basis by a certified individual, and repaired or replaced if found defective.
- ° Periodically (at least quarterly) inspect the operation of the reuse site irrigation systems to verify that reclaimed water is being applied in accordance with the requirements specified in Order No. R3-2003-081.
- ° On an annual basis, perform a cross-connection test at each landscape irrigation reuse site.
- ° Conduct quarterly interviews with each Site Supervisor to determine whether system modifications have been made properly, to solicit their assessment of system peculiarities, and to verify employee training. Unusual occurrences shall be promptly addressed.
- ° Conduct quarterly review of the monthly reclaimed water meter readings to identify unusual usage behavior, with follow-up investigations if patterns change dramatically.

REPORTING

The User shall submit quarterly reports (Jan, Apr, Jul, Oct) summarizing reclaimed water use, including the total volume of reclaimed water supplied, and the total number of reclaimed use sites and their locations. Reports shall include records of the User's reuse site inspections and results of the annual cross-connection tests.

Reports shall be submitted by the 20th day of the month following the end of the preceding quarter.

Ordered by: _____/S/
Executive Officer

Date: _____