

California Regional Water Quality Control Board
Santa Ana Region

ORDER NO. 00-75

Waste Discharge Requirements
for
Southeastern California Conference of Seventh-day Adventists
Pine Springs Ranch
Riverside County

The California Regional Water Quality Control Board, Santa Ana Region (hereinafter, Regional Board), finds that:

1. On October 14, 1994, the Regional Board adopted Order No. 94-14 for the discharge of tertiary treated wastewater from Southeastern California Conference of Seventh-day Adventists (hereinafter, discharger) from Pine Springs Ranch in the Mountain Center area of Riverside County.
2. Pine Springs Ranch is a resort type facility with a lodge, cafeteria, and parking spaces for recreational vehicles. The facility will ultimately be able to accommodate up to 1,200 people during large, short-term (3-5 day) events.
3. Originally, tertiary treated wastewater was proposed to be used for landscape irrigation at the Ranch. Order No. 94-14 specified requirements for this use. The discharger no longer proposes to recycle the wastewater. Undisinfected secondary treated wastewater will now be discharged to a spray disposal area that will be restricted from the public.
4. Order No. 94-14 must be revised to reflect the change in wastewater treatment and disposal. The order must also be updated to reflect changes in state laws, regulations, plans, and policies.
5. The wastewater treatment facility is an extended aeration plant. An average of approximately 15,000 gallons per day of wastewater is currently treated. The design capacity of the treatment facility is 60,000 gallons per day. Sludge and other solids are dried in sludge beds and disposed of at Riverside County landfills.
6. The facility and the point of discharge are located within portions of Section 27, T5S, R3E, SBB&M.
7. A revised Water Quality Control Plan for the Santa Ana River Basin (Basin Plan) became effective on January 24, 1995. The Basin Plan contains beneficial uses and water quality objectives for waters in the Santa Ana Region.

8. The area of the discharge/use is tributary to the Garner Valley Groundwater Subbasin, the beneficial uses of which include:
 - a. Municipal and domestic supply, and
 - b. Agricultural supply.
9. The surface drainage from the Ranch is tributary to Lake Hemet, the beneficial uses of which include:
 - a. Municipal and domestic supply,
 - b. Agricultural supply,
 - c. Groundwater recharge,
 - d. Water contact recreation,
 - e. Non-contact water recreation,
 - f. Cold freshwater habitat,
 - g. Warm freshwater habitat,
 - h. Wildlife habitat,
 - i. Hydropower generation, and
 - j. Spawning, reproduction, and development.
10. The requirements contained in this order are necessary to meet the water quality objectives and protect the beneficial uses specified in the Basin Plan.
11. The project involves the continued operation of an existing facility and, as such, is exempt from the California Environmental Quality Act (Public Resources Code, Section 21100 et. seq) in accordance with Section 15301, Chapter 3, Title 14, California Code of Regulations.
12. The Regional Board has notified the discharger and other interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written views and recommendations.
13. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that the discharger, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder and the provisions of the Clean Water Act and regulations and guidelines adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

1. The spray irrigation of wastes to any undesignated portions of the Ranch is prohibited. Undisinfected secondary effluent is to be sprayed only within the fenced and posted areas of the Ranch.
2. The discharge of wastes to property not owned or controlled by the discharger is prohibited.
3. Odors, vectors, and other nuisances of sewage origin are prohibited outside of the treatment plant site.
4. The discharge of any substances in concentrations toxic to human, animal, plant or aquatic life is prohibited.

B. Discharge Specifications:

1. The discharge of wastes containing constituent concentrations in excess of the following limits is prohibited:

Constituents	Unit	Monthly Average Concentration Limit
Biochemical Oxygen Demand	"	30
Suspended Solids	"	30

- 2.a. The discharge of wastes containing a 12-month average total dissolved solids (TDS) concentration in excess of 550 mg/l is prohibited.
- 2.b. The discharge of wastes containing a 12-month average TDS concentration that exceeds the 12-month average TDS concentration in the water supply by more than 250 mg/l is prohibited.

For Discharge Specifications 2.a. and 2.b., whichever limitation results in the lower average TDS concentration shall be controlling.

3. The pH of the discharge shall at all times be within the range of 6 and 9 pH units.

C. Provisions:

1. The discharger shall comply with Monitoring and Reporting Program No. 00-75 as ordered by the Executive Officer of the Regional Board. This monitoring and reporting program may be modified by the Executive Officer at any time during the term of this order, and may include a reduction or an increase in the number of parameters to be monitored, the frequency of the monitoring, or the number and size of samples collected.
2. Neither the treatment nor the discharge of wastes shall cause or threaten to cause a nuisance or pollution as defined in Section 13050 of the California Water Code.
3. The wastewater treatment and storage facilities shall be protected from a 100-year frequency flood.
4. Compliance with the monthly average concentration limits specified in Discharge Specification B.1. shall be based on the flow weighted average of the analytical results of all samples collected during any calendar month.
5. The discharger shall file with the Board a report of waste discharge at least 120 days before making any material change or proposed change in the character, location, or volume of the discharge or in the operator or property ownership of any portions of the facility identified in this order.
6. The discharger shall maintain a copy of this order at the site so that it is available at all times to site operating personnel. Key operating personnel shall be familiar with its contents.
7. Collected screenings, sludge, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.
8. The discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the discharger to achieve compliance with the conditions of this order. Proper operation and maintenance also includes adequate laboratory controls, appropriate quality assurance procedures, effective performance, adequate funding, adequate staffing and training and adequate process controls. This provision requires the operation of back up or auxiliary facilities or similar systems that are installed by a discharger only when the operation is necessary to achieve compliance with the conditions of the order.
9. Whenever the discharger monitors any pollutant more frequently than is required by this order, the results of this monitoring shall be included in the calculation and reporting of the

data submitted in the discharge monitoring report specified by the Executive Officer.

10. The requirements prescribed herein do not authorize the commission of any act causing injury to the property of another, nor protect the discharger from his liabilities under federal, state, or local laws.
11. This order does not convey any property rights of any sort, or any exclusive privilege.
12. The Regional Board, and other authorized representatives shall be allowed:
 - a. Entry upon premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this order;
 - b. Access to copy any records that are kept under the conditions of the order;
 - c. To inspect any facility, equipment (including monitoring and control equipment), practices, or operations regulated or required under this order; and
 - d. To photograph, sample and monitor for the purpose of assuring compliance with this order.
12. The discharger shall take all reasonable steps to minimize or prevent any discharge that has a reasonable likelihood of adversely affecting human health or the environment.
13. Order No. 94-14 is hereby rescinded.

I, Gerard J. Thibeault, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an order adopted by the California Regional Water Quality Control Board, Santa Ana Region, on October 6, 2000.


Gerard J. Thibeault
Executive Officer

California Regional Water Quality Control Board
Santa Ana Region

Monitoring and Reporting Program No. 00-75

for
Southeastern California Conference of Seventh-day Adventists
Pine Springs Ranch
Riverside County

A. General Monitoring Provisions:

1. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. The analytical techniques or methods used; and
 - e. The results of such analyses.
2. All monitoring instruments and devices used by the discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy.
3. The flow measurement system shall be calibrated at least once per year or more frequently, to ensure continued accuracy.
4. All analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services or at a laboratory approved by the Executive Officer of the Regional Board.

B. Definition:

1. A "composite" sample is defined as a combination of no fewer than eight individual grab samples obtained over the specified sampling period. The volume of each individual grab sample shall be proportional to the discharge flow rate at the time of sampling. The compositing period shall equal the specified sampling period, or 24 hour, if no period is specified.

C. Effluent Monitoring:

1. A sampling station shall be established at the point of discharge and shall be located where representative samples of the effluent can be obtained.

2. The following shall constitute the effluent monitoring program:

Constituents	Unit	Type of sample	Minimum Frequency of Analysis
Flow	MGD	Recorder/Totalizer	Continuous
pH	pH units	Grab	Weekly
Biochemical Oxygen Demand	mg/l	Composite	Weekly
Suspended Solids	"	"	Weekly
Total Dissolved Solids	"	"	Monthly

D. Water Supply Monitoring:

At least once annually, in July, a sample of the water supply to the plant shall be collected and shall be analyzed for total dissolved solids.

E. Reporting:

1. Monitoring reports shall be submitted by the 30th day of the month following sampling and shall include:
 - a. A copy of the chemical analyses,
 - b. Flow data,
 - c. Amount and destination of sludge and other solids (from the treatment facility) hauled away, and
 - d. A statement regarding the maintenance of all wastes on the property owned and controlled by the discharger.
2. For every item where the requirements are not met, the discharger shall submit a statement of the actions undertaken or proposed which will bring the discharge into full compliance with the requirements at the earliest time and submit a timetable for correction.
3. All reports shall be signed by a responsible officer of Pine Springs Ranch and shall be submitted under penalty of perjury.

Ordered by:



Gerard J. Thibeault

Executive Officer

October 6, 2000