

Central Valley Regional Water Quality Control Board

11 August 2023

Martha S. Cardoso
Wastewater System Supervisor
City of Reedley, Reedley WWTF
1733 Ninth Street
Reedley, CA 93654

CERTIFIED MAIL
7022 2410 0000 2157 7879

REVISED MONITORING AND REPORTING PROGRAM R5-2010-0120-01 AND REVIEW OF REQUESTS TO DESTROY MONITORING WELLS AND TERMINATE GROUNDWATER REMEDIATION, CITY OF REEDLEY WASTEWATER TREATMENT FACILITY, FRESNO COUNTY

In a letter dated 6 May 2022 (Letter), City of Reedley (City) staff requested permission to destroy groundwater monitoring wells MW-18 and MW-19, terminate groundwater remediation for nitrate, and reduce groundwater and effluent monitoring requirements for the Reedley Wastewater Treatment Facility (WWTF).

Central Valley Regional Water Quality Control Board (Central Valley Water Board) staff has evaluated the City's requests and determined the following:

1. Wells MW-18 and MW-19 have already been destroyed, and based on the City's existing monitoring well network, replacement of the wells does not appear to be necessary at this time. Changes in groundwater conditions or operations at the WWTF may necessitate replacement of the wells in the future.
2. Termination of groundwater remediation for nitrate is approved.
3. Changes to the WWTF's Monitoring and Reporting Program (MRP) are appropriate. Monitoring frequencies for effluent monitoring have been reduced. However, no changes were made to the groundwater monitoring requirements in the MRP.

Further details regarding the City's requests and Central Valley Water Board staff's review and evaluation of the requests are documented in the enclosed staff memorandum.

In addition, the City in separate communications requested that Central Valley Water Board staff evaluate discontinuation of the Industrial Pretreatment Monitoring Program section of the MRP. No changes have been made to the MRP Industrial Pretreatment Monitoring Program section. Central Valley Water Board staff will address this topic in separate correspondence.

MARK BRADFORD, CHAIR | PATRICK PULUPA, ESQ., EXECUTIVE OFFICER

Revised MRP R5-2010-0120-01 is enclosed. The City of Reedley shall implement the Revised MRP beginning **1 September 2023**. The Revised MRP supersedes MRP R5-2010-0120, adopted by the Central Valley Water Board in December 2010.

If you have any questions regarding this matter, please contact Jeff Hannel of the Compliance and Enforcement Unit at 559-445-6193 or via email at Jeffrey.Hannel@waterboards.ca.gov.



Omar Mostafa, P.E.
Senior Water Resource Control Engineer

Enclosure: Staff Memorandum
Revised MRP R5-2010-0120-01

cc: Fresno County Environmental Health Division