

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL VALLEY REGION

REVISED MONITORING AND REPORTING PROGRAM NO. 82-007  
FOR  
THE TULARE COUNTY HOUSING AUTHORITY  
LINNELL FARM LABOR CENTER  
TULARE COUNTY

The Discharger shall comply with the following monitoring and reporting program:

**EFFLUENT MONITORING**

Representative samples shall be collected at the treatment facility according to the specified frequency:

| <u>Measurement</u>                       | <u>Unit</u> | <u>Type of Sample</u> | <u>Frequency</u> |
|------------------------------------------|-------------|-----------------------|------------------|
| Total Daily Flow                         | mgd         | Continuous            | Daily            |
| Dissolved Oxygen <sup>1</sup>            | mg/l        | Grab                  | 2/week           |
| Specific Electrical<br>Conductance @25°C | μmhos/cm    | Grab                  | Monthly          |

<sup>1</sup> Sample to be collected from a location opposite each pond inlet between the hours of 0800 and 0900.

**GROUND WATER MONITORING**

Representative samples shall be collected from the three ground water monitoring wells and analyzed for the following constituents at the frequency specified:

| <u>Measurement</u>                    | <u>Unit</u> | <u>Type of Sample</u> | <u>Frequency</u>       |
|---------------------------------------|-------------|-----------------------|------------------------|
| Total Coliform<br>Organism            | MPN/100 ml  | Grab                  | Quarterly <sup>1</sup> |
| Depth from surface<br>to ground water | feet        | --                    | Monthly                |

<sup>1</sup> The frequency of sampling shall be changed from quarterly to monthly when the depth of the ground water is less than and equal to 10 feet below ground surface.

**MONITORING AND REPORTING PROGRAM  
THE TULARE COUNTY HOUSING AUTHORITY  
LINNELL FARM LABOR CENTER  
TULARE COUNTY**

-2-

**REPORTING**

Monitoring reports shall be submitted monthly to the Board by the 20th day of the following month. In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly the compliance with waste discharge requirements.

If the Discharger monitors any pollutant at the locations designated herein more frequently than is required by this Order, the results of such monitoring shall be included in the discharge monitoring report.

The Discharger may also be requested to submit an annual report to the Board with tabular and graphical summaries of the monitoring data obtained during the previous year. Any such requests shall be made in writing. The report shall discuss the corrective actions taken and planned to bring the Discharger into full compliance with the waste discharge requirements.

By 31 January of each year, the Discharger shall submit a written report to the Executive Officer containing the following:

- a. The names, titles, certificate grade (if any) and general responsibilities of persons operating and maintaining the wastewater treatment plant.
- b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.
- c. A certified statement of when the flow meter and other monitoring instruments and devices were last calibrated, including identification of who did the calibration (Standard Provision C.5).
- d. A statement whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last reviewed for accuracy.
- e. The total quantity of sludge disposed of during the previous year and ultimate disposal site(s).

MONITORING AND REPORTING PROGRAM  
THE TULARE COUNTY HOUSING AUTHORITY  
LINNELL FARM LABOR CENTER  
TULARE COUNTY


-3-

All reports submitted in response to this Order shall comply with the signatory requirements in Standard Provision D.7 and include the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

The Discharger shall implement the above monitoring program on the first day of December 1994.

WILLIAM H. CROOKS, Executive Officer

by:   
LOREN J. HARLOW, Principal Engineer

21 November 1994

(Date)

Revised 11/21/94


SH:cjs

# MEMORANDUM

## CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD • CENTRAL VALLEY REGION


3614 East Ashlan Avenue  
Fresno, CA 93726

Phone: (209) 445-5116  
CALNET: 8-421-5116

TO: Lonnie M. Wass 

FROM: Sumangali Hoode

DATE: 4 November 1994

SIGNATURE: 

SUBJECT: LINNELL FARM LABOR CAMP, TULARE COUNTY

### Background

Tulare County Housing Authority operates a wastewater treatment plant at Linnell Farm Labor Camp. The treatment plant consists of an imhoff tank, three stabilization ponds, which operate in series. The treated wastewater is discharged to three evaporation/percolation ponds. Discharge from the facility is regulated by Waste Discharge Requirements Order No. 82-007. Monitoring and Reporting Program No. 82-007 requires the Discharger to monitor the effluent and ground water at the site. The Discharger is required to monitor the ground water for total and fecal coliform every month. On 18 October 1994, we received a letter from Vern Bitney, Assistant Executive Director of Tulare County Housing Authority, requesting the frequency of ground water monitoring to be changed from monthly to at least quarterly, as the cost of monitoring is about \$1000 per month and as the samples tested so far indicate no contamination problem at the site.

### Discussions

Presently the ground water at the site is 40 to 45 feet below ground level. Ground water monitoring for coliform organism was initially required because the treatment plant is situated next to and down gradient of an unauthorized solid disposal site and at the time the disposal ponds were constructed, the ground water at the site was only two feet below the bottom of the ponds.

High levels of total and fecal coliform counts were noted in the ground water prior to 1984. From 1988 until May 1991 the discharger did not report coliform levels as the wells went dry. The Discharger installed three additional wells in May 1991. After the installation of the new wells in 1991, the Discharger failed to monitor the wells every month for coliform organisms. Our records indicate that the Discharger has monitored the ground water wells only eight times since 1991. Monthly self monitoring results on ground water monitoring submitted by the Discharger is tabulated in Table 1.

Table 1

| Sample Date | MW-1           |                | MW-2           |                | MW-3           |                |
|-------------|----------------|----------------|----------------|----------------|----------------|----------------|
|             | Total Coliform | Fecal Coliform | Total Coliform | Fecal Coliform | Total Coliform | Fecal Coliform |
| 06-15-92    | 5.5            | <2.2           | <2.2           | **             | <2.2           | **             |
| 10-13-92    | <1.1           | **             | <1.1           | **             | <1.1           | **             |
| 06-04-93    | < 1.1          | **             | < 1.1          | **             | < 1.1          | **             |
| 03-30-94    | < 1.1          | **             | < 1.1          | **             | < 1.1          | **             |
| 05-31-94    | < 1.1          | **             | < 1.1          | **             | < 1.1          | **             |
| 06-29-94    | < 1.1          | **             | < 1.1          | **             | < 1.1          | **             |
| 07-26-94    | < 1.1          | **             | 1.1            | < 1.1          | < 1.1          | **             |
| 08-24-94    | < 1.1          | **             | < 1.1          | **             | < 1.1          | **             |

\*\* No pathogen presence indicated

Review of Table 1 shows that the ground water at the site does not show the presence of total and fecal coliform organisms.

#### Summary

Review of our file on Linnell ground water monitoring shows that the Discharger has failed to perform monitoring of ground water for coliform organisms at the required frequency. Based on a total of eight sets of sample results, it is concluded that the ground water at the site is not contaminated by coliform organisms.

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 82-007

FOR  
THE TULARE COUNTY HOUSING AUTHORITY  
LINNELL FARM LABOR CENTER  
TULARE COUNTY

The Discharger shall implement the following monitoring and reporting program:

EFFLUENT MONITORING

Representative samples shall be collected at the treatment facility according to the specified frequency:

| <u>Measurement</u>                       | <u>Unit</u> | <u>Type of Sample</u> | <u>Frequency</u> |
|------------------------------------------|-------------|-----------------------|------------------|
| Total Daily Flow                         | mgd (l/sec) | Continuous            | Daily            |
| Dissolved Oxygen <sup>1/</sup>           | mg/l        | Grab                  | 2/week           |
| Specific Electrical<br>Conductance @25°C | umhos/cm    | Grab                  | Monthly          |

1/ Sample to be collected from a location opposite each pond inlet between the hours of 0800 and 0900.

GROUND WATER MONITORING

Representative samples shall be collected from the four ground water monitoring wells and analyzed for the following constituents at the frequency specified:

| <u>Measurement</u>                    | <u>Unit</u> | <u>Type of Sample</u> | <u>Frequency</u> |
|---------------------------------------|-------------|-----------------------|------------------|
| Total Coliform<br>Organisms           | MPN/100 ml  | Grab                  | Monthly          |
| Fecal Coliform<br>Organisms           | MPN/100 ml  | Grab                  | Monthly          |
| Depth from surface<br>to ground water | feet        | --                    | Monthly          |