



Central Valley Regional Water Quality Control Board

4 September 2019

Jim Abercrombie
El Dorado Irrigation District
2890 Mosquito Road
Placerville, CA 95667

REVISED MONITORING AND REPORTING PROGRAM, GOLD RIDGE FOREST PROPERTY OWNERS ASSOCIATION, EL DORADO IRRIGATION DISTRICT, GOLD RIDGE FOREST UNIT NO. 3, EL DORADO COUNTY

Central Valley Regional Water Quality Control Board staff has revised the Monitoring and Reporting Program (MRP) 2014-0153-DWQ-R5293-1 for the Gold Ridge Forest Unit No. 3.

Existing Waste Discharge Requirements (WDRs) Order 5-00-135 will be rescinded at the 10/11 October 2019 Central Valley Water Board meeting. Effective upon rescission of Order 5-00-135, the discharge shall be regulated under the Notice of Applicability 2014-0153-DWQ-R5293, which was issued on 6 August 2019 and this Revised MRP 2014-0153-DWQ-R5293-1 pursuant to the General Order *Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems*, Order WQ 2014-0153-DWQ. Please review the Revised MRP carefully to ensure that all monitoring and reporting complies with the Revised MRP.

Please contact Ms. Lixin Fu at (916) 464-4689 or lfu@waterboards.ca.gov if you have any questions regarding this revised MRP. All monitoring reports and compliance and enforcement questions should be directed to Kenny Croyle at (916) 464-4676 or kcroyle@waterboards.ca.gov.

SCOTT ARMSTRONG, P.G., C.H.G.
Senior Engineering Geologist
Waste Discharge to Land Permitting Unit

Enclosed: Revised MRP 2014-0153-DWQ-R5293-1

cc w/o enc: Greg Stanton, El Dorado County Environmental Management Department,
Placerville

KARL E. LONGLEY SCD, P.E., CHAIR | PATRICK PULUPA, ESQ., EXECUTIVE OFFICER

11020 Sun Center Drive #200, Rancho Cordova, CA 95670 | www.waterboards.ca.gov/centralvalley

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION
REVISED MONITORING AND REPORTING PROGRAM WQ 2014-0153-DWQ-R5293-1
FOR
GOLD RIDGE FOREST OWNERS ASSOCIATION
EL DORADO IRRIGATION DISTRICT
GOLD RIDGE FOREST UNIT NO. 3
EL DORADO COUNTY**

This Monitoring and Reporting Program (MRP) describes requirements for monitoring a wastewater treatment system at the Gold Ridge Forest Unit No.3. This MRP is issued pursuant to Water Code section 13267. The Discharger shall not implement any changes to this MRP unless and until a revised MRP is issued by the Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board) or Executive Officer.

Water Code section 13267 states, in part:

"In conducting an investigation specified in subdivision (a), the regional board may require that any person who has discharged, discharges, or is suspected of having discharged or discharging, or who proposes to discharge waste within its region, or any citizen or domiciliary, or political agency or entity of this state who has discharged, discharges, or is suspected of having discharged or discharging, or who proposes to discharge, waste outside of its region that could affect the quality of waters within its region shall furnish, under penalty of perjury, technical or monitoring program reports which the regional board requires. The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports. In requiring those reports, the regional board shall provide the person with a written explanation with regard to the need for the reports, and shall identify the evidence that supports requiring that person to provide the reports."

Water Code section 13268 states, in part:

"(a) Any person failing or refusing to furnish technical or monitoring program reports as required by subdivision (b) of section 13267, or failing or refusing to furnish a statement of compliance as required by subdivision (b) of section 13399.2, or falsifying any information provided therein, is guilty of a misdemeanor and may be liable civilly in accordance with subdivision (b).

(b)(1) Civil liability may be administratively imposed by a regional board in accordance with article 2.5 (commencing with section 13323) of chapter 5 for a violation of subdivision (a) in an amount which shall not exceed one thousand dollars (\$1,000) for each day in which the violation occurs."

The El Dorado Irrigation District operates the wastewater system that is subject to the Notice of Applicability (NOA) of Water Quality Order 2014-0153-DWQ-R5293. The reports are necessary to ensure that the Discharger complies with the NOA and General Order.

REVISED MONITORING AND REPORTING REQUIREMENTS
WQ 2014-0153-DWQ-R5293-1
GOLD RIDGE FOREST OWNERS ASSOCIATION
EL DORADO IRRIGATION DISTRICT
GOLD RIDGE FOREST UNIT NO. 3
EL DORADO COUNTY

- 5 -

Pursuant to Water Code section 13267, the Discharger shall implement this MRP and shall submit the monitoring reports described herein.

All samples shall be representative of the volume and nature of the discharge or matrix of material sampled. The name of the sampler, sample type (grab or composite), time, date, location, bottle type, and any preservative used for each sample shall be recorded on the sample chain of custody form. The chain of custody form must also contain all custody information including date, time, and to whom samples were relinquished. If composite samples are collected, the basis for sampling (time or flow weighted) shall be approved by Central Valley Water Board staff.

Field test instruments (such as those used to test pH, dissolved oxygen, and electrical conductivity) may be used provided that they are used by a State Water Resources Control Board, Environmental Laboratory Accreditation Program certified laboratory, or:

1. The user is trained in proper use and maintenance of the instruments;
2. The instruments are field calibrated prior to monitoring events at the frequency recommended by the manufacturer;
3. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency, and
4. Field calibration reports are maintained and available for at least three years.

Analytical procedures shall comply with the methods and holding times specified in the following: Methods for Organic Chemical Analysis of Municipal and Industrial Wastewater (EPA); Test Methods for Evaluating Solid Waste (EPA); Methods for Chemical Analysis of Water and Wastes (EPA); Methods for Determination of Inorganic Substances in Environmental Samples (EPA); Standard Methods for the Examination of Water and Wastewater (APHA/AWWA/WEF); and Soil, Plant and Water Reference Methods for the Western Region (WREP 125). Approved editions shall be those that are approved for use by the United States Environmental Protection Agency or the California Department of Public Health's Environmental Laboratory Accreditation Program. The Discharger may propose alternative methods for approval by the Executive Officer. Where technically feasible, laboratory reporting limits shall be lower than the applicable water quality objectives for the constituents to be analyzed.

SEPTIC TANK MONITORING

All septic tanks attached to or contained in the collection system and any grease traps shall be inspected at least annually to assure adequate treatment and perform biosolids removal as necessary. Biosolids removal shall be reported annually and documented as to the volume

removed, by whom, and location of disposal. The septic tank monitoring report shall be included in the annual report.

A monthly written report of the system conditions observed including the volume of biosolids removed (if any) shall be prepared following each inspection. Such written descriptions shall include the conditions of all the items listed in the above paragraphs and shall identify any maintenance work on the physical aspects of the system, if any.

EFFLUENT MONITORING

Samples of effluent shall be taken at the point of discharge to the leachfields. At a minimum, effluent monitoring shall consist of the following:

Constituent	Units	Sample Type	Sampling Frequency	Reporting Frequency
Flow to Leachfield	gallon	Calculated	Bi-monthly	Semi-annually
BOD ₅	mg/L	Grab	Semi-annually	Semi-annually
Total Dissolved Solids	mg/L	Grab	Semi-annually	Semi-annually
Nitrate a Nitrogen	mg/L	Grab	Semi-annually	Semi-annually
Total Kjeldahl Nitrogen	mg/L	Grab	Semi-annually	Semi-annually
Standard Minerals	mg/L	Grab	Annually	Annually

Wastewater discharged to leachfield may be estimated based on potable water supply meter readings or other approved method.

Standard Minerals shall include, at a minimum, the following elements and compounds: boron, calcium, iron, magnesium, manganese, sodium, potassium, chloride, sulfate, total alkalinity (including alkalinity series), and hardness.

LEACHFIELD MONITORING

All leachfield system facilities including collection system, sewer mains, headworks, distribution lines and boxes, diversion trenches, effluent disposal trenches (such as French drain), and other appurtenant monitoring systems associated with the system inspection port(s), septic tank(s), shall be inspected on a monthly basis. Observations made during these inspections shall be recorded on a monthly basis.

Inspections of the leachfield system facilities will be comprised of a physical evaluation of the disposal site area to determine whether waste is being contained beneath the ground surface. The ground in the immediate vicinity and surrounding the disposal site shall be inspected to determine the presence of effluent on the ground surface.

A written report of the conditions observed for the system shall be prepared following each inspection and submitted with the semi-annual monitoring report. Evidence of surfacing wastewater, erosion, field saturation, runoff, or the presence of nuisance conditions shall be noted in the report. The report shall identify any maintenance work necessary on the physical aspects of the system.

WATER SUPPLY MONITORING

A sampling station shall be established where a representative sample of the municipal water supply can be obtained. Water supply monitoring may be substituted with the annual report of the supplying agency. Water supply monitoring shall include at least the following:

Constituent	Units	Sample Type	Sampling and Reporting Frequency
Total Dissolved Solids	mg/L	Grab	Annually
Standard Minerals	mg/L	Grab	Annually

Standard Minerals shall include, at a minimum, the following elements and compounds: boron, calcium, iron, magnesium, manganese, sodium, potassium, chloride, sulfate, total alkalinity (including alkalinity series), and hardness.

REPORTING

All regulatory documents, submissions, materials, data, monitoring reports, and correspondence should be converted to a searchable Portable Document Format (PDF) and submitted electronically. Documents that are less than 50MB should be emailed to: centralvalleysacramento@waterboards.ca.gov

Documents that are 50 MB or larger should be transferred to a CD, DVD, or flash drive and mailed to the following address:

Central Valley Regional Water Quality Control Board
ECM Mailroom
11020 Sun Center Drive, Suite 200
Rancho Cordova, California 95670

To ensure that your submittals are routed to the appropriate staff, the following information block should be included in any correspondence used to transmit documents to this office:

REVISED MONITORING AND REPORTING REQUIREMENTS
WQ 2014-0153-DWQ-R5293-1
GOLD RIDGE FOREST OWNERS ASSOCIATION
EL DORADO IRRIGATION DISTRICT
GOLD RIDGE FOREST UNIT NO. 3
EL DORADO COUNTY

- 5 -

Facility Name: Gold Ridge Forest Unit No.3, El Dorado County
Program: Non-15 Compliance
Order: WQ 2014-0153-DWQ-R5293
CIWQS Place ID: 227444

In reporting monitoring data, the Discharger shall arrange the data in tabular form so that the date, sample type (e.g., effluent, pond, etc.), and reported analytical result for each sample are readily discernible. The data shall be summarized in such a manner to clearly illustrate compliance with waste discharge requirements and spatial or temporal trends, as applicable. The results of any monitoring done more frequently than required at the locations specified in the MRP shall be reported in the next scheduled monitoring report.

In addition to the requirements of Standard Provision C.3, monitoring information shall include the method detection limit (MDL) and the Reporting limit (RL) or practical quantitation limit (PQL). If the regulatory limit for a given constituent is less than the RL (or PQL), then any analytical results for that constituent that are below the RL (or PQL) but above the MDL shall be reported and flagged as estimated.

A. Semi-Annual Monitoring Report

The Discharger shall establish a semi-annual sampling schedule for effluent monitoring such that samples are obtained approximately every six months. Semi-Annual Monitoring Reports shall be submitted to the Central Valley Water Board by the 1st day of February and August. The Semi-Annual Monitoring Reports shall include the following:

1. The results of all leachfield monthly monitoring, and
2. The results from bi-monthly and Semi-Annual monitoring of the effluent including analytical laboratory results.

B. Annual Report

In addition to the semi-annual monitoring reports, an Annual shall be prepared. The Annual Report shall be submitted to the Central Valley Water Board by **1 February** each year. The Annual Report shall include the following:

1. Results of the septic tank monitoring;
2. The results from annual monitoring of the effluent, and water supply including analytical laboratory results;
3. An estimated flow volume from water supplied to the homes connected to the system;
4. Estimated wastewater annual total flow and average dry weather flow;

REVISED MONITORING AND REPORTING REQUIREMENTS
WQ 2014-0153-DWQ-R5293-1
GOLD RIDGE FOREST OWNERS ASSOCIATION
EL DORADO IRRIGATION DISTRICT
GOLD RIDGE FOREST UNIT NO. 3
EL DORADO COUNTY

- 5 -

5. The dates, duration, and volume of any leachfield failure events;
6. An update on the number of homes connected to the system;
7. For biosolids and sludge: the dates of removal, volume, analysis (if any), final disposal location, and who performed the removal and transportation of any biosolids or sludge from the system;
8. Any other significant events or changes which may have water quality implications;
9. A discussion of compliance and the corrective action taken, as well as any planned or proposed actions needed to bring the discharge into full compliance with the waste discharge requirements;
10. A discussion of any data gaps and potential deficiencies/redundancies in the monitoring system or reporting program;
11. Tabular and graphical summaries of all data collected during the year, and
12. A copy of the certification for each certified wastewater treatment plant operator working at the facility and a statement about whether the Discharger is in compliance with Title 23, CCR, Division 3, Chapter 26.


A letter transmitting the self monitoring reports shall accompany each report. Such a letter shall include a discussion of requirement violations found during the reporting period, and actions taken or planned for correcting noted violations, such as operation or facility modifications. If the Discharger has previously submitted a report describing corrective actions and/or a time schedule for implementing the corrective actions, reference to the previous correspondence will be satisfactory.

The transmittal letter shall contain the penalty of perjury statement by the Discharger, or the Discharger's authorized agent, as described in the Standard Provisions General Reporting Requirements Section B.3.

The Discharger shall implement the above monitoring program on the first day of the month following adoption of this Order.

Ordered by:

for



Patrick Pulupa, Executive Officer

4 September 2019
(Date)