

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 90-080

WASTE DISCHARGE REQUIREMENTS
FOR
NEVADA IRRIGATION DISTRICT
ROLLINS RESERVOIR RECREATION AREAS
NEVADA AND PLACER COUNTIES

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. The Nevada Irrigation District (hereafter Discharger) submitted a Report of Waste Discharge, dated 22 June 1989. The property is owned by the Nevada Irrigation District.
2. The Board, on 27 August 1976, adopted Order No. 76-187 which prescribed requirements for a discharge from Nevada Irrigation District, Rollins Recreation Areas to stabilization ponds.
3. Present waste discharge requirements established in Order No. 76-187 are neither adequate nor consistent with plans and policies of the Board.
4. The Discharger discharges an average of 13,000 gallons per day (design flow 26,000 gallons per day) of domestic sewage to stabilization ponds at four sites, as shown on Attachment A, a part of this Order. There are two wastewater ponds operated in series at each site. Sewage is generated from camping day use and administrative facilities as listed in Attachment B, a part of this Order.
5. The Discharger receives wastes from recreational vehicles (RVs) at the Long Ravine and Peninsula campgrounds. These RV wastes are discharged to the Long Ravine South and Peninsula South wastewater treatment facilities. No RV wastes are discharged to the Long Ravine North, Peninsula North, Greenhorn or Orchard Springs wastewater treatment facilities.
6. Wastewater monitoring requirements for facilities receiving RV wastes are necessary to assess potential impacts to water quality. In the event that wastewater monitoring shows the potential for surface or ground water degradation, the Discharger will be required to determine the extent of the threat to ground water quality and/or conduct ground water monitoring.
7. The normal recreation season at the reservoir is from 15 April through 15 September. With the exception of the Peninsula campground, which is closed during the off season, the campgrounds are open year-round. Pond monitoring is required only during the normal recreation season, unless RV wastes are discharged during the off season.
8. The Discharger is considering a proposal to eventually eliminate the discharge of RV wastes to the wastewater ponds. The proposal calls for RV wastes to be temporarily stored in holding tanks before final disposal to an off-site facility capable of receiving the waste. If the proposal is implemented, the monitoring program will be revised accordingly.

WASTE DISCHARGE REQUIREMENTS
NEVADA IRRIGATION DISTRICT
ROLLINS RESERVOIR RECREATION AREAS
NEVADA AND PLACER COUNTIES

9. The Discharger's facilities are in Sections 10, 14, 22, and 23, T15N, R9E, MDB&M, as shown on Attachment A, which is part of this Order, with surface water drainage to Rollins Reservoir.
10. The beneficial uses of Rollins Reservoir are municipal, industrial, and agricultural supply; recreation; esthetic enjoyment; ground water recharge; fresh water replenishment; hydroelectric power generation; and preservation and enhancement of fish, wildlife, and other aquatic resources.
11. The beneficial uses of the ground water are municipal, industrial, and agricultural supply.
12. The Board, on 25 July 1975, adopted a Water Quality Control Plan for the Sacramento River Basin (5A) which contains water quality objectives for all waters of the Basin. These requirements are consistent with that Plan.
13. The action to update waste discharge requirements for this facility is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301, Title 14, California Code of Regulations (CCR).
14. This discharge is exempt from the requirements of Section 2511(b), Subchapter 15, Chapter 3, Title 23, of the CCR. The exemption is based on the following:
 - a. The Board has issued waste discharge requirements.
 - b. The discharge is in compliance with the applicable Water Quality Control Plan, and
 - c. The wastewater does not need to be managed according to Chapter 30 of Division 4, Title 22, CCR, as a hazardous waste.
15. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.
16. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Order No. 76-187 be rescinded and the Nevada Irrigation District, Rollins Reservoir Recreation Areas, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

1. The direct discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. The by-pass or overflow of untreated or partially treated waste is prohibited.

WASTE DISCHARGE REQUIREMENTS
NEVADA IRRIGATION DISTRICT
ROLLINS RESERVOIR RECREATION AREAS
NEVADA AND PLACER COUNTIES

-3-

B. Discharge Specifications:

1. Neither the treatment nor the discharge shall cause a nuisance or condition of pollution as defined by the California Water Code, Section 13050.
2. The discharge shall not cause degradation of any water supply.
3. The discharge shall remain within the designated disposal area at all times.
4. The 30-day average daily dry weather discharge flow shall not exceed 26,000 gallons.
5. Collected screening, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.
6. A 2.0 foot freeboard shall be maintained in all ponds at all times.
7. Any discharge by seepage or other indirect means reaching Rollins Reservoir, or any water course, shall not cause any of the following conditions to exist in the receiving waters:
 - a. visible oil, grease, scum, or foam;
 - b. apparent or esthetically undesirable discoloration;
 - c. fungus, slimes, or other objectionable growths;
 - d. bottom deposits;
 - e. floating or suspended materials; and
 - f. concentrations of any materials which are harmful or deleterious to human, animal, aquatic, or plant life.
8. The dissolved oxygen content of holding ponds shall not be less than 1.0 mg/l for 16 hours in any 24-hour period.
9. RV wastes shall only be discharged to the Long Ravine South and Peninsula South wastewater treatment facilities.

C. Provisions:


1. The Discharger may be required to submit technical reports as directed by the Executive Officer.
2. The Discharger shall comply with the attached Monitoring and Reporting Program No. 90-080.

WASTE DISCHARGE REQUIREMENTS
NEVADA IRRIGATION DISTRICT
ROLLINS RESERVOIR RECREATION AREAS
NEVADA AND PLACER COUNTIES

-4-

3. The Discharger shall comply with the Standard Provisions and Reporting Requirements, dated 1 February 1990, which are a part of this Order.
4. The Discharger shall report promptly to the Board any material change or proposed change in the character, location, or volume of the discharge.
5. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this office.
6. The Board will review this Order periodically and may revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 23 April 1990.



WILLIAM H. CROOKS, Executive Officer

Amended:4/23/90:MGW:gs

Attachments

MONITORING AND REPORTING PROGRAM
NEVADA IRRIGATION DISTRICT
ROLLINS RESERVOIR RECREATION AREAS
NEVADA COUNTY

-2-

In addition to the normal season monitoring requirements, the Discharger shall also submit monthly reports during the off season (October through April) for the Long Ravine South campground, which specifies the number and volume of RV waste discharges to the facility. If RV wastes are received during the month, the Discharger shall monitor all of the parameters described under "Wastewater Monitoring".

REPORTING

In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly the compliance with waste discharge requirements.


Monthly monitoring reports shall be submitted to the Regional Board by the 15th day of the following month.

The results of any monitoring done more frequently than required at the locations specified in the Monitoring and Reporting Program shall be reported to the Board.

Upon written request of the Board, the Discharger shall submit a report to the Board by 30 January of each year. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year. In addition, the Discharger shall discuss the compliance record and the corrective actions taken or planned which may be needed to bring the discharge into full compliance with the waste discharge requirements.

The Discharger shall implement the above monitoring program as of the date of this Order.

Ordered by



WILLIAM H. CROOKS, Executive Officer

23 April 1990

(Date)

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 90-080

FOR
NEVADA IRRIGATION DISTRICT
ROLLINS RESERVOIR RECREATION AREAS
NEVADA COUNTY

Specific sample station locations shall be established under direction of the Board's staff and a description of the stations shall be attached to this Order.

WASTEWATER MONITORING

Effluent samples shall be collected from the first pond at each facility. Effluent samples should be representative of the volume and nature of the discharge. Time of collection of a grab sample shall be recorded. The following shall constitute the monitoring program for the period May through September unless otherwise directed by the Executive Officer:

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Flow	mgd	Cumulative	Daily
Pond Freeboard	feet	---	Monthly
Dissolved Oxygen ¹	mg/l	Grab	Monthly
Formaldehyde ^{1,2}	µg/l	Grab	Monthly
Copper ^{1,3}	µg/l	Grab	Monthly
Zinc ^{1,3}	µg/l	Grab	Monthly
Specific Conductance ¹	µmhos/cm	Grab	Monthly
pH ¹	pH Units	Grab	Monthly
Temperature ¹	°C	Grab	Monthly

¹ For wastewater ponds at the Peninsula South and Long Ravine South facilities from May through September and whenever RV wastes are discharged to the ponds.

² Using High Pressure Liquid Chromatography methods

³ Using Total Recoverable Metals methods

By 15 October of each year, the Discharger shall submit a report which addresses the condition of all wastewater ponds at the end of the normal recreation season. The report shall specify the remaining storage capacity in all of the wastewater ponds.

INFORMATION SHEET

NEVADA IRRIGATION DISTRICT ROLLINS RESERVOIR RECREATION AREAS NEVADA AND PLACER COUNTIES

These are existing recreation areas around Rollins Reservoir, including camping and day use facilities. Sewage is generated from toilets and showers and is discharged to stabilization ponds. The ponds are fenced to exclude the public and unauthorized personnel. Surface drainage is to Rollins Reservoir.

RV wastes were discharged to several of the wastewater ponds in the past. As a result of this practice, formaldehyde has been found in some of the ponds. A sample taken from wastewater pond at the Long Ravine (South) campground in December 1988 contained 102 $\mu\text{g/l}$, which exceeds the Department of Health Services' State Action Level of 30 $\mu\text{g/l}$. Wastewater monitoring for facilities which will continue to receive RV wastes are necessary to assess potential impacts to water quality. In the event that wastewater monitoring shows the potential for surface or ground water degradation, the Discharger will be required to determine the threat to water quality and/or conduct ground water monitoring.

The normal recreation season at the reservoir is from 15 April through 15 September. With the exception of the Peninsula campground, which is closed from 15 September through 15 April, all of the campgrounds are open year-round. Pond monitoring is required only during the normal season unless RV wastes are discharged during the off-season.

The Discharger will monitor and control the discharge of RV wastes to the Long Ravine South campground during the off season. RV users will have to inform the campground managers before discharging wastes, since the RV dump will be locked during the off season. In this manner, the Discharger will be able to monitor RV wastes discharged to the ponds.

Revised:3/2/90:MGW:gs

ATTACHMENT B

Rollins Reservoir Disposal Facilities

A. Greenhorn camping and day use area:

- 5 toilets
- 4 showers

(Note: the above are located in the multi-purpose building.)

B. Greenhorn administrative area:

- 2 house trailers
- (Future: gatekeeper/security quarters - 1 toilet, 1 shower)

C. Peninsula camping area:

1. upper stabilization pond

- 8 toilets
- 4 showers

2. lower stabilization pond

- 4 toilets
- 2 showers

D. Peninsula administrative area:

- 2 house trailers

E. Long Ravine camping & day use area:

1. upper stabilization pond

- 8 toilets

2. lower stabilization pond

- 10 toilets
- 2 showers

F. Orchard Springs camping and day use area:

- 14 toilets
- 5 showers

G. Orchard Springs administrative area:

- 2 house trailers

1 multi purpose store/office building

1 multi purpose store / office building