

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 90-014

WASTE DISCHARGE REQUIREMENTS
FOR
MERCED COUNTY CORRECTIONAL FACILITY
SANDY MUSH ROAD
MERCED COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. The Merced County Correctional Facility (hereafter Discharger) submitted a Report of Waste Discharge, dated 24 March 1987, and a site evaluation report, dated January 1986.
2. The Discharger proposes to discharge approximately 50,000 gallons per day of domestic sewage to land disposal.
3. The Discharger is in Section 34, T8S, R13E, MDB&M, with surface water drainage to Deadman Slough which is tributary to the San Joaquin River.
4. Sewage treatment will be effected by an extended aeration plant followed by a stabilization pond. Final disposal will be spray irrigation of 15 acres for non-dairy pasture and fodder crops.
5. Effluent runoff from spray irrigation will be controlled by best management practices to insure no runoff of effluent from the site.
6. The treatment and disposal areas will be fenced to preclude access by unauthorized personnel.
7. The beneficial uses of Deadman Slough and the San Joaquin River are municipal, industrial, and agricultural supply; recreation; esthetic enjoyment; ground water recharge; fresh water replenishment; and preservation and enhancement of fish, wildlife, and other aquatic resources.
8. The beneficial uses of the ground water are municipal, industrial, and agricultural supply.
9. The Board, on 25 July 1975, adopted a Water Quality Control Plan for the San Joaquin River Basin (5C) which contains water quality objectives for all waters of the Basin. These requirements are consistent with that Plan.
10. The County of Merced has adopted a final environmental impact report (EIR) in accordance with the California Environmental Quality Act, (Public Resources Code Section 21000, et seq.), and the State Guidelines.
11. The Board has reviewed the EIR and concurs there are no significant impacts on water quality.

WASTE DISCHARGE REQUIREMENTS
MERCED COUNTY CORRECTIONAL FACILITY
SANDY MUSH ROAD
MERCED COUNTY

-2-

12. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.
13. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Merced County Correctional Facility, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

1. The direct discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. The by-pass or overflow of untreated or partially treated waste is prohibited.
3. Public contact with effluent in reservoirs or spray fields is prohibited.
4. The discharge of other than domestic waste to the wastewater treatment and disposal system is prohibited.
5. The discharge of industrial waste or any waste which is classified as 'hazardous waste' under California Code of Regulations (CCR), Title 22, Chapter 30, or a 'designated waste' under CCR, Title 23, Chapter 3, Subchapter 15, is specifically prohibited.

B. Discharge Specifications:

1. The following constituent limitation shall apply to wastewater discharged to the holding reservoir and spray fields:

<u>Constituent</u>	<u>Units</u>	<u>Monthly Mean</u>	<u>Daily Maximum</u>
BOD ₅	mg/l	40	80

2. The following constituent limitation shall apply to wastewater discharged to the spray fields:

<u>Constituent</u>	<u>Units</u>	<u>Monthly Mean</u>	<u>Daily Maximum</u>
Settleable Solids	ml/l/hr	0.5	1.0

3. The Discharger shall maintain a fenced (or some other equivalent alternative) spray disposal area and a setback of 100 feet from the wetted spray field area to the edge of the property or residential areas where trees and brush are adequate to limit the movement of aerosols.

WASTE DISCHARGE REQUIREMENTS
MERCED COUNTY CORRECTIONAL FACILITY
SANDY MUSH ROAD
MERCED COUNTY

-3-

4. Neither the treatment nor the discharge shall cause a nuisance or condition of pollution as defined by the California Water Code, Section 13050.
5. The discharge shall not cause degradation of any water supply.
6. The discharge shall remain within the designated disposal area at all times.
7. The 30-day average daily dry weather discharge flow shall not exceed 50,000 gallons.
8. Peak daily wet weather discharge shall not exceed 75,000 gallons.
9. Collected screening, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.
10. A 1.0 foot freeboard shall be maintained in all ponds at all times.
11. The dissolved oxygen content of holding ponds shall not be less than 1.0 mg/l for 16 hours in any 24-hour period.
12. Reclaimed wastewater shall meet the criteria contained in Title 22, Division 4, CCR (Section 60301, et seq.).

C. Provisions:

1. The Discharger may be required to submit technical reports as directed by the Executive Officer.
2. The Discharger shall comply with the attached Monitoring and Reporting Program No. 90-014.
3. The Discharger shall submit, for staff approval, a detailed report on sludge disposal practices by **15 May 1990**. Practices shall meet the requirements of Subchapter 15 of Title 23.
4. The Discharger shall comply with the Standard Provisions and Reporting Requirements, dated 1 September 1985, which are a part of this Order.
5. The Discharger shall report promptly to the Board any material change or proposed change in the character, location, or volume of the discharge.
6. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this office.

WASTE DISCHARGE REQUIREMENTS
MERCED COUNTY CORRECTIONAL FACILITY
SANDY MUSH ROAD
MERCED COUNTY

-4-

7. The Board will review this Order periodically and may revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 26 January 1990.


WILLIAM H. CROOKS, Executive Officer

12/28/89:EZC:gs

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 90-014

FOR
MERCED COUNTY CORRECTIONAL FACILITY
SANDY MUSH ROAD
MERCED COUNTY

Specific sample station locations shall be established under direction of the Board's staff and a description of the stations shall be attached to this Order.

Prior to construction, plans and specifications for ground water monitoring wells shall be submitted to Board staff for review and approval.

EFFLUENT MONITORING

Effluent samples shall be collected just prior to discharge to the disposal facility. Effluent samples should be representative of the volume and nature of the discharge. Samples collected from the outlet structure of ponds will be considered adequately composited. Time of collection of a grab sample shall be recorded. The following shall constitute the effluent monitoring program:

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Pond Freeboard	feet, inches	Grab	Monthly
BOD ₅	mg/l	Grab	Monthly
Specific Conductivity	μmhos/cm	Grab	Quarterly
pH	pH Units	Grab	Quarterly
Settleable Solids	ml/l	Grab	Weekly
Flow	mgd	Cumulative	Daily

Flow from
200,000 gpd
See RNN
7/23/2001

WATER SUPPLY MONITORING

A sampling station shall be established where a representative sample of the municipal water supply can be obtained. The following shall constitute the water supply monitoring program:

<u>Constituents</u>	<u>Units</u>	<u>Sampling Frequency</u>
Specific Conductivity	μmhos/cm @ 25°C	Annually

GROUND WATER MONITORING

Three shallow ground water wells or piezometers shall be installed within 100 feet of the ponds and irrigated area to establish shallow (<50 feet) ground water gradient. Two ground water monitoring wells shall be installed, one upgradient of the ponds and

MONITORING AND REPORTING PROGRAM
MERCED COUNTY CORRECTIONAL FACILITY
SANDY MUSH ROAD
MERCED COUNTY

-2-

one downgradient of the pond and irrigated area. Water samples shall be collected from the wells and analyzed as follows:

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Specific Conductance	μ mhos/cm	Grab	Semi-annually April and October
Chloride	mg/l	Grab	Semi-annually April and October
Depth to ground water	feet & inches	Grab	Semi-annually April and October

REPORTING

In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly the compliance with waste discharge requirements.

Monthly monitoring reports shall be submitted to the Regional Board by the **15th day** of the following month.

The results of any monitoring done more frequently than required at the locations specified in the Monitoring and Reporting Program shall be reported to the Board.

Upon written request of the Board, the Discharger shall submit a report to the Board by **30 January** of each year. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year. In addition, the Discharger shall discuss the compliance record and the corrective actions taken or planned which may be needed to bring the discharge into full compliance with the waste discharge requirements.

The Discharger shall implement the above monitoring program as of the date of this Order.

Ordered by



WILLIAM H. CROOKS, Executive Officer

26 January 1990

(Date)

1/3/89:EZC:gs

INFORMATION SHEET


MERCED COUNTY CORRECTIONAL FACILITY SANDY MUSH ROAD, MERCED COUNTY

This is a new correctional facility which will augment an existing facility near Castle Air Force Base. This facility will be on Sandy Mush Road about one-quarter mile east of Combs Road.

The facility will be designed to accommodate about 364 inmates. In addition to a dormitory, there will be a kitchen, dining facilities, laundry, out buildings, crop cultivation and potential livestock grazing and poultry operation on a 135 acre site. Sewage treatment and disposal will be aerated ponds and on-site agricultural irrigation. All drainage water is proposed to be retained on-site.

Soils in the area are loam and sandy loam. Average depth to ground water varies between 9 and 19 feet.

12/21/89:EZC:gs



ATTACHMENT A

MERCED COUNTY CORRECTIONAL
FACILITY

Section 34, T8S, R13E, MDB&M
USGS 7.5 Min Sandy Mush Quad.
Merced County

Scale: 1 inch = 2,000 feet