

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 85-155

WASTE DISCHARGE REQUIREMENTS
FOR
SNELLING COMMUNITY SERVICES DISTRICT
MERCED COUNTY

Feb 92
Diane Bartlow
Plant Operator

209-722-2719

JAN 09

209 563 6525

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. The Snelling Community Services District (hereafter Discharger) owns and operates wastewater treatment and disposal facilities in Merced County, approximately one-half mile west of the City of Snelling, in Sections 4, 5, 8, and 9, T5S, R14E, MDB&M.
2. The Board, on 26 September 1975, adopted Order No. 75-213 which prescribed requirements for a discharge from aerated lagoons to six acres of adjacent District-owned land for pasture irrigation.
3. Present waste discharge requirements established by Order No. 75-213 are neither adequate nor consistent with plans and policies of the Board.
4. The Discharger discharges 40,000 gallons per day (1.8 l/s) from two mechanically aerated lagoons in series to the adjacent spray disposal area. The design capacity of the treatment facility is 0.10 mgd (4.4 l/s).
5. The beneficial uses of the ground water are municipal and agricultural supply.
6. The Board, on 25 July 1975, adopted a Water Quality Control Plan for the San Joaquin River Basin (5C) which contains water quality objectives. These requirements are consistent with that Plan.
7. The action to adopt waste discharge requirements for this existing facility is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301, Title 14, California Administrative Code.
8. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.
9. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Order No. 75-213 be rescinded and the Snelling Community Services District, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

WASTE DISCHARGE REQUIREMENTS
SNELLING COMMUNITY SERVICES DISTRICT
MERCED COUNTY

-2-

A. Discharge Prohibitions:

1. The direct discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. The by-pass or overflow of untreated or partially treated waste is prohibited.

B. Discharge Specifications:

1. Neither the treatment nor the discharge shall cause a pollution or nuisance as defined by the California Water Code, Section 13050.
2. The discharge shall not cause degradation of any water supply.
3. The discharge shall be confined to property owned or controlled by the Discharger.
4. The 30-day average daily dry weather discharge flow shall not exceed 0.10 million gallons (379 m³).
5. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.
6. Any discharge shall not contain constituents in excess of the following:

<u>Constituent</u>	<u>Unit</u>	<u>30-Day Mean</u>	<u>Maximum</u>
BOD ₅ ^{1/}	mg/l	30	50
Settleable Matter	ml/l	0.2	1.0
Total Coliform	MPN ^{2/} /100ml	23	240

^{1/} Five-day, 20° Celsius biochemical oxygen demand.

^{2/} Most Probable Number.

7. Reclaimed wastewater shall meet the criteria contained in Title 22, Division 4, California Administrative Code (Section 60301, et seq.).
8. The dissolved oxygen content of the treatment and holding ponds shall not be less than 1.0 mg/l for 16 hours in any 24-hour period.
9. Public access shall be precluded through a satisfactory combination of fencing, signing, and irrigation management practices, or some other equivalent alternative.

WASTE DISCHARGE REQUIREMENTS
SNELLING COMMUNITY SERVICES DISTRICT
MERCED COUNTY


-3-

10. The disinfection unit process shall be provided with the uninterrupted feed and reliability features of Sections 60353 and 60355 of Title 22, Division 4, of the California Administrative Code.

C. Provisions:

1. The Discharger may be required to submit technical reports as directed by the Executive Officer.
2. The Discharger shall comply with the attached Monitoring and Reporting Program No. 85-155.
3. The Discharger shall comply with the Standard Provisions and Reporting Requirements, dated 1 October 1983, which are a part of this Order.
4. The Discharger shall report promptly to the Board any material change or proposed change in the character, locations, or volume of the discharge.
5. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this office.
6. The Board will review this Order periodically and may revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 28 June 1985.



WILLIAM H. CROOKS, Executive Officer

SGT:hmm:4/2/85

Attachments

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 85-155

FOR
SNELLING COMMUNITY SERVICES DISTRICT
MERCED COUNTY

EFFLUENT MONITORING

Effluent samples shall be collected downstream from the last connection through which wastes can be admitted to the spray disposal area, except as noted for dissolved oxygen. Effluent samples should be representative of the volume and nature of the discharge. The following shall constitute the monitoring program:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Total Daily Flow	gpd	Continuous	Daily
BOD ₅ ^{1/}	mg/l	Grab	Weekly
Chlorine Residual	mg/l	Grab	Daily
Total Coliform	MPN/100 ml	Grab	Monthly
Settleable Matter	ml/l	Grab	Weekly
Dissolved Oxygen ^{2/}	mg/l	Grab	3/Week

1/ Five-day, 20° Celsius biochemical oxygen demand.

2/ Samples to be collected from near the outlet of each pond between the hours of 0800 and 0900.

If the discharge is intermittent rather than continuous, then on the first day of each such intermittent discharge, the Discharger shall monitor and record data for all of the constituents listed above, after which the frequencies of analysis given in the schedule shall apply for the duration of each such intermittent discharge. In no event shall the Discharger be required to monitor and record data more often than twice the frequencies listed in the schedule.

SPRAY DISPOSAL FIELD MONITORING

The Discharger shall review the spray field two times per month. In conducting the review, a log shall be kept of the spray field conditions. Attention shall be given to the presence of absence of:

- a. breaches of berms
- b. overspray outside of the pasture area

MONITORING AND REPORTING PROGRAM
SNELLING COMMUNITY SERVICES DISTRICT
MERCED COUNTY

-2-


- c. runoff of effluent
- d. erosion
- e. standing water

Notes on the spray field shall be summarized in the monitoring report.

REPORTING

Monthly monitoring reports shall be submitted to the Regional Board by the 15th day of the following month. In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly the compliance with waste discharge requirements.

Ordered by



WILLIAM H. CROOKS, Executive Officer

28 June 1985

(Date)

SGT:hmm

4/2/85

INFORMATION SHEET

SNELLING COMMUNITY SERVICES DISTRICT MERCED COUNTY

The Snelling Community Services District owns and operates wastewater treatment and disposal facilities in Merced County, in the area common to the corners of Sections 4, 5, 8, and 9, T5S, R14E, MDB&M.

The treatment facility consists of a wet well, lift station, two mechanically aerated lagoons, a chlorine contact chamber, and an irrigation regulating reservoir. The capacity of the treatment facility is 0.10 mgd (4.4 l/s), and the current estimated flow is 0.04 mgd (1.8 l/s). Effluent disposal is accomplished by spray irrigation to six acres of adjacent District-owned land.

In 1973, the Board adopted a prohibition of discharge from septic tanks and cesspools within the District because of high levels of bacterial contamination of domestic wells. The existing facility was completed in 1975 and its discharge has since been governed by Order No. 75-213.

Ground water in the area can be found at depths from 4 to 14 feet (1.2 to 4.3 m), and is of good quality. The specific electrical conductance of this water is around 300 micromhos. Annual average precipitation and evaporation rates are about 12 and 60 inches (0.3 and 1.5 m), respectively.

The soils in the area are dredge tailings underlain by recent alluvium. Permeability of these soils is generally high. Because of the high permeability of the soils, the aeration and holding ponds have been gunite-lined.

U. S. Corps of Engineers flood studies indicated that the disposal site was not inundated by the record 1969 flood.

The action to adopt waste discharge requirements for this existing facility is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301, Title 14, California Administrative Code.

SGT:hmm

4/2/85

SNELLING COMMUNITY SERVICES DIST.
MERCED COUNTY
Portions of Sections
4, 5, 8, & 9, T5S, R14E, MDB&M
Snelling 7.5' USGS Quad

