

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 86-021

WASTE DISCHARGE REQUIREMENTS
FOR
TUOLUMNE REGIONAL WATER DISTRICT
TWIN HARTE WASTEWATER TREATMENT PLANT
TUOLUMNE COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. The Tuolumne Regional Water District (TRWD), (hereafter Discharger), submitted a Report of Waste Discharge, dated 25 November 1985.
2. Waste discharge requirements for this facility were rescinded by Board Order No. 82-042 when the plant ceased effluent discharge to Woods Creek and began discharging to the Sonora Regional Wastewater Treatment Plant (WWTP). Sludge treatment and disposal were retained at this facility.
3. Waste discharge requirements are now considered appropriate for this facility to insure proper sludge treatment and disposal and for consistency with present Board policy.
4. The Twin Harte WWTP treats .25 mgd of domestic sewage from the community of Twin Harte. The treatment works consist of: a mechanical bar rack, two clarifiers, an aerated lagoon with two surface aerators, a polishing pond, and sludge drying beds. Design flow is .5 mgd. Effluent is discharged to the Sonora WWTP for additional treatment via a 14 mile interceptor. Sludge was formerly buried on-site, but is now combined with sludge from the Sonora WWTP and disposed of as a soil amendment.
5. The Twin Harte WWTP is in Section 18, T2N, R16E, MDB&M, with surface water drainage to Sullivan Creek, thence Don Pedro Reservoir.
6. The beneficial uses of Don Pedro Reservoir are municipal, industrial, and agricultural supply; recreation; esthetic enjoyment; navigation; ground water recharge; fresh water replenishment; hydroelectric power generation; and preservation and enhancement of fish, wildlife and other aquatic resources.
7. The beneficial uses of the ground water are municipal and agricultural supply.
8. The Board, on 25 July 1975, adopted a Water Quality Control Plan for the San Joaquin Sub Basin (5C) which contains water quality objectives. These requirements are consistent with that Plan.
9. The action to adopt waste discharge requirements for this facility is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301, Title 14, California Administrative Code.

WASTE DISCHARGE REQUIREMENTS
TUOLUMNE REGIONAL WATER DISTRICT
TWIN HARTE WASTEWATER TREATMENT PLANT
TUOLUMNE COUNTY

-2-

10. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.
11. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Tuolumne Regional Water District, Twain Harte Wastewater Treatment Plant, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

1. The direct discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. The by-pass or overflow of untreated or partially treated waste is prohibited.
3. On-site disposal of dewatered sludge is prohibited.

B. Discharge Specifications:

1. Neither the treatment nor the discharge shall cause a pollution or nuisance as defined by the California Water Code, Section 13050.
2. The 30-day average daily dry weather discharge flow shall not exceed .5 million gallons.
3. Collected screening, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.
4. The dissolved oxygen content of treatment ponds shall not be less than 1.0 mg/l for 16 hours in any 24-hour period.

C. Provisions:


1. The Discharger shall comply with the attached Monitoring and Reporting Program No. 86-021.
2. The Discharger shall comply with the Standard Provisions and Reporting Requirements, dated 1 September 1985, which are a part of this Order.

WASTE DISCHARGE REQUIREMENTS
TUOLUMNE REGIONAL WATER DISTRICT
TWIN HARTE WASTEWATER TREATMENT PLANT
TUOLUMNE COUNTY

-3-

3. The Discharger shall provide certified wastewater treatment plant operators in accordance with regulations adopted by the State Water Resources Control Board.
4. The Discharger shall report promptly to the Board any material change or proposed change in the character, location, or volume of the discharge.
5. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this office.
6. The Board will review this Order periodically and may revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 24 January 1985.



WILLIAM H. CROOKS, Executive Officer

12/17/85:BCN:gs

Attachments

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 86-021

FOR
TUOLUMNE REGIONAL WATER DISTRICT
TWIN HARTE WASTEWATER TREATMENT PLANT
TUOLUMNE COUNTY

INFLUENT MONITORING

The following shall constitute the influent monitoring program:

<u>Constituent</u>	<u>Units</u>	<u>Sample Type</u>	<u>Sampling Frequency</u>
Flow	mgd	Continuous	Daily
BOD	mg/l	Grab	Weekly
Suspended Solids	mg/l	Grab	Weekly
Settleable Solids	ml/l	Grab	Weekly

SLUDGE MONITORING

Semi-annually, the Discharger shall report the volume of dewatered sludge removed from the drying beds during the previous six months. The presence or absence of odors and flies shall be noted.

REPORTING

In conducting the monitoring program, the Discharger shall keep a daily log. In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly the compliance with waste discharge requirements.

Monthly monitoring reports shall be submitted to the Regional Board by the 15th day of the following month.

The results of any monitoring done more frequently than required at the locations specified in the Monitoring and Reporting Program shall be reported to the Board.

Upon written request of the Board, the Discharger shall submit a report to the Board by 30 January of each year. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year. In

MONITORING AND REPORTING PROGRAM
TUOLUMNE REGIONAL WATER DISTRICT
TWIN HARTE WASTEWATER TREATMENT PLANT
TUOLUMNE COUNTY

-2-

addition, the Discharger shall discuss the compliance record and the corrective actions taken or planned which may be needed to bring the discharge into full compliance with the waste discharge requirements.

The Discharger shall implement the above monitoring program on the effective date of this Order.

Ordered by

William H. Crooks

WILLIAM H. CROOKS, Executive Officer

24 January 1986

(Date)

12/10/85:BCN:gs

INFORMATION SHEET

TUOLUMNE REGIONAL WATER DISTRICT
TWIN HARTE WASTEWATER TREATMENT PLANT
TUOLUMNE COUNTY

The Twain Harte WWTP treats .25 mgd of domestic sewage from the community of Twain Harte. The treatment works consist of: a mechanical bar rack, two claragestors, an aerated lagoon with two surface aerators, a polishing pond, and sludge drying beds. Design flow is .5 mgd. Effluent is discharged to the Sonora WWTP for additional treatment via a 14 mile interceptor. Sludge was formally buried on-site, but is now combined with sludge from the Sonora WWTP and disposed of as a soil amendment.

12/10/85:BCN:gs

TUOLUMNE REGIONAL WATER DISTRICT
 TWAIN HARTE WWTP
 Section 18, T2N, R16E, MDB&M
 USGS 15 Min. Columbia Quad
 Tuolumne County

Scale: 1 inch = 5208 ft
 1 cm = 625 M

