

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 86-210

WASTE DISCHARGE REQUIREMENTS
FOR

ALTUA VILLAGE
SACRAMENTO COUNTY

*name change to
River City Recovery Center*

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board), finds that:

1. Altua Village (hereafter Discharger) submitted a Report of Waste Discharge, dated 22 February 1986
2. The Board, on 18 November 1966, adopted Resolution 67-57 which prescribed requirements for a discharge from on-site domestic sources to percolation/evaporation ponds and crop land.
3. Present waste discharge requirements established by the Board are neither adequate nor consistent with plans and policies of the Board.
4. The Discharger discharges 2,000 gallons per day from on-site domestic sources to a series of four percolation/evaporation ponds.
5. Altua Village is in Section 8, T5N, R7E, MDB&M with surface water drainage to Skunk Creek, a tributary to Laguna Creek, and the Cosumnes River, and the San Joaquin Delta.
6. The beneficial uses of the Cosumnes River and the Delta are municipal, agricultural and industrial supply; recreation; esthetic enjoyment; navigation; ground water recharge; fresh water replenishment; and preservation and enhancement of fish, wildlife, and other aquatic resources.
7. The beneficial uses of the ground water are: municipal, industrial, agricultural supply.
8. The Board, on 25 July 1975, adopted a Water Quality Control Plan for the Sacramento-San Joaquin Delta Basin (58) which contains water quality objectives for all waters of the Basin. These requirements are consistent with that Plan.
9. The action to update waste discharge requirements for this domestic wastewater disposal facility is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301, Title 14, California Administrative Code.
10. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.

11. The Board, in a public meeting, heard and considered all comments pertaining to this discharge.

IT IS HEREBY ORDERED, that Resolution No. 67-57 be rescinded, and Altua Village in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

1. The direct discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. The by-pass or overflow of untreated or partially treated waste is prohibited.

B. Discharge Specifications:


1. Neither the treatment nor disposal of wastes shall cause a pollution or nuisance as defined by the California Water Code, Section 13050.
2. The discharge shall not cause degradation of any water supply.
3. The discharge shall remain within the designated disposal area (shown on the attached map) at all times.
4. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.
5. Reclaimed wastewater shall meet the criteria contained in Title 22, Division 4, California Administrative Code. (Section 60301, et seq.).
6. The dissolved oxygen content of holding ponds shall not be less than 1.0 mg/l for 16 hours in any 24-hour period.

C. Provisions:

1. The Discharger may be required to submit monitoring or technical reports as directed by the Executive Officer.
2. By 15 February of each year, the discharger shall submit to the Board a report summarizing the operation of the wastewater facilities and compliance with this Order during the previous year.

3. The Discharger shall comply with the Standard Provisions and Reporting Requirements, dated 1 September 1985, which are a part of this Order.
4. The Discharger shall report promptly to the Board any material change or proposed change in character, location, or volume of the discharge.
5. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this office.
6. The Board will review this Order periodically and may revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 24 October 1986.


WILLIAM H. CROOKS, Executive Officer

GDM:jj

Attachment

INFORMATION SHEET

ALTUA VILLAGE SACRAMENTO COUNTY

Altua Village is an alcohol recovery ranch seven miles northeast of Galt. This nonprofit organization was founded in 1959 and is licensed and certified by the California Department of Alcohol and Drug Programs to serve up to 102 adult residents.

The existing wastewater treatment and disposal system was designed and built by the County of Sacramento for a design population of 100 people. The system consists of three wet well sewage collection sumps in series, a transfer pump, and a series of four evaporation/percolation ponds about 60' x 60' in combined area. Existing wastewater disposal facilities are adequate for the current population of 50 men.

Although the sewage system was designed and installed by the County, maintenance is provided by Altua Village. Maintenance activities include routine wet well solids removal by a qualified contractor.

GDM:jj

