

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 87-190

28

WASTE DISCHARGE REQUIREMENTS
FOR
NEVADA COUNTY
SANITATION DISTRICT NO. 1
NORTH SAN JUAN WASTEWATER FACILITY
NEVADA COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. Nevada County (hereafter Discharger) submitted a Report of Waste Discharge, dated 25 August 1987, requesting waste discharge requirements for the proposed North San Juan wastewater facility. The property on which the wastewater treatment and disposal will occur is owned by the Bureau of Land Management and United States Forest Service. The County will obtain the necessary use permits and be responsible for the entire system.
2. The Community of North San Juan presently utilizes individual septic tanks with leachfields for wastewater disposal and is within the North San Juan septic tank prohibition area, established by Board Order No. 74-123.
3. The Discharger proposes an average discharge of 24,000 gallons per day (gpd) to land via a community septic tank/leachfield system.
4. The proposed wastewater system will provide treatment in two, approximately 30,000 gallon septic tanks on BLM property and effluent disposal in a community leachfield on U.S. Forest Service property.
5. The North San Juan wastewater treatment facility is in Section 32, T18N, R8E, and Section 5, T17N, R8E, MDB&M, with surface water drainage to the Middle Fork Yuba River.
6. The beneficial uses of the Middle Fork Yuba River are municipal and agricultural supply; recreation; esthetic enjoyment; navigation; ground water recharge; fresh water replenishment; hydroelectric power generation; and preservation and enhancement of fish, wildlife and other aquatic resources.
7. The beneficial uses of the ground water are domestic and agricultural supply.
8. The Board, on 25 July 1975, adopted a Water Quality Control Plan for the San Joaquin River Basin (5B), which contains water quality objectives. These requirements are consistent with that Plan.
9. Nevada County has adopted a final environmental impact report (EIR), in accordance with the California Environmental Quality Act, (Public Resources Code Section 21000, et seq.), and the State Guidelines.

WASTE DISCHARGE REQUIREMENTS
NEVADA COUNTY
SANITATION DISTRICT NO. 1
NORTH SAN JUAN WASTEWATER FACILITY
NEVADA COUNTY

10. The Board has reviewed the EIR and concurs there will not be significant impacts on water quality.
11. This discharge is exempt from the requirements of Section 2511(a), Subchapter 15, Chapter 3, Title 23, of the California Administrative Code (CAC). The exemption is based on the following:
 - a. The Board has issued waste discharge requirements.
 - b. The discharge is in compliance with the applicable Water Quality Control Plan, and
 - c. Sludges will be discharged in accordance with the applicable provisions of Subchapter 15.
12. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.
13. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Nevada County, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

1. The direct discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. The by-pass or overflow of untreated or partially treated waste is prohibited.

B. Discharge Specifications:

1. Neither the treatment nor the discharge shall cause a pollution or nuisance as defined by the California Water Code, Section 13050.
2. The discharge shall not cause degradation of any water supply.
3. The discharge shall remain within the designated disposal area at all times.
4. Effluent discharged to leachfields shall remain underground at all times.

WASTE DISCHARGE REQUIREMENTS
NEVADA COUNTY
SANITATION DISTRICT NO. 1
NORTH SAN JUAN WASTEWATER FACILITY
NEVADA COUNTY

-3-

5. The 30-day average daily dry weather discharge flow shall not exceed 24,000 gallons.
6. The maximum daily wet weather flow shall not exceed 30,000 gallons.
7. Collected screening, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.

C. Provisions:

1. The Discharger may be required to submit technical reports as directed by the Executive Officer.
2. The Discharger shall comply with the attached Monitoring and Reporting Program No. 87-190.
3. By 1 May 1988, the Discharger shall submit an operation and maintenance plan and a comprehensive ground water monitoring program to ensure proper operation of the system. The ground water monitoring program shall include a minimum of two downgradient monitoring wells below each leachfield.
4. The Discharger shall comply with the Standard Provisions and Reporting Requirements, dated 1 September 1985, which are a part of this Order.
5. The Discharger shall report promptly to the Board any material change or proposed change in the character, location, or volume of the discharge.
6. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this office.
7. The Board will review this Order periodically and may revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 23 October 1987.



WILLIAM H. CROOKS, Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 87-190

FOR
NEVADA COUNTY
SANITATION DISTRICT NO. 1
NORTH SAN JUAN WASTEWATER FACILITY
NEVADA COUNTY

Specific sample station locations shall be established under direction of the Board's staff.

Prior to construction, plans and specifications for ground water monitoring and observation wells shall be submitted to Board staff and the Nevada County Environmental Health Department for review and approval.

GROUND WATER MONITORING

All ground water samples shall be grab samples. Ground water monitoring shall consist of the following:

<u>Constituent</u>	<u>Units</u>	<u>Stations</u>	<u>Sampling Frequency</u>
Depth to Ground Water	Feet	All	Twice Monthly
Total and Fecal Coliform Organisms	MPN/100 ml	All	Monthly

INFLUENT MONITORING

The following shall constitute the influent monitoring program:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Flow	gpd	Cumulative	Quarterly

PERCOLATION BEDS

Leachfield Inspection Risers

A minimum of 8 inspection risers shall be established as designated monitoring points. The selected risers shall be located so as to adequately characterize the entire subsurface disposal area. The selected risers will be permanently numbered. The total depth of each riser from ground surface will be established and recorded. The location of the selected risers shall be established under direction of the Board's staff. For each riser, the following shall constitute the monitoring program:

<u>Constituents Measured</u>	<u>Units</u>	<u>Frequency</u>
Depth of water, if any	Feet	Twice Monthly

MONITORING AND REPORTING PROGRAM
NEVADA COUNTY
SANITATION DISTRICT NO. 1
NORTH SAN JUAN WASTEWATER FACILITY
NEVADA COUNTY

-2-

The Discharger shall maintain bimonthly records of the condition of the ground in and around the percolation beds. The presence or absence of the following will be recorded:

- a. odors
- b. surfacing effluent, seeps, wet spots
- c. excessive vegetation growth

REPORTING

In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly the compliance with waste discharge requirements.


Monthly monitoring reports shall be submitted to the Regional Board by the 15th day of the following month.

The results of any monitoring done more frequently than required at the locations specified in the Monitoring and Reporting Program shall be reported to the Board.

Upon written request of the Board, the Discharger shall submit a report to the Board by 30 January of each year. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year. In addition, the Discharger shall discuss the compliance record and the corrective actions taken or planned which may be needed to bring the discharge into full compliance with the waste discharge requirements.

The Discharger shall implement the above monitoring program upon initiating waste discharge.

Ordered by



WILLIAM H. CROOKS, Executive Officer

23 October 1987

Date

INFORMATION SHEET

NEVADA COUNTY
SANITATION DISTRICT NO. 1
NORTH SAN JUAN WASTEWATER FACILITY
NEVADA COUNTY

The community of North San Juan presently utilizes individual septic tank/leach-field systems for wastewater treatment and disposal. The shallow soils and ground water in the area are not conducive to on-site systems. In December 1973, in response to public health concerns in the community, the Regional Board adopted Order No. 74-123, which prohibited additional discharges from conventional individual systems. The proposed community system will be on BLM and Forest Service property outside the community with soils more conducive to subsurface wastewater disposal.

The system is being constructed with the aid of Clean Water Grant monies and Farmers' Home Administration funds. The Nevada County Department of Transportation, Sanitation District No. 1, will oversee the construction and operation of the entire system.

Design flow is for 24,000 gallons per day (130 equivalent dwelling units) average dry weather flow. A 30,000 gallon per day peak wet weather flow provision is proposed to ensure that flushing of the septic tanks does not occur.

The North San Juan community experiences high precipitation (80 in/yr) and low evaporation (30 in/yr). Based in part on these climatic conditions, the septic tank/leachfield system was chosen over the previously proposed pond system.

9/3/87:BCN:gs

