

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. 88-012

WASTE DISCHARGE REQUIREMENTS
FOR
RIO RAMAZA UTILITIES MANAGEMENT PROJECT
SUTTER COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter Board) finds that:

1. The Board, on 24 June 1977, adopted Order No. 77-193 which prescribed requirements for a discharge from Sutter County's Rio Ramaza Utilities Management Project (hereafter Discharger) to land.
2. Present waste discharge requirements established by Order 77-193 are neither adequate nor consistent with plans and policies of the Board.
3. The Discharger discharges approximately 10,000 gallons per day of domestic sewage (design flow 0.168 mgd) from a residential development to stabilization ponds.
4. The Rio Ramaza Utilities Management Project is in Section 1, T10N, R3E, MDB&M, with surface water drainage to Reclamation District 1000 North Drainage Canal, thence the Sacramento River.
5. The beneficial uses of the Sacramento River are municipal, industrial, and agricultural supply; recreation; esthetic enjoyment; navigation; ground water recharge; fresh water replenishment; hydroelectric power generation; and preservation and enhancement of fish, wildlife and other aquatic resources.
6. The beneficial uses of the ground water are municipal, industrial, and agricultural supply.
7. The Board, on 25 July 1975, adopted a Water Quality Control Plan for the Sacramento River Basin (5A) which contains water quality objectives for all waters of the Basin. These requirements are consistent with that Plan.
8. The action to revise waste discharge requirements for this facility is exempt from the provisions of the California Environmental Quality Act, in accordance with Section 15301, Title 14, California Code of Regulations (CCR).
9. The Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.
10. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.
11. This discharge is exempt from the requirements of Section 2511(b), Subchapter 15, Chapter 3, Title 23, of the CCR. The exemption is based on the following:

WASTE DISCHARGE REQUIREMENTS
RIO RAMAZA UTILITIES MANAGEMENT PROJECT
SUTTER COUNTY

-2-

- a. the Board has issued waste discharge requirements,
- b. the discharge is in compliance with the applicable Water Quality Control Plan, and
- c. the wastewater does not need to be managed according to Chapter 30 of Division 4, Title 22, as a hazardous waste.

IT IS HEREBY ORDERED that Order No. 77-193 be rescinded and Sutter County and the Rio Ramaza Utilities Management Project, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

A. Discharge Prohibitions:

1. The direct discharge of wastes to surface waters or surface water drainage courses is prohibited.
2. The by-pass or overflow of untreated or partially treated wastes is prohibited.

B. Discharge Specifications:

1. Neither the treatment nor the discharge shall cause a nuisance or condition of pollution as defined by the California Water Code, Section 13050.
2. The Discharge shall not cause degradation of any water supply.
3. The discharge shall remain within the designated disposal area at all times.
4. A minimum freeboard of 2.0 feet shall be maintained in the ponds.
5. The 30-day average daily dry weather discharge flow shall not exceed 0.168 million gallons.
6. Collected screening, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer.
7. The dissolved oxygen content of holding ponds shall not be less than 1.0 mg/l for 16 hours in any 24-hour period.

C. Provisions:


1. The Discharger may be required to submit technical reports as directed by the Executive Officer.

WASTE DISCHARGE REQUIREMENTS
RIO RAMAZA UTILITIES MANAGEMENT PROJECT
SUTTER COUNTY

-3-

2. The Discharger shall comply with the attached Monitoring and Reporting Program No. 88-012.
3. The Discharger shall report promptly to the Board any material change or proposed change in the character, location, or volume of the discharge.
4. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be forwarded to this Office.
5. The Board will review this Order periodically and may revise requirements when necessary.

I, WILLIAM H. CROOKS, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 29 January 1988.



WILLIAM H. CROOKS, Executive Officer

JWK/mm:12/16/87

Attachments

INFORMATION SHEET

RIO RAMAZA UTILITIES MANAGEMENT PROJECT SUTTER COUNTY

Rio Ramaza Utilities Management Project is an existing wastewater treatment facility approximately 4 miles south of Verona in Sutter County. The facility is operated by the Sutter County Department of Public Works, and it consists of a lift station, a distribution box, and two stabilization ponds.

Waste discharge requirements were originally adopted for this facility in 1973, at which time there were 125 lots in the project. There are currently approximately 30 residences remaining. This reduction is due to the purchasing of property by Sacramento County to facilitate a proposed expansion of the Sacramento Metropolitan Airport. Sacramento County intends to continue purchasing residences at a rate of 3 to 5 homes per year.

JWK/mm

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. 88-012

FOR
RIO RAMAZA UTILITIES MANAGEMENT PROJECT
SUTTER COUNTY

WASTEWATER POND MONITORING

The following shall constitute the wastewater pond monitoring program:

<u>Constituents</u>	<u>Units</u>	<u>Station</u>	<u>Sampling Frequency</u>
Freeboard	Feet	Ponds	Monthly

REPORTING

In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly the compliance with waste discharge requirements.

Quarterly monitoring reports shall be submitted to the Regional Board by the 15th day following the calendar quarter.

The results of any monitoring done more frequently than required at the locations specified in the Monitoring and Reporting Program shall be reported to the Board.

Upon written request of the Board, the Discharger shall submit a report to the Board by 30 January of each year. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year. In addition, the Discharger shall discuss the compliance record and the corrective actions taken or planned which may be needed to bring the discharge into full compliance with the waste discharge requirements.

The Discharger shall implement the above monitoring program as of the date of this Order.


WILLIAM H. CROOKS, Executive Officer

29 January 1988
(Date)

