

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION**

**MONITORING AND REPORTING PROGRAM R5-2014-0153-DWQ-R5428
FOR
INDIAN VALLEY COMMUNITY SERVICES DISTRICT
GREENVILLE WASTEWATER PONDS**

PLUMAS COUNTY

This Monitoring and Reporting Program (MRP) describes requirements for monitoring a wastewater disposal pond system. This MRP is issued pursuant to Water Code section 13267. The Discharger shall not implement any changes to this MRP until a revised MRP is issued by the Regional Water Quality Control Board (Regional Water Board) Executive Officer.

Water Code section 13267 states, in part:

“In conducting an investigation specified in subdivision (a), the regional board may require that any person who has discharged, discharges, or is suspected of having discharged or discharging, or who proposes to discharge waste within its region, or any citizen or domiciliary, or political agency or entity of this state who has discharged, discharges, or is suspected of having discharged or discharging, or who proposes to discharge, waste outside of its region that could affect the quality of waters within its region shall furnish, under penalty of perjury, technical or monitoring program reports which the regional board requires. The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports. In requiring those reports, the regional board shall provide the person with a written explanation with regard to the need for the reports and shall identify the evidence that supports requiring that person to provide the reports.”

Water Code section 13268 states, in part:

“(a) Any person failing or refusing to furnish technical or monitoring program reports as required by subdivision (b) of section 13267, or failing or refusing to furnish a statement of compliance as required by subdivision (b) of section 13399.2, or falsifying any information provided therein, is guilty of a misdemeanor and may be liable civilly in accordance with subdivision (b).

(b)(1) Civil liability may be administratively imposed by a regional board in accordance with article 2.5 (commencing with section 13323) of chapter 5 for a violation of subdivision (a) in an amount which shall not exceed one thousand dollars (\$1,000) for each day in which the violation occurs.”

The Discharger owns and operates the wastewater treatment system that is subject to the Notice of Applicability (NOA) of Water Quality Order 2014-0153-DWQ. The reports

are necessary to ensure that the Discharger complies with the NOA and General Order. Pursuant to Water Code section 13267, the Discharger shall implement this MRP and shall submit the monitoring reports described herein.

All samples shall be representative of the volume and nature of the discharge or matrix of material sampled. The name of the sampler, sample type (grab or composite), time, date, location, bottle type, and any preservative used for each sample shall be recorded on the sample chain of custody form. The chain of custody form must also contain all custody information including date, time, and to whom samples were relinquished. If composite samples are collected, the basis for sampling (time or flow weighted) shall be approved by Regional Water Board staff.

Field test instruments (such as those used to test pH, dissolved oxygen, and electrical conductivity) may be used provided that they are used by a State Water Board California Environmental Laboratory Accreditation Program certified laboratory, or:

1. The user is trained in proper use and maintenance of the instruments;
2. The instruments are field calibrated prior to monitoring events at the frequency recommended by the manufacturer;
3. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency; and
4. Field calibration reports are maintained and available for at least three years.

POND SYSTEM MONITORING

Influent Monitoring

Influent samples shall be taken from a location that provides representative samples of the wastewater and flow rate. At a minimum, influent monitoring shall consist of the following:

Constituent	Units	Sample Type	Sampling Frequency	Reporting Frequency
Flow Rate ^a	gpd	Meter	Continuous	Quarterly

gpd denotes gallons per day. mg/L denotes milligrams per liter.

- a. At a minimum, the total flow shall be measured monthly to calculate the average daily flow for the month. Flow may be calculated if approved by Regional Water Board staff.

Wastewater Pond Monitoring

All wastewater ponds (lined and unlined) shall be monitored as specified below:

Constituent	Units	Sample Type	Sampling Frequency	Reporting Frequency
Dissolved Oxygen	mg/L	Grab	Monthly	Quarterly
Biochemical Oxygen Demand	mg/L	Grab	Monthly	Quarterly
Freeboard	0.1 feet	Measurement	Monthly	Quarterly
Odors	NA	Observation	Monthly	Quarterly
Berm condition	NA	Observation	Monthly	Quarterly

mg/L denotes milligrams per liter. NA denotes not applicable.

Effluent Monitoring

Effluent samples shall be taken from a location that provides representative samples of the wastewater and flow rate. At a minimum, effluent monitoring shall consist of the following:

Constituent	Units	Sample Type	Sampling Frequency	Reporting Frequency
Biochemical Oxygen Demand	mg/L	Grab	Monthly	Quarterly

mg/L denotes milligrams per liter.

SOLIDS DISPOSAL MONITORING

The Discharger shall report the handling and disposal of all solids (e.g., screenings, grit, sludge, biosolids, etc.) generated at the wastewater system. Records shall include the name/contact information for the hauling company, the type and amount of waste transported, the date removed from the wastewater system, the disposal facility name and address, and copies of analytical data required by the entity accepting the waste. These records shall be submitted as part of the next quarterly monitoring report that follows the disposal date.

GROUNDWATER MONITORING

The Discharger shall monitor groundwater quality. Consistent with the Business and Professions Code, groundwater monitoring reports, well construction workplans, etc. shall be prepared under the supervision of a California licensed civil engineer or geologist. Prior to construction of any groundwater monitoring wells, the Discharger shall submit plans and specifications to the Regional Water Board's staff for review and approval. Once installed, all monitoring wells designated as part of the monitoring network shall be sampled and analyzed according to the schedule below.

The data from routine groundwater monitoring events shall be submitted quarterly. Analysis of the data and groundwater flow directions shall be performed at least annually and shall be performed under the supervision of a California licensed professional (as described above). The Discharger may request a reduced monitoring and reporting schedule once adequate data has been collected to characterize the site. (Typically two years of quarterly sampling is required for adequate characterization.)

Prior to sampling, groundwater elevations shall be measured, and the wells shall be purged of at least three well volumes and until pH and electrical conductivity have stabilized. No-purge, low-flow, or other sampling techniques are acceptable if they are described in an approved Sampling and Analysis Plan. Depth to groundwater shall be measured to the nearest 0.01 feet. Groundwater elevations shall be calculated. Samples shall be collected using approved USEPA methods. Groundwater monitoring shall include, at a minimum, the following:

Constituent	Units	Sample Type	Sampling/Reporting Frequency ^c
Groundwater Elevation ^a	0.01 Feet	Calculated	Quarterly
Depth to Groundwater	0.01 Feet	Measurement	Quarterly
Gradient	Feet/Feet	Calculated	Quarterly
Gradient Direction	degrees	Calculated	Quarterly
pH	Std. Units	Grab	Quarterly
Total Dissolved Solids	mg/L	Grab	Quarterly
Nitrate as Nitrogen	mg/L	Grab	Quarterly
Sodium	mg/L	Grab	Quarterly

Constituent	Units	Sample Type	Sampling/Reporting Frequency ^c
Chloride	mg/L	Grab	Quarterly
Total Coliform Organisms ^b	MPN/100 ml	Grab	Quarterly

MPN/100 ml denotes most probable number per 100 mL sample. Std. Units denotes standard units. mg/L denotes milligrams per liter.

- Groundwater elevation shall be based on depth to water using a surveyed measuring point elevation on the well and a surveyed.
- Using a minimum of 15 tubes or three dilutions.
- Analysis of data by a California licensed professional is required at least annually.

REPORTING REQUIREMENTS

The Discharger must submit all monitoring reports and analytical monitoring results to the State Water Resources Control Board's (State Water Board's) GeoTracker database. GeoTracker is an Internet-accessible database system used by the State Water Board, regional boards, and local agencies to track and archive compliance data from authorized or unauthorized discharges of waste to land, or unauthorized releases of hazardous substances from underground storage tanks. This system consists of a relational database, online compliance reporting features, a geographical information system (GIS) interface, and other features that are utilized by regulatory agencies, regulated industries, and the public to input, manage, or access compliance and regulatory tracking data.

GeoTracker Electronic Reporting Requirements: All monitoring reports and monitoring results shall be submitted to GeoTracker in accordance with the timeframes specified below and in searchable Portable Document Format (PDF). The Discharger shall follow the applicable Electronic Submittal of Information (ESI) requirements under the Facility-specific **Global Identification Number WDR100031680** at the [GeoTracker](https://geotracker.waterboards.ca.gov/esi/login.asp) database. (<https://geotracker.waterboards.ca.gov/esi/login.asp>)

In order to submit reports electronically, the Discharger shall create a secure GeoTracker ESI account and log in credentials, claim their facility by requesting access in GeoTracker, and finally uploading PDF copies of the required reports via the ESI portal as outlined in the GeoTracker ESI Beginner's Guide for Responsible Parties (Beginner's Guide) linked below. The Discharger may complete the above tasks by accessing the 'Getting Started' section on the GeoTracker [ESI webpage](https://www.waterboards.ca.gov/ust/electronic_submittal/index.html). (https://www.waterboards.ca.gov/ust/electronic_submittal/index.html)

Additional GeoTracker support information can be found at the following:

1. 'Guides/Resources' document link in the "Tools" on the Discharger's GeoTracker ESI account.
2. Resources on the GeoTracker ESI website, such as the [Beginner's Guide](https://www.waterboards.ca.gov/ust/electronic_submittal/docs/geotracker_esi_rp_beginner_s_guide_revisedoct2019.pdf) (https://www.waterboards.ca.gov/ust/electronic_submittal/docs/geotracker_esi_rp_beginner_s_guide_revisedoct2019.pdf)
3. General GeoTracker Help Desk contact information:
Phone: 1-866-480-1028, Email: geotracker@waterboards.ca.gov

A transmittal letter shall accompany each monitoring report. The letter shall include a discussion of all violations of this MRP during the reporting period and actions taken or planned for correcting each violation. If the Discharger has previously submitted a report describing corrective actions taken and/or a time schedule for implementing the corrective actions, reference to the previous correspondence will be satisfactory. The transmittal letter shall contain a statement by the Discharger or the Discharger's authorized agent certifying under penalty of perjury that the report is true, accurate and complete to the best of the signer's knowledge.

In reporting monitoring data, the Discharger shall arrange the data in tabular form so that the date, sample type (e.g., effluent, solids, etc.), and reported analytical or visual inspection results are readily discernible. The data shall be summarized to clearly illustrate compliance with the General Order and NOA as applicable. The results of any monitoring done more frequently than required at the locations specified in the MRP shall be reported in the next regularly scheduled monitoring report and shall be included in calculations as appropriate.

Laboratory analysis reports shall be included in the monitoring reports. All laboratory reports must also be retained for a minimum of three years. For a Discharger conducting any of its own analyses, reports must also be signed and certified by the chief of the laboratory.

Monitoring information shall include the method detection limit (MDL) and the Reporting limit (RL) or practical quantitation limit (PQL). If the regulatory limit for a given constituent is less than the RL (or PQL), then any analytical results for that constituent that are below the RL (or PQL) but above the MDL shall be reported and flagged as estimated.

A. Monitoring Reports

Quarterly reports shall be submitted to the Regional Water Board on the **first day of the second month after the quarter ends** (e.g. the January-March

Quarterly Report is due by May 1st). The reports shall bear the certification and signature of the Discharger's authorized representative. At a minimum, the quarterly reports shall include:

1. Results of all required monitoring.
2. A comparison of monitoring data to the discharge specifications, disclosure of any violations of the NOA and/or General Order, and an explanation of any violation of those requirements. (Data shall be presented in tabular format.)
3. If requested by staff, copies of laboratory analytical report(s) and chain of custody form(s).

B. Annual Reports

Annual reports shall be submitted to the Regional Water Board with the fourth quarter monitoring report by **March 1st following the monitoring year**. The annual report shall include the following:

1. Tabular and graphical summaries of all monitoring data collected during the year.
2. An evaluation of the performance of the wastewater treatment facility, including discussion of capacity issues, nuisance conditions, system problems, and a forecast of the flows anticipated in the next year. A flow rate evaluation as described in the General Order (Provision E.2.c) shall also be submitted.
3. An evaluation of the performance of the wastewater treatment facility, including discussion of capacity issues, nuisance conditions, system problems, and a forecast of the flows anticipated in the next year. A flow rate evaluation as described in the General Order (Provision E.2.c) shall also be submitted.
4. A discussion of compliance and the corrective action taken, as well as any planned or proposed actions needed to bring the discharge into compliance with the NOA and/or General Order.
5. A discussion of any data gaps and potential deficiencies/redundancies in the monitoring system or reporting program.
6. The name and contact information for the wastewater operator responsible for operation, maintenance, and system monitoring.
7. A groundwater monitoring report prepared by a California licensed professional. This report may be prepared separately from the rest of the Annual Report. The report shall contain an analysis of groundwater data collected during the year.

The analysis shall include a description of the sample events, copies of the field logs, purge method and volume, groundwater elevation and trend, a groundwater elevation map for each sample event, summary tables showing results for parameters measured, comparison of groundwater quality parameters to standards in the NOA, chain-of-custody forms, calibration logs for field equipment used, and a general evaluation of any impacts the wastewater discharge is having on groundwater quality.

A letter transmitting the monitoring reports shall accompany each report. The letter shall report violations found during the reporting period, and actions taken or planned to correct the violations and prevent future violations. The transmittal letter shall contain the following penalty of perjury statement and shall be signed by the Discharger or the Discharger's authorized agent:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of the individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

The Discharger shall implement the above monitoring program as of the date of this MRP.

Ordered by:

For PATRICK PULUPA, Executive Officer