

Central Valley Regional Water Quality Control Board

28 February 2014

WDID #5A520703001

Mr. William Poytress
Fish and Wildlife Service
Red Bluff Office
10950 Tyler Road
Red Bluff, CA 96080

NOTICE OF APPLICABILITY (NOA), WATER QUALITY ORDER 97-10-DWQ-R5156, U.S. DEPARTMENT OF INTERIOR FISH AND WILDLIFE SERVICE, FISHERIES ASSISTANCE OFFICE, TEHAMA COUNTY

In January 2014, The U.S. Fish and Wildlife Service, Fisheries Assistance Office, in Tehama County, responded with information pertaining to the Central Valley Regional Water Quality Control Board (Central Valley Water Board) staff's request for updated information for the facility's domestic wastewater treatment and disposal system.

Based on the information provided, the facility treats and disposes of less than 20,000 gallons of wastewater per day, and is therefore eligible for coverage under the general and specific conditions of State Water Resources Control Board (State Water Board) Water Quality Order 97-10-DWQ *General Waste Discharge Requirements for Discharges to Land by Small Domestic Wastewater Treatment Systems* (General Order). This letter serves as formal notice that General Order 97-10-DWQ is applicable to the site and the discharge described below. You are hereby assigned General Order No. 97-10-DWQ-R5156 for this facility.

You should familiarize yourself with the contents of the entire General Order which prescribes mandatory discharge and monitoring requirements. The facility must be operated in accordance with the requirements contained in the General Order, and Monitoring and Reporting Program (MRP) 97-10-DWQ-R5156.

A copy of the General Order is enclosed. You can also find the General Order on the State Water Board's website at:

http://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/1997/wq1997_10.pdf.

REGULATORY BACKGROUND

Discharges of domestic wastewater from the facility were formerly regulated under Waste Discharge Requirements (WDRs) 90-007, adopted by the Central Valley Regional Water Quality Control Board (Central Valley Water Board) on 26 January 1990. These WDRs required routine monitoring of wastewater flow, dissolved oxygen, freeboard, and observations of potential nuisance conditions of which were compiled into monthly monitoring reports submittals.

DISCHARGE DESCRIPTION

Domestic wastewater from the Fisheries Assistance Office flows by gravity to a lift station containing dual ejection pumps. One pump is used at a time, so that a secondary pump is available in the event of needed service. Sewage is then pumped to one of two unlined evaporation/percolation ponds. A third pond is connected to the first two receiving ponds and is available if needed for additional capacity. The distribution of wastewater to the first two ponds is controlled manually by a metal plate at a tee in the distribution line to the ponds. Wastewater flow rates are estimated based on potable water use rates, which average 500 to 700 gallons per day.


FACILITY SPECIFIC REQUIREMENTS

The Discharger shall comply with the terms and conditions of General Order 97-10-DWQ-R5156 and will maintain exclusive control over the discharge. As such, the Discharger is primarily responsible for compliance with General Order 97-10-DWQ-R5156, this NOA and the attached MRP 97-10-DWQ. The Discharger's wastewater treatment system will fall under the surface disposal and pond/basin sections of General Order 97-10-DWQ-R5156 and MRP 97-10-DWQ. Failure to comply with the requirements in the Order could result in an enforcement action as authorized by provisions of the California Water Code. Discharge of wastes other than those described in the Report of Waste Discharge is prohibited. If the method of waste disposal changes from that described in your Report of Waste Discharge, you must submit a new Report of Waste Discharge describing the new operation.

The required annual fee specified in the annual billing from the State Water Board shall be paid until this NOA is officially terminated. You must notify this office in writing if the discharge regulated by this Order ceases so that we may terminate coverage and avoid unnecessary billing.

Please note that WDRs Order 90-007 is proposed to be rescinded at the 5/6 June 2014 meeting of the Central Valley Water Board. Upon rescission of individual WDRs Order No. 90-007, coverage under General Order 97-10-DWQ shall become applicable subject to this Notice of Applicability.

If you have any questions regarding submitting an updated report of waste discharge, making changes to your permitted operations, compliance or enforcement please contact Katie Connaughton at (530) 226-3458, Katie.Connaughton@waterboards.ca.gov, or the footer address.



PAMELA C. CREEDON
Executive Officer

KC:lmw

Attachments: General Order No. 97-10-DWQ and MRP No. 97-10-DWQ