
Los Angeles Regional Water Quality Control Board

April 30, 2024

Nathan Jacobsen
311 Main Road
Suite 1 N45V
Point Mugu, CA 93042
nathan.j.jacobsen.civ@us.navy.mil

REVISED ENROLLMENT UNDER THE GENERAL WASTE DISCHARGE REQUIREMENTS FOR SMALL DOMESTIC WASTEWATER TREATMENT SYSTEMS FOR SAN NICOLAS ISLAND WWTP AT BUILDING 27, SAN NICOLAS ISLAND, CALIFORNIA 93042 (FILE NO. 20-065, WDR ORDER WQ 2014-0153-DWQ, SERIES NO. 057, CI NO. 10667, GLOBAL ID WDR100052324)

Dear Nathan Jacobsen:

The Los Angeles Regional Water Quality Control Board (Los Angeles Water Board) is the public agency with primary responsibility for the protection of ground and surface water quality for all beneficial uses of water within major portions of Los Angeles and Ventura Counties. The subject property is within the Los Angeles Water Board jurisdiction.

On June 20, 2022, the Department of the Navy, U.S. Naval Air Weapons Station, Point Mugu (Discharger) was authorized to discharge under general waste discharge requirements (WDRs) Order 2014-0153-DWQ and monitoring and reporting program No. CI-10667 at San Nicolas Island (SNI) Wastewater Treatment Plant (WWTP). The WWTP serves a small Naval facility on the San Nicolas Island with an average population of 240 Navy personnel and contractors, the majority of which are temporary or transient residents.

On January 18, 2024, the Los Angeles Water Board received your request to increase the discharge volume to 60,000 gallons per day (gpd) from the current limit of 20,000 gpd. The reason for this request is to increase the ability of the operators to gain freeboard in the three treatment ponds when experiencing unusually large and frequent storm events.

Based on the October 2021 report submitted by the Discharger, titled *Technical Report Addendum 1 – Additional Change in Design and Operation Information*, the 24-hour-soak percolation rate of the land application areas (LAAs) at the subject site was 0.26 inches per hour (in/hr). Disposal of effluent from the ponds is via spray irrigation onto the LAA #1 and LAA #2 using Rain Bird Type 35A sprinklers, each with a flow rate of 4 gallons per minute and a throw radius of 40 feet.

LAA #1 has 14 sprinklers and LAA #2 has 12 sprinklers, for a total maximum daily discharge capacity of 149,760 gpd. Based on the 24-hour-soak percolation rate of 0.26 in/hr and the areas of the two LAAs (LAA #1 is 44,950 square feet and LAA #2 is 13,850 square feet), LAA #1 has a percolation capacity of 174,850 gpd and LAA #2 has a percolation capacity of 53,875 gpd. Additionally, both LAAs are surrounded by 12-inch berms and have runoff capture drains which return any runoff to the treatment ponds, reducing the risk of overspills from the LAAs.

Based on the estimated percolation capacities for LAAs, the maximum treated wastewater disposal flowrate to LAA #1 shall not exceed 60,000 gpd, while the disposal flowrate to LAA #2 shall not exceed 30,000 gpd. Total disposal flowrate shall not exceed 60,000 gpd. The effluent limit for total nitrogen shall be 10 mg/L. A revised MRP No. CI-10667 is also included as an attachment with additional monitoring required for total nitrogen in the effluent. The effective date of these changes is **April 30, 2024**. All other requirements outlined in the June 20, 2022, notice of enrollment and Order No. WQ 2014-0153-DWQ remain in effect.

If you have any additional questions, please contact the Project Manager, Mr. Ryan Nickerson at (213) 620-6119 (ryan.nickerson@waterboards.ca.gov) or the Groundwater Permitting Unit Supervisor, Dr. James Kang, P.E. at (213) 576-6683 (jim.kang@waterboards.ca.gov).

Sincerely,

Jenny Newman
Digitally signed by Jenny Newman
Date: 2024.04.30 14:28:16 -07'00'

for Susana Arredondo
Executive Officer

Enclosure:
Revised Monitoring and Reporting Program No. CI-10667