
Central Valley Regional Water Quality Control Board

9 March 2018

Jay Steinbach, Owner
Interstate 5 Travel Center
5382 N. McCall Avenue
Clovis, CA 93619

CERTIFIED MAIL
7017 1070 0000 8970 9073

NOTICE OF APPLICABILITY (NOA), STATE WATER RESOURCES CONTROL BOARD ORDER WQ 2014-0153-DWQ-R5232, GENERAL WASTE DISCHARGE REQUIREMENTS FOR SMALL DOMESTIC WASTEWATER TREATMENT SYSTEMS, JAY STEINBACH, INTERSTATE 5 TRAVEL CENTER, ONSITE WASTEWATER TREATMENT SYSTEM, FRESNO COUNTY

On 15 March 2017, O.S.T System Designs, Inc., on behalf of Jay Steinbach (hereafter "Discharger"), Owner of the Interstate 5 Travel Center (Travel Center), submitted a Report of Waste Discharge (RWD) and technical report for a new wastewater treatment system at the Travel Center, also known as the Hillcrest Travel Plaza in Fresno County. OST submitted a Revised On-Site Sewage Treatment System Design report on 9 May 2017 due to the relocation of the leachfield, and a second Revised On-Site Sewage Treatment System Design report in September 2017 with the required stamp and signature of a California Professional Civil Engineer. Based on the information provided, the system treats and disposes of less than 100,000 gallons of wastewater per day, and is therefore eligible for coverage under the general and specific conditions of State Water Resources Control Board (State Water Board) Water Quality Order 2014-0153-DWQ *General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems* (General Order). This letter serves as formal notice that the General Order is applicable to your system and the wastewater discharge described below. You are hereby assigned General Order 2014-0153-DWQ-R5232 for your system.

You should familiarize yourself with the entire General Order and its attachments enclosed with this letter, which describe mandatory discharge and monitoring requirements. Sampling, monitoring, and reporting requirements applicable to your treatment and disposal methods must be completed in accordance with the appropriate treatment system sections of the General Order and the attached *Monitoring and Reporting Program* (MRP) No. 2014-0153-DWQ-R5232. The MRP was developed after consideration of your waste characterization and site conditions described in the attached memorandum.

DISCHARGE DESCRIPTION

The Travel Center is at 44779 South Lassen Avenue about 8 miles south of Huron and about 5 miles north of Avenal at the intersection of Interstate 5 and State Highway 269 (Lassen Avenue), as shown on Attachment A. The Travel Center is in the northwest quarter of Section 26, Township 21 South, Range 17 East, Mount Diablo Base and Meridian in Fresno County.

The former onsite wastewater treatment system (OWTS) at the Travel Center consisted of a 1,500-gallon capacity grease interceptor, an 8,000 gallon septic tank, and a failed leachfield as shown on Attachment B. All but the grease interceptor was removed and replaced with an upgraded OWTS. The new OWTS retained the 1,500-gallon grease interceptor, but added an effluent filter and an alarm. The new septic tanks consist of a 30,000 gallon primary septic tank, a 15,000 gallon secondary septic tank equipped with aerators, and a 15,000 gallon surge tank. The surge tank can handle surges and peak flows that may occur during weekends and holidays, and is equipped with an Orenco Duplex pump system for timed dosing of effluent to the new leachfield. The effluent is discharged from the surge tank into a new 1,000-linear foot leachfield with ten 100-foot laterals. Each leachfield lateral has an inspection port for monitoring wastewater depth in the leach trenches. Fresno County approved the proposed system design on 9 May 2017.

The anticipated average daily flow from the new OWTS will be about 7,500 gallons per day (gpd) with estimated peak flows of 11,145 gpd on weekends and holidays. The maximum permitted flow rate is 15,000 gpd.

FACILITY SPECIFIC REQUIREMENTS

The Discharger will maintain exclusive control over the discharge, and shall comply with the terms and conditions of this Notice of Applicability (NOA), General Order 2014-0153-DWQ-R5232, with all attachments, and MRP No. 2014-0153-DWQ-R5232.

In accordance with the requirements of the General Order, discharges without shallow groundwater and average flow rates less than 20,000 gpd are not required to meet a nitrogen effluent limitation.

In accordance with Section B.1 of the General Order, treated wastewater discharged to the Facility's leachfield shall not exceed 15,000 gpd as a monthly average.

The General Order states in Section B.1.I that the Discharger shall comply with the setbacks as described in Table 3. This table summarizes different setback requirements for wastewater system equipment, activities, land application areas, and storage and/or treatment ponds from sensitive receptors and property lines where applicable. The Discharger shall comply with the applicable setback requirements, as summarized in the following table:

Site Specific Applicable Setback Requirements				
Equipment or Activity	Domestic Well	Flowing Stream ¹	Ephemeral Stream Drainage ²	Property Line
Septic Tank ³	150 ft. ⁴	50 ft. ⁵	50 ft.	5 ft. ⁵
Leach Field ⁶	100 ft. ⁵	100 ft. ⁵	50 ft.	5 ft. ⁵

1. A flowing stream shall be measured from the ordinary high water mark established by fluctuations of water elevation and indicated by characteristics such as shelving, changes in soil character, vegetation type, presence of litter or debris, or other appropriate means.
2. Ephemeral Stream Drainage denotes a surface water drainage feature that flows only after rain or snow-melt and does not have sufficient groundwater seepage (baseflow) to maintain a condition of flowing surface water. The drainage shall be measured from a line that defines the limit of the ordinary high water mark (described in "a" above). Irrigation canals are not considered ephemeral streams drainage features. The ephemeral stream shall be a "losing stream" (discharging surface water to groundwater) at the proposed wastewater system site.
3. Septic Tank addresses equipment located below ground or that impedes leak detection by routine visual inspection.
4. Setback established by Onsite Wastewater Treatment System Policy, section 7.5.6.
5. Setback established by California Plumbing Code, Table K-1.
6. Leach Field includes all subsurface dispersal systems, including mound systems except seepage pits.

The Discharger shall comply with the septic system requirements specified in Section B.2 of the General Order. In particular, the General Order states in Section B.2.d that septic tanks shall be pumped when any of the following conditions exist.

- i. The combined thickness of sludge and scum exceeds one-third of the tank depth of the first compartment.
- ii. The scum layer is within 3 inches of the outlet device.
- iii. The sludge layer is within 8 inches of the outlet device.

The Discharger shall comply with the septic system requirements specified in Section B.6 of the General Order. With regards General Order Section B.6.b., and as stated in the RWD, there is sufficient reserve area for leachfield replacement under this Order WQ 2014-0153-DWQ-R5232.

Provision E.1. of the General Order requires dischargers enrolled under the General Order to prepare and implement the following reports within 90 days of the issuance of the NOA (8 March 2018).

- Spill Prevention and Emergency Response Plan (Provision E.1.a).
- Sampling and Analysis Plan (Provision E.1.b).

Failure to comply with the requirements in this NOA, General Order 2014-0153-DWQ-R5232, with all attachments, and MRP No. 2014-0153-DWQ-R5232 could result in an enforcement action as authorized by provisions of the California Water Code. Discharge of wastes other than those described in this NOA is prohibited. If the method of waste disposal changes from that described in this NOA, you must submit a new Report of Waste Discharge describing the new operation.

The required annual fee specified in the annual billing from the State Water Board shall be paid until this NOA is officially terminated. You must notify this office in writing if the


discharge regulated by the General Order ceases, so that we may terminate coverage and avoid unnecessary billing.

The Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board) has gone to a Paperless Office System. All regulatory documents, submissions, materials, data, monitoring reports, and correspondence should be converted to a searchable Portable Document Format (PDF) and submitted electronically. Documents that are less than 50MB should be emailed to: centralvalleyfresno@waterboards.ca.gov. Documents that are 50MB or larger should be transferred to a disk and mailed to the Central Valley Water Board office at 1685 E Street, Fresno, CA 93706. To ensure that your submittals are routed to the appropriate staff, the following information block should be included in any email used to transmit documents to this office: Program: Non-15, WDID: 5C10NC00203, Facility: Interstate 5 Travel Center OWTS, Order: 2014-0153-DWQ-R5232.

In order to conserve paper and reduce mailing costs, a paper copy of the General Order has been sent only to the Discharger. Others are advised that the General Order is available on the State Water Board's web site at:

http://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf

If you have any questions regarding this matter, please contact Jeff Pyle by phone at (559) 445-5145, by email at jpyle@waterboards.ca.gov.



for Pamela C. Creedon
Executive Officer

Attachments: Attachment A – Site Location Map
Attachment B – Site Map
Monitoring and Reporting Program No. 2014-0153-DWQ-R5232
Technical Memorandum, Jay Steinbach, Interstate 5 Travel Center
Onsite Wastewater Treatment System, Report of Waste Discharge
State Water Resources Control Board Order WQ 2014-0153-DWQ
(Discharger Only)

cc: Ms. Janet Gardner, Fresno County Health Department of Public Health,
Environmental Health (via email)
Armando G. Flores, O.S.T. System Designs, Inc (via email)