
Central Coast Regional Water Quality Control Board

September 26, 2016

Lisa Arroyo
Wastewater System Manager
Public Works Department
City of Santa Barbara
630 Garden Street
Santa Barbara, CA 93102
Email:
larroyo@santabarbaraca.gov

Sent via Electronic Mail only

Dear Ms. Arroyo:

**NOTICE OF APPLICABILITY FOR GENERAL WASTE DISCHARGE REQUIREMENTS,
ORDER WQ 2016-0068-DDW, EL ESTERO WATER RECYCLING FACILITY, CITY OF
SANTA BARBARA, SANTA BARBARA COUNTY**

Water Board staff has reviewed your Notice of Intent (NOI) to comply with the terms of the General Waste Discharge Requirements for Recycled Water Use, State Water Resources Control Board, Order WQ 2016-0068-DDW (General Permit) for City of Santa Barbara El Estero Water Recycling Facility, Santa Barbara County. We also received your first annual fee. We understand the following:

- In a package dated April 20, 2016, we received your NOI and Title 22 Engineering Report. On March 17, 2016, we received a letter stating acceptance of your Title 22 Engineering Report by Jeff Densmore of the State Water Resources Control Board Division of Drinking Water.
- Increased uses of recycled water are documented in the 2015 El Estero Wastewater Treatment Plant Tertiary Filtration Plant Replacement Amended Title 22 Engineering Report produced by CDM Smith.
- The City of Santa Barbara owns the Water Recycling Facility (WRF) and operates the WRF and wastewater collection system. The City's primary responsible individual who is charged with operation and oversight of the water recycling program is Lisa Arroyo, Wastewater System Manager for the City of Santa Barbara, (805) 564-5486 or larroyo@santabarbaraca.gov. The El Estero Wastewater Treatment Plant Chief Operator is Thomas Welche, a Grade V operator, who can be contacted at (805) 568-1002 or twelche@santabarbaraca.gov (who is also copied on this letter).
- The WRF meets the requirements of Title 22, California Code of Regulations for tertiary recycled water of the highest degree, meeting a 2.2 most probable number (MPN)

coliform disinfection requirement. Detailed effluent limitations and monitoring data are contained in the submitted El Estero Wastewater Treatment Plant Tertiary Filtration Plant Replacement Amended Title 22 Engineering Report (CDM Smith, 2015).

The City of Santa Barbara, El Estero Wastewater Treatment Tertiary Treatment Plant discharge is hereby enrolled under the General Permit. You are required to comply with the General Permit and the monitoring and reporting program (MRP). A copy of the General Permit and MRP can be obtained at the following website:

http://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2016/wqo20160068_ddw.pdf

Water Board staff will notify the Central Coast Water Board of your enrollment in the General Permit at its next regularly scheduled meeting in Watsonville on December 8-9, 2016. After a 30-day public comment period, the Water Board will consider rescinding the City's individual order (No. 97-044) at its regularly scheduled meeting in January 2017 to avoid duplicate regulation.

If you have any questions, please contact **Peter von Langen at (805) 549-3688** (peter.vonlangen@waterboards.ca.gov) or Sheila Soderberg at (805) 549-3592 (Sheila.soderberg@waterboards.ca.gov).

Sincerely,

 Digitally signed by Harvey C.
Packard
Date: 2016.09.26 10:22:09 -07'00'

for John M. Robertson
Executive Officer

cc:

Josh Haggmark, City of Santa Barbara, JHaggmark@SantaBarbaraCA.gov
Thomas Welche, City of Santa Barbara, twelche@santabarbaraca.gov
Lawrence Fay Jr., Santa Barbara County Public Health, Lawrence.Fay@sbcphd.org
Jeff Densmore, Division of Drinking Water, jeff.densmore@waterboards.ca.gov
Peter von Langen, Water Board, peter.vonlangen@waterboards.ca.gov
Chris Adair, Water Board, chris.adair@waterboards.ca.gov