

Los Angeles Regional Water Quality Control Board

October 3, 2022

Ms. Lysa Gaboudian, Supervising Engineer
Los Angeles County Sanitation District, Reuse & Compliance Section
1955 Workman Mill Road
Whittier, CA 90601

RESPONSE TO REQUEST FOR MODIFICATION OF THE MONITORING AND REPORTING PROGRAM (MRP) FOR WASTE DISCHARGE REQUIREMENTS (WDRS) AND NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT FOR THE JOINT OUTFALL SYSTEM, WHITTIER NARROWS WATER RECLAMATION PLANT (WHITTIER NARROWS WRP), EL MONTE, CA (NPDES PERMIT NUMBER CA0053716, ORDER NUMBER R4-2021-0096, CI-2848)

Dear Ms. Gaboudian:

On September 2, 2022 the California Regional Water Quality Control Board, Los Angeles Region (Los Angeles Water Board) staff received an email request from the Joint Outfall System (JOS) to modify the required sample type for TCDD equivalents from a grab sample to a 24-hour composite sample in the Monitoring and Reporting Program (MRP) for the National Pollutant Discharge Elimination System (NPDES) permit (Order Number R4-2021-0096) for the Whittier Narrows Water Reclamation Plant (WRP). JOS made the request to reduce duplicative monitoring since 24-hour composite sampling for 2,3,7,8-TCDD is required in the MRP included in the Notice of Applicability for the Whittier Narrows WRP enrollment in Order WQ 2016-0068-DDW. JOS also proposes to use glass sample containers for 24-hour composite sampling of TCDD equivalents to mitigate any potential interference.

The Los Angeles Water Board staff reviewed the request from JOS and has determined the proposed change is appropriate. The MRP of Order Number R4-2021-0096 is hereby modified as follows. Changes to the MRP appear in strikethrough and underline format.

1. Table E-2 (page E-8 to page E-9):

Table E-2. Influent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Note
Remaining USEPA priority pollutants excluding asbestos	µg/L	24-hour composite; grab for VOCs, Cyanide; and grab or composite for bis(2-ethylhexyl) phthalate and <u>2,3,7,8-TCDD</u>	Semiannually	b, d, and f

Footnotes for Table E-2

JAMES STAHL, ACTING CHAIR | RENEE PURDY, EXECUTIVE OFFICER

f. The 40 CFR Part 136 method for phthalate esters including bis (2-ethylhexyl) phthalate and for 2,3,7,8-TCDD requires samples to be collected in glass sample containers to avoid interference, which can lead to artifacts and/or elevated baselines in gas chromatograms. Sample collection must be done using glass sample containers for all phthalate esters including bis (2-ethylhexyl) phthalate and for 2,3,7,8-TCDD unless analytical methods for these pollutants in 40 CFR Part 136 specify that other means of sample collection are approved. Grab sample type is recommended, but an automatic sampler (composite sample) can be used to collect samples for all phthalate esters including bis (2-ethylhexyl) phthalate and for 2,3,7,8-TCDD as long as the sample bottles are glassware.

End of footnotes for Table E-2

2. Table E-3 (page E-9 to page E-13):

Table E-3. Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Note
TCDD Equivalents	pg/L	grab <u>or composite</u>	quarterly	b, & j, & <u>m</u>

Footnotes for Table E-3

m. The 40 CFR Part 136 method for phthalate esters including bis (2-ethylhexyl) phthalate and for TCDD equivalents requires samples to be collected in glass sample containers to avoid interference, which can lead to artifacts and/or elevated baselines in gas chromatograms. Sample collection must be done using glass sample containers for all phthalate esters including bis (2-ethylhexyl) phthalate and for TCDD equivalents unless analytical methods for these pollutants in 40 CFR Part 136 specify that other means of sample collection are approved. Grab sample type is recommended, but an automatic sampler (composite sample) can be used to collect samples for all phthalate esters including bis (2-ethylhexyl) phthalate and for TCDD equivalents as long as the sample bottles are glassware.

End of footnotes for Table E-3

If you have any questions, please contact [Xiaofei Cui](mailto:xiaofei.cui@waterboards.ca.gov) at xiaofei.cui@waterboards.ca.gov and (213) 576-6696 or [Steven Webb](mailto:steven.webb@waterboards.ca.gov) at steven.webb@waterboards.ca.gov and (213) 576-6793.

Sincerely

Renee Purdy
Executive Officer