

Central Valley Regional Water Quality Control Board

25 April 2019

WDID: 5A450001003

Mr. Patrick Minturn
Shasta County Department of Public Works
1855 Placer Street
Redding, CA 96001

CERTIFIED MAIL:
7018 1130 0001 8556 0073

NOTICE OF APPLICABILITY (NOA), WATER QUALITY ORDER 2014-0153-DWQ-R5310, SHASTA COUNTY SERVICE AREA NO. 13, ALPINE MEADOWS/WHISPERING WOODS, SHASTA COUNTY

On 1 March 2019 Central Valley Regional Water Quality Control Board (Central Valley Water Board) staff inspected the wastewater facilities at the Shasta County Service Area No. 13 (hereafter "Discharger"), or Alpine Meadows and Whispering Woods Estates subdivisions, located on Alpine Meadows Road and Emigrant Trail, in Shingletown, Shasta County. Based on the site inspection and a case file review, the facility treats and disposes of less than 100,000 gallons of wastewater per day and is therefore eligible for coverage under the general and specific conditions of State Water Resources Control Board (State Water Board) Water Quality Order 2014-0153-DWQ *General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems* (General Order). This letter serves as formal notice that the General Order is applicable to your facility and the wastewater discharge described below. You are hereby assigned General Order 2014-0153-DWQ-R5310 for your facility.

You should familiarize yourself with the entire General Order and its attachments enclosed with this letter, which prescribe mandatory discharge and monitoring requirements. Sampling, monitoring, and reporting requirements applicable to your treatment and disposal methods must be completed in accordance with the appropriate treatment system sections of the *General Order* and the attached *Monitoring and Reporting Program* (MRP). This MRP was developed after consideration of your waste characterization and site conditions described in the attached *Technical Memorandum*.

REGULATORY BACKGROUND

The Central Valley Water Board currently regulates discharges from this Facility under Waste Discharge Requirements (WDRs) Order R5-2005-0025, adopted on 27 January 2005. The Monitoring and Reporting Program requires the following:

- Monthly effluent flow from each septic tank/leach field system as total gallons
- Monthly visual monitoring of the leach field areas for saturated soils, standing liquid, or nuisance conditions.
- Annual septic tank maintenance inspections and pumping events.
- Weekly depth to water in Alpine Meadows piezometers, both disposal areas (January through March)

KARL E. LONGLEY SCD, P.E., CHAIR | PATRICK PULUPA, ESQ., EXECUTIVE OFFICER

364 Knollcrest Drive, Suite 205, Redding, CA 96002 | www.waterboards.ca.gov/centralvalley

- Monthly depth to water in Alpine Meadows piezometers, both disposal areas (April through December)
- Monthly depth to water in Whispering Woods Estates piezometers

DISCHARGE DESCRIPTION

The Alpine Meadows subdivision is located on the south side of Highway 44 on Alpine Meadows Road and Chateau Drive in Shingletown, Shasta County. The Alpine Meadows wastewater treatment and disposal facility is located in Section 5, T30N, R1E, MDB&M in Shasta County. The system consists of two septic tanks, a gravity collection system, a lift station equipped with alternating pumps, a force main and two leach field areas, one serving ten commercial lots with a design capacity of 3,000 gallons per day (gpd) and the other serving four residential lots with a 2,128 gpd capacity. The four residential lots have not been developed and the associated leach field area has not been used. The leach fields are all on the same parcel and adjacent to one another. Both leach field systems have piezometers to monitor groundwater depth.

The Whispering Woods Estates subdivision is located in Section 32 T31N, R1E, MDB&N on the north side of Highway 44 on Emigrant Trail Road. The wastewater system serves 42 residences with a gravity sewer collection system, a common septic tank, a lift station with alternating pumps, a force main, and a leach field. The treatment and disposal system has a maximum daily flow capacity of 14,700 gpd. The leach field area has piezometers to monitor shallow groundwater depths.

This is an existing facility; therefore, enrollment under the General Order is categorically exempt from the California Environmental Quality Act (CEQA) pursuant to California Code of Regulations, title 14, section 15301 which applies to ongoing or existing projects.

FACILITY SPECIFIC REQUIREMENTS

The Discharger will maintain exclusive control over the discharge and shall comply with the terms and conditions of this NOA and the General Order 2014-0153-DWQ-R5310, with all attachments.

Additionally, the General Order states in Section B.1.L that the discharger shall comply with the setbacks as described in Table 3. This table summarizes different setback requirements for wastewater system equipment, activities, land application areas, and storage and/or treatment ponds from sensitive receptors and property lines where applicable. The Discharger shall comply with the following applicable setback requirements as summarized in the following table.

Site Specific Applicable Setback Requirements					
Equipment or Activity	Domestic Well	Flowing Stream ^a	Ephemeral Stream Drainage ^b	Property Line	Lake or Reservoir ^d
Septic Tank, Aerobic Treatment Unit, Treatment System, or Collection System ^e	150 ft. ^y 100 ft. ^o 50 ft. ^c	20 ft. ¹	50 ft.	50 ft. ^{c, z}	200 ft. ^w 50 ft. ^c
Leach Field ^f	100 ft. ^{o, c}	100 ft. ^c	50 ft.	50 ft. ^c	200 ft. ^w 100 ft. ^c
¹ Initial setback requirements of 50 feet have been waived in accordance with Section B.1.L (v). ^a A flowing stream shall be measured from the ordinary high-water mark established by fluctuations of water elevation and indicated by characteristics such as shelving, changes in soil character, vegetation type, presence of litter or debris, or other appropriate means. ^b Ephemeral Stream Drainage denotes a surface water drainage feature that flows only after rain or snow-melt and does not have sufficient groundwater seepage (baseflow) to maintain a condition of flowing surface water. The drainage shall be measured from a line that defines the limit of the ordinary high-water mark (described in "a" above). Irrigation canals are not considered ephemeral streams drainage features. The ephemeral stream shall be a "losing stream" (discharging surface water to groundwater) at the proposed wastewater system site. ^c Setback established by California Plumbing Code, Table K-1. ^d Lake or reservoir boundary measured from the high-water line. ^e Septic Tank, Aerobic Treatment Unit, Treatment System, or Collection System addresses equipment located below ground or that impedes leak detection by routine visual inspection. ^f Leach Field includes all subsurface dispersal systems, including mound systems except seepage pits. ^o California Well Standards, part II, section 8. Site-specific conditions may allow reduced setback or require an increased setback. See discussion in Well Standards. ^w Setback established by the Onsite Wastewater Treatment System Policy, section 7.5.5. ^y Setback established by Onsite Wastewater Treatment System Policy, section 7.5.6. ^z Collection system to property line setback is not applicable.					

The collection system is greater than one mile in length and publicly-owned which means it is subject to the Statewide General Waste Discharge Requirements for Sanitary Sewer Systems Order No. 2006-0003-DWQ, adopted by the State Water Resources Control Board (State Water Board) on 2 April 2006. The facility is currently enrolled and has a Sanitary Sewer Overflow (SSO) Database account through the California Integrated Water Quality System (CIWQS) to report SSOs to the State Water Board, as required.

Failure to comply with the requirements in the documents could result in an enforcement action as authorized by provisions of the California Water Code. Discharge of wastes other than those described in this NOA is prohibited. If the method of waste disposal changes from that described in this NOA, you must submit a new Report of Waste Discharge describing the new operation.

The required annual fee specified in the annual billing from the State Water Board shall be paid until this NOA is officially terminated. You must notify this office in writing if the discharge regulated by the General Order ceases, so that we may terminate coverage and avoid unnecessary billing.

Facility Information	
Facility Name	Shasta CSA No. 13, Alpine Meadows/Whispering Woods
Program	WDR
Order Number	2014-0153-DWQ-R5310
WDID	5A450001003
Design Flow	19,825 gpd
Threat and Complexity	3B
Monitoring Requirements	Daily flow, monthly depth to water in piezometers, quarterly visual inspections of leach field area, annual septic tank evaluations

Billing Information	
Name	Shasta County Public Works Department
Contact	Troy Bartolomei
Email	tbartolomei@co.shasta.ca.us
Address	1855 Placer St., Redding, CA 96001
Phone	530-225-5661

The Central Valley Water Board has gone to a Paperless Office System. All regulatory documents, MRPs, submissions, materials, data, monitoring reports, and correspondence should be converted to a searchable Portable Document Format (PDF) and submitted electronically. Documents that are less than 50MB should be emailed to: centralvalleyredding@waterboards.ca.gov. Documents that are 50MB or larger should be transferred to a disc and mailed to the appropriate regional water board office, in this case 364 Knollcrest Drive, Suite 205, Redding, CA 96002. To ensure that your submittals are routed to the appropriate staff, the following information block should be included in any email used to transmit documents to this office:

WDID: 5A4450001003

Order: 2014-0153-DWQ-R5310

Please note that WDRs Order R5-2005-0025 is proposed to be rescinded at the 6/7 June 2019 meeting of the Central Valley Water Board. Following Board meeting approval, coverage for your facility under the 2014-0153-DWQ General Order shall become applicable subject to this Notice of Applicability.

If you have any questions regarding submitting an updated report of waste discharge, making changes to your permitted operations, compliance or enforcement please contact Monique Gaido by phone at (530) 224-4205, by email at monique.gaido@waterboards.ca.gov, or at the footer address.

Executive Officer

MEG: ch

Attachments: Technical Memorandum
Monitoring and Reporting Program
Shasta CSA No. 13, Alpine Meadows/Whispering Woods Location Map
Alpine Meadows/Whispering Woods Facility Map
Alpine Meadows Leach Field Map
Whispering Woods Leach Field Map
General Order 2014-0153-DWQ

cc w/o enclo: Shasta County Environmental Health Division, Redding
Tim O'Brien, State Water Board, Sacramento
David Lancaster, SWRCB, Office of Chief Counsel, Sacramento