

Central Valley Regional Water Quality Control Board

3 April 2019

WDID: 5A32NC00018

Mr. Aaron Corr, General Manager
Grizzly Ranch Community Service District
4456 Grizzly Road
Portola, CA 96122

CERTIFIED MAIL:
7018 1130 0001 8556 3111

Mr. Caleb Olson
Grizzly Ranch Golf Club LLC
250 Clubhouse Dr
Portola, CA 96122

NOTICE OF APPLICABILITY (NOA), WATER QUALITY ORDER 2014-0153-DWQ-R5301, GRIZZLY RANCH COMMUNITY SERVICES DISTRICT, PLUMAS COUNTY

On 8 August 2018 Central Valley Regional Water Quality Control Board (Central Valley Water Board) staff inspected the wastewater and water reclamation facilities at Grizzly Ranch Community Services District (hereafter "Discharger") located at 4456 Grizzly Ranch Road, northeast of Portola, in Plumas County. To date the Discharger has stored and hauled all wastewater for offsite disposal because wastewater flows are too low to operate the existing treatment facility. No discharges to surface water have occurred.

Based on the January 2019 Report of Waste Discharge (ROWD) application, the facility plans to amend their current wastewater treatment system to treat smaller volumes onsite and eliminate surface water discharges. In a 20 February 2019 letter the Central Valley Water Board deemed the ROWD complete and the Discharger proceeded with plans to treat wastewater onsite and discharge reclaimed wastewater on the adjacent golf course owned and operated by the Grizzly Ranch Golf Club LLC.

According to the 2019 ROWD, the Discharger will treat and dispose of less than 100,000 gallons of wastewater per day and is therefore eligible for coverage under the general and specific conditions of State Water Resources Control Board (State Water Board) Water Quality Order 2014-0153-DWQ *General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems* (General Order). Currently the facility discharges to surface water are covered under Waste Discharge Requirements Order R5-2011-0081 (NPDES Order CA0085162), adopted on 1 December 2011 and reclaimed water discharges to the adjacent golf course are covered under Waste Discharge Requirements R5-2007-0001.

This letter serves as formal notice that the General Order is applicable to your facility and the wastewater discharge described below. You are hereby assigned General Order 2014-0153-DWQ-R5301 for your facility.

KARL E. LONGLEY ScD, P.E., CHAIR | PATRICK PULUPA, ESQ., EXECUTIVE OFFICER

364 Knollcrest Drive, Suite 205, Redding, CA 96002 | www.waterboards.ca.gov/centralvalley

You should familiarize yourself with the entire General Order and its attachments enclosed with this letter, which prescribes mandatory discharge and monitoring requirements. Sampling, monitoring, and reporting requirements applicable to your treatment and disposal methods must be completed in accordance with the appropriate treatment system sections of the *General Order* and the attached *Monitoring and Reporting Program* (MRP). This MRP was developed after consideration of your waste characterization and site conditions described in the attached *Technical Memorandum*.

REGULATORY BACKGROUND

The Central Valley Water Board regulates wastewater discharges and water reclamation activities for this Facility under the Waste Discharge Requirements and Water Recycling Requirements Order R5-2011-0081 (NPDES No. CA0085162) (WDRs) adopted on 11 December 2011 for discharges to Big Grizzly Creek. The Monitoring and Reporting Program requires the following:

- Continuous influent flow in millions of gallons per day (MGD)
- Prior to treatment system operation, daily amounts of wastewater pumped and hauled

DISCHARGE DESCRIPTION

Grizzly Ranch CSD is located at 169 Spring Meadow Drive northeast of Portola in Sections 16, 17, and 21, T23N, R14E, MDB&M.

This is an existing facility; therefore, enrollment under the General Order is categorically exempt from the California Environmental Quality Act (CEQA) pursuant to California Code of Regulations, Title 14, Section 15301 which applies to ongoing or existing projects.

FACILITY SPECIFIC REQUIREMENTS

The Discharger will maintain exclusive control over the discharge and shall comply with the terms and conditions of this NOA and the General Order 2014-0153-DWQ-R5301, with all attachments.

Additionally, the General Order states in Section B.1.L that the discharger shall comply with the setbacks as described in Table 3. This table summarizes different setback requirements for wastewater system equipment, activities, and storage and/or treatment ponds from sensitive receptors and property lines where applicable. The Discharger shall comply with the following applicable setback requirements as summarized in the following table.

Site Specific Applicable Setback Requirements					
Equipment or Activity	Domestic Well	Flowing Stream ^a	Ephemeral Stream Drainage ^b	Property Line	Lake or Reservoir ^d
Septic Tank, Aerobic Treatment Unit, Treatment System, or Collection System ^e	150 ft. ^y 100 ft. ^o 50 ft. ^c	50 ft. ^c	50 ft.	5 ft. ^{c, z}	200 ft. ^w 50 ft. ^c
LAA (disinfected sec-2.2 or sec-23 recycled water) ^h	100 ft. ^r	50 ft.	50 ft.	100 ft. ^x 50 ft. ^p	200 ft.
Spray Irrigation (disinfected tertiary recycled water) ^k	No spray irrigation of any recycled water, other than disinfected tertiary recycled water, shall take place within 100 feet of a residence or a place where public exposure could be similar to that of a park, playground, or school yard.				
Impoundment (disinfected sec-2.2 or sec-23 recycled water) ^h	100 ft. ^r	100 ft.	100 ft.	50 ft.	200 ft.
LAA denotes Land Application Area. Sec denotes secondary. ^a A flowing stream shall be measured from the ordinary high-water mark established by fluctuations of water elevation and indicated by characteristics such as shelving, changes in soil character, vegetation type, presence of litter or debris, or other appropriate means. ^b Ephemeral Stream Drainage denotes a surface water drainage feature that flows only after rain or snow-melt and does not have sufficient groundwater seepage (baseflow) to maintain a condition of flowing surface water. The drainage shall be measured from a line that defines the limit of the ordinary high-water mark (described in "a" above). Irrigation canals are not considered ephemeral streams drainage features. The ephemeral stream shall be a "losing stream" (discharging surface water to groundwater) at the proposed wastewater system site. ^c Setback established by California Plumbing Code, Table K-1. ^d Lake or reservoir boundary measured from the high-water line. ^e Septic Tank, Aerobic Treatment Unit, Treatment System, or Collection System addresses equipment located below ground or that impedes leak detection by routine visual inspection. ^h Disinfected secondary-2.2 recycled water is defined in California Code of Regulations, title 22, section 60301.220. Disinfected secondary-23 recycled water is defined in California Code of Regulations, title 22, section 60301.225. ^k Additional restrictions for spray irrigation of recycled water are contained in California Code of Regulations, title 22, section 60310(f) ^o California Well Standards, part II, section 8. Site-specific conditions may allow reduced setback or require an increased setback. See discussion in Well Standards. ^p Setback for drip or flood application methods. Spray irrigation is subject to additional setbacks and restrictions. (See footnote k.) ^r Setback established by California Code of Regulations, title 22, section 60310(c). ^w Setback established by the Onsite Wastewater Treatment System Policy, section 7.5.5. ^x Setback established by California Code of Regulations, title 22, section 60310(f). ^y Setback established by Onsite Wastewater Treatment System Policy, section 7.5.6. ^z Collection system to property line setback is not applicable.					

Failure to comply with the requirements in the documents could result in an enforcement action as authorized by provisions of the California Water Code. Discharge of wastes other than those described in this NOA is prohibited. If the method of waste disposal changes from that described in this NOA, you must submit a new Report of Waste Discharge describing the new operation.

The required annual fee specified in the annual billing from the State Water Board shall be paid until this NOA is officially terminated. You must notify this office in writing if the discharge regulated by the General Order ceases, so that we may terminate coverage and avoid unnecessary billing.

Facility Information	
Facility Name	Grizzly Ranch CSD
Program	WDR
Order Number	2014-0153-DWQ-R5301
WDID	5A32NC00018
Design Flow	15,000 gpd
Threat and Complexity	3B
Monitoring Requirements	Daily flow, quarterly visual inspection of ponds and land application areas, quarterly, annual septic tank evaluation

Billing Information	
Name	Grizzly Ranch WW Recycling FAC
Contact	Aaron Corr
Email	grizzlyranchcsd@gmail.com
Address	4456 Grizzly Rd, Portola, CA 96122
Phone	(530) 832-4716

The Central Valley Water Board has gone to a Paperless Office System. All regulatory documents, MRPs, submissions, materials, data, monitoring reports, and correspondence should be converted to a searchable Portable Document Format (PDF) and submitted electronically. Documents that are less than 50MB should be emailed to: centralvalleyredding@waterboards.ca.gov. Documents that are 50MB or larger should be transferred to a disc and mailed to the appropriate regional water board office, in this case 364 Knollcrest Drive, Suite 205, Redding, CA 96002. To ensure that your submittals are routed to the appropriate staff, the following information block should be included in any email used to transmit documents to this office:

Program: WDR

WDID: 5A32NC00018

Facility Name: Grizzly Ranch CSD

Order: 2014-0153-DWQ-R5301

Please note that WDR Order R5-2011-0081 (NPDES Order CA0085162) and WDR Order R5-2007-0001 are proposed to be rescinded at the 1/2 August 2019 meeting of the Central Valley Water Board. However, coverage for your facility under the General Order is effective upon receipt of this Notice of Applicability.

If you have any questions regarding submitting an updated report of waste discharge, making changes to your permitted operations, compliance or enforcement please contact Monique Gaido by phone at (530) 224-4205, by email at Monique.gaido@waterboards.ca.gov, or by mail at the Redding address shown above for report submittals.


(for) Patrick Pulupa
Executive Officer

3 April 2019

MEG:

Attachments: Technical Memorandum
Monitoring and Reporting Program
Grizzly Ranch CSD Location Map
Grizzly Ranch CSD Facility Map
Grizzly Ranch CSD Process Flow Diagram
General Order 2014-0153-DWQ

Electronic copy

cc w/ enclo: Daniel Smith, Grizzly Ranch CSD, Portola

cc w/o enclo: Plumas County Environmental Health Division, Redding
Tim O'Brien, State Water Board, Sacramento
David Lancaster, SWRCB, Office of Chief Counsel, Sacramento