

## Los Angeles Regional Water Quality Control Board

August 29, 2023

Lysa Gaboudian, Supervising Engineer  
Joint Outfall System  
San Jose Creek Water Reclamation Plant  
1965 South Workman Mill Road  
Whittier, CA 90601

**ADMINISTRATIVE REVISIONS TO MONITORING AND REPORTING PROGRAM (MRP) FOR WASTE DISCHARGE REQUIREMENTS (WDRs) AND NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT FOR THE JOINT OUTFALL SYSTEM, SAN JOSE CREEK WATER RECLAMATION PLANT (NPDES NO. CA0053911, ORDER NO. R4-2021-0131, CI-5542)**

Dear Lysa Gaboudian:

On July 18, 2023, the Los Angeles Regional Water Quality Control Board (Los Angeles Water Board) received a letter from the Joint Outfall System/Los Angeles County Sanitation Districts (Discharger) requesting a change to the sample type for 1,4-dioxane, perchlorate, 1,2,3-trichloropropane (1,2,3-TCP), and methyl tert-butyl-ether (MTBE) at monitoring location EFF-003, and to change the reporting units for iron at monitoring locations EFF-001, EFF-001A, and EFF-001B. Order No. R4-2021-0131 currently requires 24-hour composite samples for 1,4-dioxane, perchlorate, 1,2,3-TCP, and MTBE at EFF-003. The Discharger requests that these pollutants be collected as grab samples to be consistent with the sample type used at monitoring location EFF-002 and since monitoring results at some monitoring locations are calculated based on the results from EFF-002 and EFF-003. The reporting units required for iron at EFF-001, EFF-001A, and EFF-001B in NPDES Order No. R4-2021-0131 are currently mg/L. The Discharger also requests to change the reporting units for iron to µg/L to be consistent with the required reporting units for all other monitoring locations.

Since 1,4-dioxane, perchlorate, 1,2,3-TCP, and MTBE are specified as grab samples at EFF-002 in NPDES Order R4-2021-0131 and the results from samples collected at EFF-002 and EFF-003 are used to calculate effluent concentrations at EFF-001, EFF-001A, and EFF-001B, the sample type for these pollutants at EFF-002 and EFF-003 should be consistent to provide for more accurate calculated results at EFF-001, EFF-001A, and EFF-001B. Similarly, since the results for EFF-001, EFF-001A, and EFF-001B are calculated using results from EFF-002 and EFF-003, the units for all monitoring locations should also be consistent.

---

NORMA CAMACHO, CHAIR | SUSANA ARREDONDO, EXECUTIVE OFFICER

Since monitoring results at EFF-001, EFF-001A, and EFF-001B are dependent on monitoring conducted at EFF-002 and EFF-003, and to provide consistency to the monitoring requirements in the permit, the Los Angeles Water Board has determined administrative revisions are needed in the MRP. In accordance with section 122.63 of Title 40 of the Code of Federal Regulations, the MRP of Order No. R4-2021-0131 is hereby amended as follows:

1. Table E-5 and E-6 – The sample type for 1,4-dioxane, perchlorate, 1,2,3-TCP, and MTBE shall be changed from 24-hour composite to grab.
2. Table E-3 – The reporting units for iron shall be changed from mg/L to µg/L.

If you have any questions, please contact Danielle Robinson at [danielle.robinson@waterboards.ca.gov](mailto:danielle.robinson@waterboards.ca.gov) or (213) 576-6656, or Steven Webb at [steven.webb@waterboards.ca.gov](mailto:steven.webb@waterboards.ca.gov) or (213) 576-6793.

Sincerely,

*for* Susana Arredondo  
Executive Officer