

Los Angeles Regional Water Quality Control Board

March 26, 2024

Bradshaw Pruitt, Treatment Plant Supervisor
Ojai Valley Sanitary District
1072 Tico Road,
Ojai, CA 93023

ADMINISTRATIVE REVISION TO WASTE DISCHARGE REQUIREMENTS (WDRs) AND NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT – OJAI VALLEY SANITARY DISTRICT – OJAI VALLEY WASTEWATER TREATMENT PLANT, VENTURA, CALIFORNIA (NPDES NO. CA0053961, CI NO. 4245)

Dear Bradshaw Pruitt:

On December 21, 2023, the Los Angeles Regional Water Quality Control Board (Los Angeles Water Board) adopted the NPDES permit Order No. R4-2023-0430 for the Ojai Valley Wastewater Treatment Plant. The Los Angeles Water Board has determined a minor modification to correct a typographical error is needed in Table E-3 of the Monitoring and Reporting Program (MRP) to revise the required effluent sample type for naphthalene from a grab to a 24-hour composite to be consistent with the previous permit. Naphthalene is a polycyclic aromatic hydrocarbon and is fairly stable in the environment; therefore, a 24-hour composite sample will provide a more representative value for naphthalene over the course of a single day. In accordance with section 122.63 of Title 40 of the Code of Federal Regulations, the following administrative revision shall be effective immediately:

Table E-3 of Order No. R4-2023-0430 shall read as follows for naphthalene:

Parameter	Units	Sample Type	Minimum Sampling Frequency	Notes
Naphthalene	µg/L	grab 24-hour composite	quarterly	---

If you have any questions, please contact Steven Webb at Steven.Webb@waterboards.ca.gov or at (213) 576-6793, or Don Tsai at Don.Tsai@waterboards.ca.gov or at (213) 576-6681.

Sincerely,

 Digitally signed by Jenny Newman
Date: 2024.03.26 14:47:27
-07'00'
Water Boards

for Susana Arredondo, Executive Officer
Los Angeles Regional Water Quality Control Board

NORMA CAMACHO, CHAIR | SUSANA ARREDONDO, EXECUTIVE OFFICER