

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION
895 Aerovista Place, Suite 101
San Luis Obispo, California 93401**

MONITORING AND REPORTING PROGRAM NO. R3-2017-0047
Waste Discharger Identification No. 3 421003001

**FOR
CUYAMA COMMUNITY SERVICES DISTRICT
SANTA BARBARA COUNTY
Revised January 19, 2018**

1. ACTIVATED SLUDGE MONITORING

Influent Monitoring - Influent samples shall be taken from a location that provides representative samples of the wastewater quality. At a minimum, influent monitoring shall consist of the following:

Table 1 - Influent Monitoring

Constituent	Units	Sample Type	Sample Frequency	Reporting Frequency
Biochemical Oxygen Demand (BOD ₅)	mg/L	Grab	Quarterly	Quarterly
Total Nitrogen	mg/L	Grab	Quarterly	Quarterly

Effluent Monitoring - Effluent samples shall be taken at an area that represents the effluent quality distributed to the disposal area. At a minimum, effluent monitoring shall consist of the following:

Table 2 - Effluent Monitoring

Constituent	Units	Sample Type	Sample Frequency	Reporting Frequency
Total Flow Rate	MGD	Meter	Continuous	Quarterly
Mean Daily Flow	MGD	Meter	Quarterly	Quarterly
Maximum Daily Flow	MGD	Meter	Quarterly	Quarterly
pH	pH units	Grab	Quarterly	Quarterly
Electrical Conductivity	µmhos/cm	Grab	Quarterly	Quarterly
Biochemical Oxygen Demand (BOD ₅)	mg/L	Grab	Quarterly	Quarterly
Fecal Coliform Bacteria	MPN/100mL	Grab	Quarterly	Quarterly
Total Dissolved Solids (TDS)	mg/L	Grab	Quarterly	Quarterly
Total Suspended Solids (TSS)	mg/L	Grab	Quarterly	Quarterly
Total Nitrogen (Calculated)	mg/L	Grab	Quarterly	Quarterly

Ammonia (NH ₃ as N)	mg/L	Grab	Quarterly	Quarterly
Total Nitrite (NO ₂ as N)	mg/L	Grab	Quarterly	Quarterly
Total Nitrate (NO ₃ as N)	mg/L	Grab	Quarterly	Quarterly
Total Kjeldahl Nitrogen (N)	mg/L	Grab	Quarterly	Quarterly
Standard Minerals ^a	mg/L	Grab	Annually	Annually

MGD = million gallons per day.

µmhos/cm = micro mhos per centimeter.

a Standard minerals will include, at a minimum, the following elements/compounds: boron, calcium, chloride, iron, magnesium, manganese, potassium, sodium sulfate, total alkalinity (including alkalinity series), and hardness.

2. RECYCLED WATER MONITORING

When recycled water is used for irrigation of landscape areas¹, priority pollutant monitoring is required at the production facility. Sampling shall be consistent with the following:

Table 3 – Recycled Water Monitoring Constituent	Sample Frequency	Reporting Frequency
Priority Pollutants	Every 5 years	The next annual report

3. LAND APPLICATION AREA MONITORING

- A. The Discharger shall monitor LAAs when wastewater and/or supplemental irrigation water is applied. If wastewater/supplemental irrigation water is not applied during a reporting period, the monitoring report shall so state. LAA monitoring shall include the following:

Table 4 – Land Application Area Monitoring

Constituent	Units	Sample Type	Sample Frequency	Reporting Frequency
Supplemental Irrigation	gpd	Meter ^a	Monthly	Quarterly
Wastewater Flow ^a	gpd	Meter ^a	Monthly	Quarterly
Local Rainfall	Inches	Weather Station ^b	Monthly	Quarterly
Acreage Applied ^c	Acres	Calculated	Annually	Annually
Application Rate ^d	gal/acre/mo	Calculated	Annually	Annually
Soil Erosion Evidence	--	observation	Monthly	Quarterly
Containment Berm Condition	--	observation	Monthly	Quarterly
Soil Saturation/Ponding	--	observation	Monthly	Quarterly

¹ Landscape areas are defined as parks; greenbelts, playgrounds; school yards; athletic fields; golf courses; cemeteries; residential landscaping; common areas; commercial landscaping (except eating areas); industrial landscaping (except eating areas); freeway, highway, and street landscaping

Nuisance Odors/Vectors	--	observation	Monthly	Quarterly
Discharge Off-Site	--	observation	Monthly	Quarterly
Total Nitrogen Loading Rate	lb/ac/month	Calculated	Annually	Annually

gpd denotes gallons per day.

a. Meter requires meter reading, a pump run time meter, or other approved method.

b. Weather station may be site-specific station or nearby governmental weather reporting station.

c. Acreage applied denotes the acreage to which wastewater is applied.

d. Application rate may also be reported as inch/acre/month.

B. Maintain a log book documenting:

- Irrigation with recycled water did not take place within 150 feet of a domestic (potable) water well.
- Irrigation with recycled water did not take place during the 14-day period immediately prior to harvesting.
- Ongoing employee training which includes:
 - o Proof of routine trainings.
 - o The safe handling of the recycled water and the crop irrigated with recycled water.
 - o Methods for safe crop handling includes irrigation, tending the crop, the harvesting process, and transport of the crop to its final destination.
 - o The use of proper personal protective equipment, hand-washing recommendations (prior to eating, smoking, etc.) and safe transport and re-planting of the harvested crop.
 - o Employee training anytime a new employee is onsite and at routine intervals to maintain a high level of awareness of the potential health impacts of improperly handling disinfected, secondary recycled water.

4. WASTEWATER POND MONITORING

Samples shall be collected at established sampling points opposite the pond inlet for consistency between sampling events. Freeboard shall be measured vertically from the surface of the pond water to the lowest elevation of the surrounding berm, to the nearest 0.1 feet. Pond monitoring shall include, at a minimum:

Table 5 – Wastewater Pond Monitoring

Constituent	Unit	Sample Type	Frequency
Dissolved Oxygen ^a	mg/L	Grab	Monthly
pH	pH units	Grab	Monthly
Freeboard	0.1 feet	Measured	Monthly
Odor	-	Observation	Monthly
Berm Condition	-	Observation	Monthly

a. Samples will be collected at a depth of one foot from each pond in use, opposite the inlet.

5. SOLIDS DISPOSAL MONITORING

The Discharger shall report the handling and disposal of all solids (e.g., screenings, grit, sludge, biosolids, etc.) generated at the wastewater system. Records shall include the name/contact information for the hauling company, the type and amount of waste transported, the date removed from the wastewater system, the disposal facility name and address, and copies of analytical data required by the entity accepting the waste. These records shall be submitted as part of the annual monitoring report.

6. CONFIRMATION THAT FACILITY INSTALLED IS CONSISTENT WITH FACILITY PROPOSED

As built drawings of the constructed facility signed by the engineer. The engineer shall confirm inspections occurred during installation and that the installation conforms with the facility proposed in the Report of Waste Discharge. Submit information with the 2017 annual report.

7. SELF-MONITORING REPORTS (SMRS)

A. Quarterly Reports

Quarterly reports shall be submitted to the Regional Water Board on **the first day of the second month after the quarter ends (May 1st, August 1st, November 1st, and February 1st)**. The reports shall bear the certification and signature of the Discharger's authorized representative. At a minimum, the quarterly reports shall include:

1. Results of all required monitoring.
2. All data collected or calculated over the previous reporting period and a narrative summary of the data.
3. A narrative summary of any surfacing effluent, saturated surface areas, or odors pursuant to Land Application Area Monitoring.
4. A comparison of monitoring data to the discharge specifications, applicable effluent limits, disclosure of any violations of the NOA and/or General Order, and an explanation of any violation of those requirements. (Data shall be presented in tabular format.)
5. Copies of laboratory analytical report(s), quality assurance/quality control sheets, and chain of custody form(s).

B. Annual Report

Annual Reports shall be submitted to the Regional Water Board by **March 1 following the monitoring year**. The Annual Report shall include the following:

1. Tabular and graphical summaries of all monitoring data collected during the year. Duplicate copies of quarterly reports are not necessary and do not fulfill requirements for "summaries."
2. An evaluation of the performance of the wastewater treatment facility, including discussion of capacity issues, nuisance conditions, system problems, and a forecast of the flows anticipated in the next year. A flow rate evaluation as described in the General Order (Provision E.2.c) shall also be submitted.
3. A discussion of compliance (any and all incidents of non-compliance) and the corrective action taken, as well as any planned or proposed actions needed to bring the discharge into compliance with the NOA and/or General Order.
4. A discussion of any data gaps and potential deficiencies/redundancies in the monitoring system or reporting program.
5. The name and contact information for the wastewater operator(s) responsible for operation, maintenance, and system monitoring. Please include corresponding certification levels.
6. Summary of solids disposal monitoring.
7. Summary of collection system management plans, or reference report submitted under separate cover as required by this or separate sanitary sewer requirements.
8. A letter transmitting the monitoring reports shall accompany each report. The letter shall report violations found during the reporting period, and actions taken or planned to correct the violations and prevent future violations. The transmittal letter shall contain the following penalty of perjury statement and shall be signed by the Discharger or the Discharger's authorized agent:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of the those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."
9. The Discharger shall implement the above monitoring program as of the date of this MRP.

6. ELECTRONIC SUBMITTAL

1. Electronically submit all reports/documents and laboratory data to the State Water Board's

GeoTracker² database for the Cuyama Community Services District, Santa Barbara County site GeoTracker No. WDR100039801 over the internet at:

http://www.waterboards.ca.gov/ust/electronic_submittal/index.shtml.

Table 6 below summarizes all the electronic reporting requirements. Staff may request submittal of some documents on paper, particularly drawings or maps that require a large size to be readable, or in other electronic formats where evaluation of data is required.

Table 6 – GeoTracker Electronic Submittal Information (ESI) Data Requirements

Electronic Submittal	Description of Action	Action	Frequency
Reports and documents	Complete copy of all documents including monitoring reports (in searchable PDF format) and any other associated documents related to the facility.	Upload directly to GeoTracker all monitoring reports (in searchable PDF format) and any other associated documents.	On or before the due dates required by this Order and for other documents when requested by Water Board staff.
Laboratory Data	All analytical data (including geochemical data) in electronic deliverable format (EDF). This includes all water, soil, and vapor samples collected when monitoring a discharge.	Direct your State Certified Laboratory staff to upload all laboratory data directly to GeoTracker.	On or before the due date of the required monitoring report.
Depth to groundwater	Monitoring wells must have the depth-to-water information reported. Report data only for wells defined as permanent sampling points.	Upload depth-to-water information to the Geotracker GEO_WELL file.	On or before the due date of the required monitoring report.
Boring Logs and Well Screen intervals	Boring logs must be prepared by a registered professional and submitted in PDF format	Upload boring logs (in searchable PDF format) to Geotracker	Every time a new boring is drilled.

² Information for first-time users is available here:
https://www.waterboards.ca.gov/ust/electronic_submittal/docs/beginnerguid2.pdf

Electronic Submittal	Description of Action	Action	Frequency
	separately (not only as attachments to reports)	whenever a new boring is drilled.	
Location Data (Geo XY)	Survey and mark all permanent sampling locations (i.e., monitoring wells, drinking water wells, and permanent influent/effluent sampling locations). These data points are required prior to laboratory data uploads.	Upload the survey data to the Geotracker Geo_XY file.	Every time a permanent monitoring point is established.
Elevation Data (Geo Z)	Survey and mark the elevation at the top of groundwater well casings for all permanent groundwater wells. These points are required prior to depth-to-water data uploads.	Upload the survey data to the Geotracker GEO_Z file.	One-time, for all groundwater monitoring wells.
Geo Map	Site layout, map of facilities, wastewater treatment system, and disposal area(s).	Upload the Site layout PDF to the Geotracker site plan file.	Year one and every five years thereafter and when the facilities are modified.

- 2. Other Reports** - The Discharger shall report the results of any special studies, monitoring, and reporting required by the NOA and/or General Order. The Discharger shall submit such reports consistent with dates identified in this MRP.

Ordered by: _____
for John M. Robertson, Executive Officer

Date: January 19, 2018